



**SPIRE & PACS  
Sorption Coolers  
FMECA**

DOC N°: HSO-SBT-RP-008  
Iss/Rev : 1.0  
DATE : 29/10/2001  
PAGE : i

**SERVICE DES BASSES TEMPERATURES [CEA/DSM/DRFMC/SBT]**

***SPIRE & PACS Sorption Coolers  
FMECA***

SBT internal ref : SBT/CT/2001-XX

|                         | Name & Function                        | Date | Signature |
|-------------------------|--|------|-----------|
| <b>Prepared</b>         | LMG Consultant                         |      |           |
| <b>SBT PA Check</b>     | P. Dupont – Cooler PA manager          |      |           |
| <b>SPIRE Approval</b>   |  |      |           |
| <b>PACS Approval</b>    |  |      |           |
| <b>PA Approval</b>      | F. Loubere – PA manager                |      |           |
| <b>Project Approval</b> | J.L Augueres - SAp HSO project manager |      |           |
| <b>Project Approval</b> | L. Duband - Cooler project manager     |      |           |

Service des Basses Températures (SBT)  
Département de Recherche Fondamentale sur la Matière Condensée (DRFMC)  
COMMISSARIAT A L'ENERGIE ATOMIQUE - GRENOBLE (CEA-Grenoble)  
17, rue des Martyrs 38054 GRENOBLE Cédex 9, France.



Référence : R\_00.224\_02

Index : D

Date : 2001-10-01

**CEA**

\*\*\*\*\*

# **CRYOGENIC SORPTION COOLER**

\*\*\*\*\*

**FMECA REPORT**

|                    |                    |
|--------------------|--------------------|
| <b>Prepared by</b> | Bruno COLLERAIS    |
| <b>Verified by</b> | Michel MONTEILLARD |

**Resume** : This document contains the FMECA report of the cryogenic sorption cooler.

**Cryogenic Sorption Cooler**  
*FMECA Report*

| <b>REVISIONS</b> |  |            |                            |
|------------------|--|------------|----------------------------|
| REV              | RAISON DE L'EVOLUTION / <i>CHANGE REASON</i>                       | DATE       | APPROUVE / <i>APPROVED</i> |
| A                | Creation   | 2001-01-25 | LGM Consultants            |
| B                | Update of the document   | 2001-02-20 | LGM Consultants            |
| C                | Integration of modifications due to the new architectural analysis | 2001-06-06 | LGM Consultants            |
| D                | Update of the document   | 2001-10-01 | LGM Consultants            |

**Cryogenic Sorption Cooler**  
*FMECA Report*

**TABLE OF CONTENTS**

|           |   |           |
|-----------|---|-----------|
| <b>1.</b> | <b>PURPOSE .....</b>  | <b>5</b>  |
| <b>2.</b> | <b>APPLICABLE DOCUMENTS .....</b>                                   | <b>6</b>  |
| <b>3.</b> | <b>TERMS AND ACRONYMS.....</b>                                      | <b>7</b>  |
| <b>4.</b> | <b>FAILURE MODES, EFFECTS AND CRITICALITY ANALYSIS (FMECA).....</b> | <b>8</b>  |
| 4.1       | GENERAL .....   | 8         |
| 4.2       | DESCRIPTION OF FMECA COLUMNS .....                                  | 9         |
| 4.3       | SYSTEM EFFECTS LIST .....   | 9         |
| 4.4       | DETECTABILITY.....  | 9         |
| 4.5       | SYSTEM FAILURE EFFECT GRAVITY .....                                 | 10        |
| 4.6       | OCCURRENCE RATE MATRIX .....  | 11        |
| 4.7       | CRITICALITY MATRIX .....  | 11        |
| <b>5.</b> | <b>SYNTHESIS .....</b>  | <b>12</b> |

# **Cryogenic Sorption Cooler**

## ***FMECA Report***

### **1. Purpose**

The cooling of the SPIRE and PACS detectors down to 300 mK will be effected by a helium three sorption cooler. This sub-Kelvin sorption cooler provides a wide range of heat lift capability at temperature below 400 mK. It relies on the capability of porous materials to adsorb or release a gas when cyclically cooled or heated. Using this physical process one can design a compressor/pump which by managing the gas pressure in a closed system, can condense liquid at some appropriate location and then perform an evaporative pumping on the liquid bath to reduce its temperature. Helium sorption refrigerators have no moving parts, are vibration less and can be designed to be self contained and compact with a high duty cycle efficiency.

The present document introduces the Failure Modes and Effects and Criticality (FMECA) analysis of the system Cryogenic Sorption Cooler (Except Electronic Part).

## Cryogenic Sorption Cooler *FMECA Report*

### 2. Applicable documents

|     | <b>Title</b>  | <b>Author</b>         | <b>Reference</b>                  | <b>Date</b> |
|-----|---|-----------------------|-----------------------------------|-------------|
| AD1 | Instrument Requirements Document                            | B. Swinyard           | SPIRE-RAL-N-0034 Issue 1.0        | 23 Nov. 00  |
| AD2 | ICD Structure cooler  | L. Duband & B. Winter | SPIRE-MSS-PRJ-000331              | 13 June 00  |
| AD3 | SPIRE & PACS sorption cooler specifications                 | L. Duband             | SBT/CT/2000-18 Issue 2.2          | 23 Nov. 00  |
| AD4 | Instrument interface document – Part B - Instrument “SPIRE” | ESA                   | SCI-PT-IIDB/SPIRE-02124 Issue 1.0 | 1 Sept. 00  |
| AD5 | Instrument interface document – Part B - Instrument “PACS”  | A. Heske              | SCI-PT-IIDB/PACS-02126 Issue 0.5  | 17 July 00  |
| AD6 | Architectural Analysis Report                               | LGM Consultants       | R_00_224_01 Index D               | 01 Oct. 01  |

# Cryogenic Sorption Cooler

## *FMECA Report*

### **3. Terms and Acronyms**

AD : Applicable Document  
CEA : Commissariat à l' Energie Atomique  
ESA : European Spatial Agency  
ETF : Environment Test Facility  
EV : Evaporator  
HSE : Heat Switch on Evaporator  
HSP : Heat Switch on sorption Pump  
MTTF : Mean Time To Failure  
N/A : Not Applicable  
RAL : TBD  
RBD : Reliability Block Diagram  
SBT : Service des Basses Températures  
SCO : Sorption Cooler (full unit)  
SP : Sorption Pump  
SST : Support Structure  
TBD : To Be Defined  
TS : Thermal Shunt

# Cryogenic Sorption Cooler

## FMECA Report

### 4. Failure Modes, Effects and Criticality Analysis (FMECA)

#### 4.1 General

The FMECA is based on a hardware approach from the architectural analysis previously performed (see AD6).

The component indenture level is the lowest indenture level from which the effects on the items of the upper indenture levels are determined.

The hereafter block functions are decomposed :

| System functions  | Function description   | Components  |
|-------------------|--|---|
| Gas enclosure     | Maintains a given volume of gas (He3)  | Sorption Pump<br>Pumping Line<br>Evaporator                       |
| Command/Control   | Establishes or interrupt thermal conduction between Cold sources and Sorption Pump or Evaporator | Heat Switch Pump<br>Heat Switch Evaporator<br>Connectors<br>Wires |
| Support Structure | Mechanically interfaces the SCO with its external environment and ensures its thermal isolation  | Support Structure   |

In order to fill in the FMECA tables, the following hypothesis have been assumed :

1. The analysed system architecture is supposed to have passed all the environmental and functional test described in chapter 4.2 LIFE PROFILE TABLE of AD6 with success, thus leading to the qualification of the architecture.
2. Each system is assumed to be manufactured, assembled and verified, according to the document : SPIRE and PACS Sorption Cooler Manufacturing, Assembly and Verification Flow Chart. Then, all potential failure that might occur due to the bad application of the manufacturing procedure mentioned above are not considered in the present FMECA report.



# Cryogenic Sorption Cooler

## FMECA Report

### 4.2 Description of FMECA Columns

The columns of the FMEA are described in the following table :

|  |  |
|--|--|
| Block ref.   | Reference of the concerned block function  |
| Functional block                                   | The name of the functional block   |
| Location   | The location of the concerned component  |
| Mission phase                                      | The phase of the mission when the failure occurs   |
| Failure Mode                                       | The Failure modes of the component   |
| Cause  | The component failure mode cause   |
| Primary failure effect                             | The failure effect at the technical function level   |
| System failure Effect                              | The effect of the failure at the SCO level   |
| G  | The gravity of the system failure effect (from the gravity matrix)   |
| D  | The detectability of the failure   |
| O  | The probability of occurrence of the failure (from the occurrence matrix)  |
| C  | The criticality of the failure (from the criticality matrix)   |
| Preventive action                                  | The action to provide to prevent failure   |
| Criticality after application of corrective action | The value of the criticality of the failure, once the potential corrective action will be applied to the system (manufacturing or testing) |
| Remarks  | Remarks  |

### 4.3 System effects list

The failure effects at the system level that have been identified through the application of the FMECA process are the following :

| <i>Line N°</i> | <i>Failure effect on system designation</i> |
|----------------|---|
| 1              | No effect                                   |
| 2              | Loss of system functionality                |
| 3              | System efficiency reduction                 |

### 4.4 Detectability

The detectability column has been completed according to the fact that the considered failure is able to be detected by one of the test to which the system will be submitted before launching or not.

Detectability of a failure that might occur after launch has no importance because there will be no way after launch to fix this failure.

The detectability matrix is consecutively presented in the hereafter table :

| Detectability | Signification  |
|---------------|--|
| 0             | Failure is detected in functional tests and efficiency measurements phases |
| 1             | Failure is not detected  |

# Cryogenic Sorption Cooler

## FMECA Report

### 4.5 System failure effect gravity

This column contains an evaluation of the gravity of each system failure effect, dedicated to allow the failure criticality for the system.

| <i>Gravity</i> | <i>Signification</i> |
|----------------|----------------------|
| 0              | No effect            |
| 1              | Minor                |
| 2              | Major                |
| 3              | Catastrophic         |

The meaning of these different gravity parameters have to be understood in the following way with regards to the function realised by the Sorption Cooler :

No effect signify that the effect engendered by the considered failure is negligible and has no impact neither on the efficiency of the system, nor on the mission life duration.

Minor signifies that the effect engendered by the considered failure can affect, either the efficiency of the system which might then only be able to cool down the instruments at a temperature a bit higher than the 300 mK expected leading to a lower sensitivity of the detectors, either the mission life duration which would be shortened by a factor of maximum 20%.

Major signifies that the effect engendered by the considered failure would affect the efficiency of the system or the mission life duration in such a way that it would be unacceptable (abortion of the mission).

Catastrophic signifies that the effect engendered by the considered failure would affect the integrity of the spacecraft.

# Cryogenic Sorption Cooler

## FMECA Report

### 4.6 Occurrence rate matrix

This matrix is indicating the probability of occurrence of the considered component failure mode.

| Failure sensitivity : |   |
|-----------------------|---|
| 1                     | Very Improbable : Failure rate (FR) < $10^{-9}$ /hour |
| 2                     | Possible : $10^{-9}$ <FR< $10^{-8}$                   |
| 3                     | Probable : $10^{-8}$ <FR< $10^{-7}$                   |
| 4                     | Very Probable : $10^{-7}$ <FR< $10^{-6}$              |

Based on the hypothesis mentioned in § 4.1 of this document, it has been considered the following :

1. Concerning all structural mechanical components of the system, like those of the Support Structure, screws, pulleys, etc, the probability of occurrence associated to their main failure mode which is “break” is assumed to be highly improbable which means much lower than  $10^{-9}$ /hour.
2. Concerning electronics components such as thermometers, heaters, wires and connectors, a dimensioning hypothesis has been taken, that is their failure modes have been considered possible (< $10^{-8}$ )
3. Concerning all the weldings and solderings of mechanical parts of the system, it is assumed that, known that the system is supposed to have passed all the environmental test with success, which then lead to the assembly process qualification, the probability of occurrence of a failure on these elements is very improbable.
4. Concerning the Kevlar cord, by lack of information and test results at the time this document is written, a conservative hypothesis has been taken, that is the probability of occurrence of its failure modes is considered to be Probable.

### 4.7 Criticality matrix

The criticality associated to a failure mode of a component is given by the value of the gravity, the probability of occurrence and the testability of the failure mode.

This parameter allows to identify the failure modes of the system which are unacceptable and need that some actions might be taken in order to reduce their criticality to an acceptable level. (which is the main objective of a FMECA process).

In the present analysis, it has been considered the following :

1. Criticality associated to a given failure mode is equal to the product of its gravity and probability of occurrence if necessary multiplied by two in the case where this failure mode would not be detectable before launch
2. Criticality values equal or greater than 4 are considered to be unacceptable and necessitates that a corrective action should be applied to the system.

# **Cryogenic Sorption Cooler**

## ***FMECA Report***

### **5. Synthesis**

The analysis of the FMECA tables which are presented in annex A of the present document shows that, excepted for the Kevlar cord, the proposed architecture of the system does not present any weakness necessitating to apply modifications.

Effectively, the tables does not show any failure mode criticality above the fixed threshold of “4” which points out that no particular improvement need to be considered.

Considering the Kevlar cord which is known since the beginning of this project to be the weak point of the Sorption Cooler (not because one might think that there is a high risk of failure on this particular component but just because of the lack of field experience of this material at such temperatures for a long period of time), specific actions are already engaged in order to demonstrate, either its compliance with the requirements of the system for the whole life mission duration, either the necessity to find how the suspension system should be modified in order to reach an acceptable criticality level.

**Cryogenic Sorption Cooler**  
*FMECA Report*

**ANNEX A**

**FMECA TABLES**

| Block ref. | Functional block | Part                                     | Location      | Failure mode               | Cause        | Primary failure effect   | System failure effect  | D | G | O | C | Corrective action | Criticality after corrective action | Remarks                               |
|------------|------------------|--|---------------|----------------------------|--------------|--|--|---|---|---|---|-------------------|-------------------------------------|---------------------------------------|
| 100        | Gas Enclosure    | 1/2 male pump                            | sorption pump | Loss of hermeticity        | part failure | Gas leakage  | Loss of system functionality   | 0 | 2 | 1 | 2 | N/A               |                                     |                                       |
| 100        | Gas Enclosure    | 1/2 female pump                          | sorption pump | Loss of hermeticity        | part failure | Gas leakage  | Loss of system functionality   | 0 | 2 | 1 | 2 | N/A               |                                     |                                       |
| 100        | Gas Enclosure    | Pulleys and pulley screws                | sorption pump | break                      | part failure | Gas enclosure badly maintained                                       | probable destruction of the system leading to the loss of system functionality | 0 | 2 | 1 | 2 | N/A               |                                     | Not applicable                        |
| 100        | Gas Enclosure    | Charcoal casing                          | sorption pump | break                      | part failure | Unability to transmit cooling and/or heating to the charcoal pellets | Loss of system functionality   | 0 | 2 | 1 | 2 | N/A               |                                     |                                       |
| 100        | Gas Enclosure    | Active charcoal pellets                  | sorption pump | No failure mode identified | N/A          | N/A  | N/A  | 0 | 0 | 0 | 0 | N/A               |                                     |                                       |
| 100        | Gas Enclosure    | Stycast glue                             | sorption pump | loss of gluing properties  | part failure | Unability to transmit cooling and/or heating to the charcoal pellets | Loss of system functionality   | 1 | 2 | 1 | 2 | N/A               |                                     |                                       |
| 100        | Gas Enclosure    | Grid mesh                                | sorption pump | No failure mode identified | N/A          | N/A  | N/A  | 0 | 0 | 0 | 0 | N/A               |                                     |                                       |
| 100        | Gas Enclosure    | Grid ring                                | sorption pump | No failure mode identified | N/A          | N/A  | N/A  | 0 | 0 | 0 | 0 | N/A               |                                     |                                       |
| 100        | Gas Enclosure    | Pump cold tip                            | sorption pump | break                      | part failure | Unability to transmit cooling and/or heating to the charcoal pellets | Loss of system functionality   | 0 | 2 | 1 | 2 | N/A               |                                     |                                       |
| 100        | Gas Enclosure    | Heater                                   | sorption pump | open circuit               | part failure | Loss of SP heating capability on one channel                         | Loss of system redundancy  | 0 | 1 | 2 | 2 | N/A               |                                     | Heaters are redounded on the SP.      |
| 100        | Gas Enclosure    | Thermometer                              | sorption pump | open circuit               | part failure | Loss of SP temperature measurement capability on one channel         | Loss of system redundancy  | 0 | 1 | 2 | 2 | N/A               |                                     | Thermometers are redounded on the SP. |
| 100        | Gas Enclosure    | External shape weld (Electron beam weld) | sorption pump | Loss of hermeticity        | part failure | Gas leakage  | Loss of system functionality   | 0 | 2 | 1 | 2 | N/A               |                                     |                                       |
| 100        | Gas              | Pumping line                             | sorption pump | Loss of                    | part         | Gas leakage  | Loss of system   | 0 | 2 | 1 | 2 | N/A               |                                     |                                       |

## Cryogenic Sorption Cooler

### FMECA Report

| Block ref. | Functional block | Part                      | Location      | Failure mode        | Cause        | Primary failure effect   | System failure effect  | D | G | O | C | Corrective action | Criticality after corrective action | Remarks  |
|------------|------------------|---------------------------|---------------|---------------------|--------------|--|--|---|---|---|---|-------------------|-------------------------------------|--|
|            | Enclosure        | weld (Electron beam weld) |               | hermeticity         | failure      |  | functionality  |   |   |   |   |                   |                                     |  |
| 100        | Gas Enclosure    | SP Heat exchanger solder  | sorption pump | break               | part failure | Unability to transmit cooling and/or heating to the charcoal pellets | Loss of system functionality   | 0 | 2 | 1 | 2 | N/A               |                                     |  |
| 100        | Gas Enclosure    | Evaporator tube           | Pumping line  | Loss of hermeticity | part failure | Gas leakage  | Loss of system functionality   | 0 | 2 | 1 | 2 | N/A               |                                     |  |
| 100        | Gas Enclosure    | Pump outgoing tube        | Pumping line  | Loss of hermeticity | part failure | Gas leakage  | Loss of system functionality   | 0 | 2 | 1 | 2 | N/A               |                                     |  |
| 100        | Gas Enclosure    | Sleeve                    | Pumping line  | Loss of hermeticity | part failure | Gas leakage  | Loss of system functionality   | 0 | 2 | 1 | 2 | N/A               |                                     | Not applicable   |
| 100        | Gas Enclosure    | Shunt                     | Pumping line  | Loss of hermeticity | part failure | Gas leakage  | Loss of system functionality   | 0 | 2 | 1 | 2 | N/A               |                                     |  |
| 100        | Gas Enclosure    | Filling pipe              | Pumping line  | Loss of hermeticity | part failure | Gas leakage  | Loss of system functionality   | 0 | 2 | 1 | 2 | N/A               |                                     |  |
| 100        | Gas Enclosure    | Thermometers              | Pumping line  | open circuit        | part failure | Loss of pumping line shunt temperature measurement on one channel    | No effect  | 0 | 0 | 2 | 0 | N/A               |                                     | The shunt thermometer has no effective rôle in the regulation of the system (there is no heater associated to this thermometer) and moreover, the shunt thermometer is redounded |
| 100        | Gas Enclosure    | Shunt weld                | Pumping line  | Loss of hermeticity | part failure | Gas leakage  | Loss of system functionality   | 0 | 2 | 1 | 2 | N/A               |                                     |  |
| 100        | Gas Enclosure    | Filling pipe weld         | Pumping line  | Loss of hermeticity | part failure | Gas leakage  | Loss of system functionality   | 0 | 2 | 1 | 2 | N/A               |                                     |  |
| 100        | Gas Enclosure    | 1/2 female evaporator     | Evaporator    | Loss of hermeticity | part failure | Gas leakage  | Loss of system functionality   | 0 | 2 | 1 | 2 | N/A               |                                     |  |
| 100        | Gas Enclosure    | 1/2 male evaporator       | Evaporator    | Loss of hermeticity | part failure | Gas leakage  | Loss of system functionality   | 0 | 2 | 1 | 2 | N/A               |                                     |  |
| 100        | Gas Enclosure    | Pulleys and pulley screws | Evaporator    | break               | part failure | Gas enclosure badly maintained                                       | probable destruction of the system leading to the loss of system functionality | 0 | 2 | 1 | 2 | N/A               |                                     | Not applicable   |
| 100        | Gas              | 1/2 female cup            | Evaporator    | No failure          | N/A          | N/A  | N/A  | 0 | 0 | 0 | 0 | N/A               |                                     |  |

## Cryogenic Sorption Cooler

### FMECA Report

| Block ref. | Functional block         | Part                    | Location   | Failure mode               | Cause        | Primary failure effect  | System failure effect        | D | G | O | C | Corrective action | Criticality after corrective action | Remarks                               |
|------------|--------------------------|-------------------------|------------|----------------------------|--------------|---|------------------------------|---|---|---|---|-------------------|-------------------------------------|---------------------------------------|
|            | Enclosure                | evaporator              |            | mode identified            |              |   |                              |   |   |   |   |                   |                                     |                                       |
| 100        | Gas Enclosure            | 1/2 male cup evaporator | Evaporator | No failure mode identified | N/A          | N/A   | N/A                          | 0 | 0 | 0 | 0 | N/A               |                                     |                                       |
| 100        | Gas Enclosure            | Procelit (foam)         | Evaporator | No failure mode identified | N/A          | N/A   | N/A                          | 0 | 0 | 0 | 0 | N/A               |                                     |                                       |
| 100        | Gas Enclosure            | Evaporator cold tip     | Evaporator | Break                      | part failure | Loss of the ability to transmit the cooling to the instrumens | Loss of system functionality | 0 | 2 | 1 | 2 | N/A               |                                     |                                       |
| 100        | Gas Enclosure            | Thermometer             | Evaporator | open circuit               | part failure | Loss of EV temperature measurement on one channel             | Loss of system redundancy    | 0 | 1 | 2 | 2 | N/A               |                                     | Thermometers are redounded on the EV. |
| 100        | Gas Enclosure            | External shape weld     | Evaporator | Loss of hermeticity        | part failure | Gas leakage   | Loss of system functionality | 0 | 2 | 1 | 2 | N/A               |                                     |                                       |
| 100        | Gas Enclosure            | Pumping line weld       | Evaporator | Loss of hermeticity        | part failure | Gas leakage   | Loss of system functionality | 0 | 2 | 1 | 2 | N/A               |                                     |                                       |
| 100        | Gas Enclosure            | EV cold tip solder      | Evaporator | break                      | part failure | Loss of the ability to transmit the cooling to the instrumens | Loss of system functionality | 0 | 2 | 1 | 2 | N/A               |                                     |                                       |
| 200        | Command / Control system | Mini pump               | HSP/HSE    | Loss of hermeticity        | part failure | Gas leakage   | Loss of system functionality | 0 | 2 | 1 | 2 | N/A               |                                     |                                       |
| 200        | Command / Control system | Active charcoal parts   | HSP/HSE    | No failure mode identified | N/A          | N/A   | N/A                          | 0 | 0 | 0 | 0 | N/A               |                                     |                                       |
| 200        | Command / Control system | Mini pump cap           | HSP/HSE    | No failure mode identified | N/A          | N/A   | N/A                          | 0 | 0 | 0 | 0 | N/A               |                                     |                                       |
| 200        | Command / Control system | Mini pump tube          | HSP/HSE    | Loss of hermeticity        | part failure | Gas leakage   | Loss of system functionality | 0 | 2 | 1 | 2 | N/A               |                                     |                                       |
| 200        | Command / Control system | Pumping line weld       | HSP/HSE    | Loss of hermeticity        | part failure | Gas leakage   | Loss of system functionality | 0 | 2 | 1 | 2 | N/A               |                                     |                                       |
| 200        | Command /                | Glue                    | HSP/HSE    | loss of gluing             | part         | Unability to transmit   | Loss of system               | 0 | 2 | 1 | 2 | N/A               |                                     |                                       |



# Cryogenic Sorption Cooler

## FMECA Report

| Block ref. | Functional block         | Part                     | Location    | Failure mode               | Cause        | Primary failure effect   | System failure effect        | D | G | O | C | Corrective action | Criticality after corrective action | Remarks                                    |
|------------|--------------------------|--------------------------|-------------|----------------------------|--------------|--|------------------------------|---|---|---|---|-------------------|-------------------------------------|--|
|            | Control system           |                          |             | properties                 | failure      | cooling and/or heating to the charcoal pellets                 | functionality                |   |   |   |   |                   |                                     |  |
| 200        | Command / Control system | Heater                   | HSP/HSE     | open circuit               | part failure | Loss of HSP or HSE mini pump heating capability on one channel | Loss of system redundancy    | 0 | 1 | 2 | 2 | N/A               |                                     | Heaters are redounded on the HSP/HSE.      |
| 200        | Command / Control system | Thermometer              | HSP/HSE     | open circuit               | part failure | Loss of HSP or HSE temperature measurement on one channel      | Loss of system redundancy    | 0 | 1 | 2 | 2 | N/A               |                                     | Thermometers are redounded on the HSP/HSE. |
| 200        | Command / Control system | Thermal shunt            | HSP/HSE     | Loss of hermeticity        | part failure | Gas leakage  | Loss of system functionality | 0 | 2 | 1 | 2 | N/A               |                                     |  |
| 200        | Command / Control system | Filling pipe             | HSP/HSE     | Loss of hermeticity        | part failure | Gas leakage  | Loss of system functionality | 0 | 2 | 1 | 2 | N/A               |                                     |  |
| 200        | Command / Control system | Filling pipe weld        | HSP/HSE     | Loss of hermeticity        | part failure | Gas leakage  | Loss of system functionality | 0 | 2 | 1 | 2 | N/A               |                                     |  |
| 200        | Command / Control system | Copper braid             | HSP/HSE     | No failure mode identified |              | N/A  | N/A                          | 0 | 0 | 0 | 0 | N/A               |                                     |  |
| 200        | Command / Control system | Copper switch head       | HSP/HSE     | No failure mode identified |              | N/A  | N/A                          | 0 | 0 | 0 | 0 | N/A               |                                     |  |
| 200        | Command / Control system | Thermal shunt weld       | HSP/HSE     | Loss of hermeticity        | part failure | Gas leakage  | Loss of system functionality | 0 | 2 | 1 | 2 | N/A               |                                     |  |
| 200        | Command / Control system | Connectors               | Lower plate | open circuit               | part failure | Loss of one command/control channel                            | Loss of system redundancy    | 0 | 1 | 2 | 2 | N/A               |                                     | Loss of system redundancy                  |
| 200        | Command / Control system | Wires                    | N/A         | Open circuit               | part failure | Loss of one heater or thermometer functionality on one channel | Loss of system redundancy    | 0 | 1 | 2 | 2 | N/A               |                                     | Loss of system redundancy                  |
| 200        | Command / Control system | Anti-vibration interface | HSP         | No failure mode identified | N/A          | N/A  | N/A                          | 0 | 0 | 0 | 0 | N/A               |                                     |  |

## Cryogenic Sorption Cooler FMECA Report

| Block ref. | Functional block         | Part                           | Location          | Failure mode               | Cause        | Primary failure effect   | System failure effect  | D | G | O | C | Corrective action | Criticality after corrective action | Remarks   |
|------------|--------------------------|--------------------------------|-------------------|----------------------------|--------------|--|--|---|---|---|---|-------------------|-------------------------------------|---|
| 200        | Command / Control system | Anti-vibration interface screw | HSP/HSE           | Break                      | part failure | Loss of one of the two screws maintaining the anti vibration interface | No effect  | 0 | 1 | 1 | 1 | N/A               |                                     | All mechanical elements fixations are redounded with two screws |
| 300        | Support Structure        | End plate                      | Support structure | No failure mode identified | N/A          | N/A  | N/A  | 0 | 0 | 0 | 0 | N/A               |                                     |   |
| 300        | Support Structure        | Lower plate                    | Support structure | No failure mode identified | N/A          | N/A  | N/A  | 0 | 0 | 0 | 0 | N/A               |                                     |   |
| 300        | Support Structure        | Upper plate                    | Support structure | No failure mode identified | N/A          | N/A  | N/A  | 0 | 0 | 0 | 0 | N/A               |                                     |   |
| 300        | Support Structure        | Lateral plate                  | Support structure | No failure mode identified | N/A          | N/A  | N/A  | 0 | 0 | 0 | 0 | N/A               |                                     |   |
| 300        | Support Structure        | Lateral plate mounting side    | Support structure | No failure mode identified | N/A          | N/A  | N/A  | 0 | 0 | 0 | 0 | N/A               |                                     |   |
| 300        | Support Structure        | Evaporator bracket             | Support structure | No failure mode identified | N/A          | N/A  | N/A  | 0 | 0 | 0 | 0 | N/A               |                                     |   |
| 300        | Support Structure        | Pump bracket                   | Support structure | No failure mode identified | N/A          | N/A  | N/A  | 0 | 0 | 0 | 0 | N/A               |                                     |   |
| 300        | Support Structure        | Pulleys screws                 | Support structure | Break                      | part failure | Gas enclosure badly maintained   | probable destruction of the system leading to the loss of system functionality | 0 | 2 | 1 | 2 | N/A               |                                     |   |
| 300        | Support Structure        | Perforated pulleys screws      | Support structure | Break                      | part failure | Gas enclosure badly maintained   | probable destruction of the system leading to the loss of system functionality | 0 | 2 | 1 | 2 | N/A               |                                     |   |
| 300        | Support Structure        | Ratchet wheel                  | Support structure | Break                      | part failure | Gas enclosure badly maintained   | probable destruction of the system leading to the loss of system functionality | 0 | 2 | 1 | 2 | N/A               |                                     |   |
| 300        | Support                  | Tensioning                     | Support           | Break                      | part         | Gas enclosure badly  | probable destruction   | 0 | 2 | 1 | 2 | N/A               |                                     |   |

## Cryogenic Sorption Cooler

### FMECA Report

| Block ref. | Functional block  | Part             | Location          | Failure mode               | Cause        | Primary failure effect         | System failure effect  | D | G | O | C | Corrective action   | Criticality after corrective action | Remarks |
|------------|-------------------|------------------|-------------------|----------------------------|--------------|--------------------------------|--|---|---|---|---|---|-------------------------------------|---------|
|            | Structure         | pulleys          | structure         |                            | failure      | maintained                     | of the system leading to the loss of system functionality                      |   |   |   |   |   |                                     |         |
| 300        | Support Structure | Pawl             | Support structure | Break                      | part failure | Gas enclosure badly maintained | probable destruction of the system leading to the loss of system functionality | 0 | 2 | 1 | 2 | N/A   |                                     |         |
| 300        | Support Structure | Kevlar cord      | Support structure | Break                      | part failure | Gas enclosure badly maintained | probable destruction of the system leading to the loss of system functionality | 0 | 2 | 2 | 4 | Vibration test might be performed in order to verify the influence of the rupture of one of the four Kevlar cords | TBD                                 |         |
|            |                   |                  |                   | Lengthening                | part ageing  | Gas enclosure badly maintained | probable destruction of the system leading to the loss of system functionality | 1 | 2 | 2 | 8 | A tool must be designed to be able to measure the tension of each portion of the Kevlar cord                      | TBD                                 |         |
| 300        | Support Structure | Centering screws | Support structure | No failure mode identified | N/A          | N/A                            | N/A  | 0 | 0 | 0 | 0 | N/A   |                                     |         |