

| | | |
|-------------------------------------|---|---|
| CARDIFF UNIVERSITY |  | Ref.:HSO-CDF-EIDP-059 Issue: 1.0 Date:2 November 2004 Page 1 of 66 |
| SPIRE Instrument PFM Filters | | |

End Item Data Package (EIDP)

SPIRE Instrument PFM Filters

SPIRE Ref.: SPIRE-UCF-

Cardiff Ref.: HSO-CDF-EIDP-059

22 October 2004

Prepared by: Peter Hargrave & Carole Tucker

Approved by: Ian Walker

Distribution list

| | | | |
|-----|----------------|---------|----------------|
| RAL | Bruce Swinyard | Cardiff | Peter Ade |
| | Eric Sawyer | | Matt Griffin |
| | Eric Clark | | Peter Hargrave |
| | Doug Griffin | | Carole Tucker |
| | | | Ian Walker |
| | | | |
| | | | |
| | | | |

Change Record

| Issue | Section | Date | Changes |
|-------|---------|----------|---------------------------------|
| 0.1 | | 02/03/04 | First draft for approval at DRB |
| 1.0 | | 22/10/04 | Delivery release |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

Table of contents

| Section | Contents | Req. | Comments |
|---------|---|------|----------|
| 1 | Shipping Documents | X | |
| 2 | Transportation, Packing, Handling & Integration Procedures | X | |
| 3 | Certificate of Conformance / Delivery Review Board MoM Ai-Lists | X | |
| 4 | Qualification Status List / Test Matrix | X | |
| 5 | Top Level Drawings (inc. Family Tree) | | |
| 6 | Interface Drawings | X | |
| 7 | Functional, Block & Mechanical Drawings | | |
| 8 | Electrical Circuit Drawings | | |
| 9 | As Built Parts List | X | |
| 10 | Serialised Components List | | |
| 11 | List of Waivers | | |
| 12 | Copies of Waivers | | |
| 13 | Operational Manual | | |
| 14 | Historical Record | X | |
| 15 | Logbook / Diary of Events | X | |
| 16 | Operating Time / Cycle Record | X | |
| 17 | Connector Mating Record | | |
| 18 | Age Sensitive Items Record | | |
| 19 | Pressure Vessel History / Test Record | | |
| 20 | Calibration Data Record | X | |
| 21 | Temporary Installation Record | X | |
| 22 | Open Work / Deferred Work / Open Tests | X | |
| 23 | List of Non-Conformance Reports | X | |
| 24 | Copies of Non-Conformance Reports | X | |
| 25 | Test Reports | X | |
| 26 | Proof Load Certificates | | |
| 27 | Reference List of EIDP's | | |

| | | | |
|----|-----------------------------|---|--|
| | (Lower Level / Associated) | | |
| 28 | Mass Records / Power Budget | X | |
| 29 | Cleanliness Statement | X | |
| 30 | Other Useful Information | X | |

Table of Figures

| | |
|--|----|
| Figure 1 CFIL-1 component drawing | 13 |
| Figure 2 PFIL-2 component drawing | 14 |
| Figure 3 PFIL-3 component drawing | 15 |
| Figure 4 SFIL-2 component drawing | 16 |
| Figure 5 SFIL-3S component drawing | 17 |
| Figure 6 SFIL-3L component drawing | 18 |
| Figure 7 CFIL-1 interface | 20 |
| Figure 8 PFIL-2 interface | 21 |
| Figure 9 PFIL-3 interface | 22 |
| Figure 10 SFIL-2 interface – sheet 1 | 23 |
| Figure 11 SFIL-2 interface – sheet 2 | 24 |
| Figure 12 SFIL-2 interface – sheet 3 | 25 |
| Figure 13 SFIL-3 interface | 26 |
| Figure 14 CFIL-1 PFM calibration curve – 0-600cm ⁻¹ | 37 |
| Figure 15 CFIL-1 PFM calibration curve - 0-120cm ⁻¹ | 38 |
| Figure 16 PFIL-2 PFM 0-600cm ⁻¹ | 39 |
| Figure 17 PFIL-2 PFM 0-120cm ⁻¹ | 40 |
| Figure 18 PFIL-3 PFM 0-600cm ⁻¹ | 41 |
| Figure 19 PFIL-3 PFM 0-120cm ⁻¹ | 42 |
| Figure 20 SFIL-2 PFM 0-600cm ⁻¹ | 43 |
| Figure 21 SFIL-2 PFM 0-120cm ⁻¹ | 44 |
| Figure 22 SFIL-3S PFM 0-600cm ⁻¹ | 45 |
| Figure 23 SFIL-3S PFM 0-120cm ⁻¹ | 46 |
| Figure 24 SFIL-3L PFM 0-600cm ⁻¹ | 47 |
| Figure 25 SFIL-3L PFM 0-120cm ⁻¹ | 48 |
| Figure 26 CFIL-1 Uniformity | 53 |
| Figure 27 PFIL-2 Uniformity | 54 |
| Figure 28 PFIL-3 Uniformity | 55 |
| Figure 29 SFIL-2 Uniformity | 56 |
| Figure 30 SFIL-3S Uniformity | 57 |
| Figure 31 SFIL-3L Uniformity | 58 |

SCOPE & Component ID

This document is the End Item Data Package (EIDP) covering the following components for the SPIRE instrument flight model:-

- CFIL1 FILT-PFM-101 B723 100cm-1 LPE
- PFIL2 FILT-PFM-102 B745 80cm-1 LPE
- PFIL3 FILT-PFM-103 W879 65cm-1 LPE – A/R coated
- SFIL2 FILT-PFM-113 B705 80cm-1 LPE
- SFIL3S FILT-PFM-116 B655 65cm-1 LPE
- SFIL3L FILT-PFM-120 B731 60cm-1 LPE

SECTION 01 - Shipping Documents

The PFM instrument filter set was hand-carried to RAL by Bruce Sibthorpe of Cardiff University on Monday 25th October 2004.

SECTION 02 - Transportation, Packing, Handling & Integration Procedures

**This package contains flight-qualification hardware.
To be opened only by authorised SPIRE personnel in clean room conditions.**

Hot-pressed filter components:-

- Open sealed bag carefully – do not cut bag below the line marked, to avoid damage to inner bag (see below)
- Handle filters only by edges.
- Install hot-pressed filters according to MSSL drawings & procedures.
- If cleaning should be required, Cardiff personnel MUST be informed. The filters can be cleaned by gentle wiping with a clean-room wipe and Iso-propyl alcohol, followed by a bake at a maximum temperature of 60°C. NEVER USE ACIDS.
- If removal of surface particulate contamination is required, an anti static gun should be used.
- Exposure to UV light should be kept to a minimum. UV lamps for contamination monitoring should only be used when deemed absolutely necessary.



SECTION 03 - Certificate of Conformance

Cardiff University Astronomy Instrumentation Group hereby certifies that the following equipment,

| | |
|--|---|
| Spacecraft / Project: | Herschel |
| Instrument: | SPIRE |
| Model: | PFM |
| Subsystem: | SPIRE PFM Instrument Filters |
| Serial No: | CFIL-1(FILT-PFM-101), PFIL-2(FILT-PFM-102), PFIL-3(FILT-PFM-103), SFIL-2(FILT-PFM-113), SFIL-3S(FILT-PFM-116), SFIL-3L(FILT-PFM-120) |
| As described in this End Item Data Package: HSO-CDF-EIDP-059 | |
| Complies with the requirements set out in: SPIRE-RAL-PRJ-000034 | |

| | Responsible Authority | Signature |
|---------------------------|------------------------------|------------------|
| Cardiff Filter Management | Prof P.A.R.Ade | |
| | Dr C.E.Tucker | |
| Cardiff Product Assurance | Dr I.Walker | |
| Cardiff SPIRE Management | Dr P.Hargrave | |

SECTION 04 - Qualification Status List / Compliance Matrix

The following table lists the qualification tests performed. See historical record for test references.

| Test | Status | | | | | | | Test Institute |
|---|--|--|--|--|--|--|--|---------------------|
| | CFIL1 | PFIL2 | PFIL3 | SFIL2 | SFIL3S | SFIL3L | Notes | |
| Spectral behaviour - Near-band transmission | Performed & compliant | HSO-CDF-SP-002-2.2 See historical record for test references | UWC |
| Spectral behaviour - out-of-band blocking, at $\lambda < 15\mu\text{m}$ | Open test. Off-cuts to be tested once facility commissioned | Open test. Off-cuts to be tested once facility commissioned | Open test. Off-cuts to be tested once facility commissioned | Open test. Off-cuts to be tested once facility commissioned | Open test. Off-cuts to be tested once facility commissioned | Open test. Off-cuts to be tested once facility commissioned | HSO-CDF-SP-002-2.2 See historical record for test references | UWC |
| Dimension and tolerances to specification | Compliant. | Compliant. | Compliant. | Compliant. | Compliant. | Compliant. | HSO-CDF-ICD-012-3.0 | UWC |
| Filter flatness | Not required for this element | HSO-CDF-ICD-012-3.0 | UWC |
| Inspection for surface defects | Passed | Passed | Passed | Passed | Passed | Passed | UWC Filters database "hundred_acre_wood.mdb" | UWC |
| Mass | Compliant | Compliant | Compliant | Compliant | Compliant | Compliant | HSO-CDF-ICD-012-3.0 | |
| Thermal cycling (5 cycles 300K-77K-300K) | Passed | Passed | Passed | Passed | Passed | Passed | See historical record for test references | UWC |
| Cold vibration | Not performed | MSSL-Technote-SPIRE-26 SPIRE-RAL-REP-002007 | RAL |
| Environmental condition - Vacuum $3 \times 10^{-1} \text{ mBar}$ | Performed | Performed | Performed | Performed | Performed | Performed | See historical record for test references | UWC |
| Differential pressure (a pumping-out rate of 10mB/sec) | Performed | Performed | Performed | Performed | Performed | Performed | See historical record for test references | UWC |
| Pre-bake out (not exceeding 80°C) | Complete | Complete | Complete | Complete | Complete | Complete | UWC PCH SPIRE Filters log-book | UWC |
| Outgassing | Test not performed. All materials used within ESA / NASA specifications | Test not performed. All materials used within ESA / NASA specifications | Test not performed. All materials used within ESA / NASA specifications | Test not performed. All materials used within ESA / NASA specifications | Test not performed. All materials used within ESA / NASA specifications | Test not performed. All materials used within ESA / NASA specifications | Test not performed. All materials used within ESA / NASA specifications | Compliant by design |
| Cleanliness checks, by visual inspection. | Passed | Passed | Passed | Passed | Passed | Passed | UWC Filters database "hundred_acre_wood.mdb" | UWC |
| Degradation due to high energy radiation. | Not tested | Compliant by design | |

Compliance matrix

Reference document SPIRE Filters Subsystem Specification Document, HSO-CDF-SP-002 V.2.2.

These components are higher frequency blocking filters, and the exact position of the edges is not important (see HSO-CDF-RFW-063).

| Name | Filter type | Edges | | | Function | | Comments | PFM filter performance | | | Difference from specification | Compliant with requirements? |
|--------|---------------|-------|-------|-------|--|------------------------------------|---|------------------------|------|-------|-------------------------------|--|
| | | | | | T = Transmit B = Block; R = Reflect | | | Trans | cm-1 | μm | | |
| | | Trans | cm-1 | μm | | | | Trans | cm-1 | μm | cm-1 | |
| CFIL1 | Low-pass edge | 90% | 60.0 | 166.7 | T B | 15 - 50 cm-1 666.7 - 200 μm | Thermal blocker. Common to Photometer and FTS. | 90% | 71.0 | 140.8 | 11.0 | Yes. This component is a thermal blocker, not an edge definer. |
| | | 50% | 100.0 | 100.0 | | 110.0 - UV cm-1 | | 50% | 95.0 | 105.3 | -5.0 | |
| | | 10% | 105.0 | 95.2 | | 90.91 - UV μm | | 10% | 98.0 | 102.0 | -7.0 | |
| PFIL2 | Low-pass edge | 90% | 60.0 | 166.7 | T B | 15 - 50 cm-1 666.7 - 200 μm | Thermal blocker. | 90% | 71.5 | 139.9 | 11.5 | Yes. This component is a thermal blocker, not an edge definer. |
| | | 50% | 90.0 | 111.1 | | 99.5 - UV cm-1 | | 50% | 84.5 | 118.3 | -5.5 | |
| | | 10% | 94.5 | 105.8 | | 100.5 - UV μm | | 10% | 86.8 | 115.2 | -7.7 | |
| PFIL3 | Low-pass edge | 90% | 57.0 | 175.4 | T B | 15 - 50 cm-1 666.7 - 200 μm | Thermal blocker. | 90% | 50.2 | 199.2 | -6.8 | Yes. This component is a thermal blocker, not an edge definer. |
| | | 50% | 60.0 | 166.7 | | 68.0 - UV cm-1 | | 50% | 55.3 | 180.8 | -4.7 | |
| | | 10% | 63.0 | 158.7 | | 147.1 - UV μm | | 10% | 56.9 | 175.7 | -6.1 | |
| SFIL2 | Low-pass edge | 90% | 60.0 | 166.7 | T B | 15 - 50 cm-1 666.7 - 200 μm | Thermal blocker. Identical to PFIL2. | 90% | 66.9 | 149.5 | 6.9 | Yes. This component is a thermal blocker, not an edge definer. |
| | | 50% | 90.0 | 111.1 | | 100 - UV cm-1 | | 50% | 89.0 | 112.4 | -1.0 | |
| | | 10% | 94.5 | 105.8 | | 100 - UV μm | | 10% | 91.0 | 109.9 | -3.5 | |
| SFIL3S | Low-pass edge | 90% | 66.5 | 150.4 | T B | 31.2 - 51.3 cm-1 320.5 - 195 μm | Blocker | 90% | 59.1 | 169.2 | -7.4 | Yes. This component is a thermal blocker, not an edge definer. |
| | | 50% | 70.0 | 142.9 | | 78.5 - UV cm-1 | | 50% | 63.9 | 156.5 | -6.1 | |
| | | 10% | 73.5 | 136.1 | | 127.4 - UV μm | | 10% | 65.8 | 152.0 | -7.7 | |
| SFIL3L | Low-pass edge | 90% | 57.0 | 175.4 | T B | 14.9 - 66.5 cm-1 671.1 - 150 μm | Blocker | 90% | 47.8 | 209.2 | -9.2 | Yes. This component is a thermal blocker, not an edge definer. |
| | | 50% | 60.0 | 166.7 | | 68.0 - UV cm-1 | | 50% | 66.4 | 150.6 | 6.4 | |
| | | 10% | 63.0 | 158.7 | | 147.1 - UV μm | | 10% | 68.2 | 146.6 | 5.2 | |

SECTION 05 - Top Level Drawings (Inc. Family Tree)

TOP LEVEL DRAWING LIST

| Drawing No. | Title |
|--------------|----------------|
| FILT-XXX-101 | CFIL-1 FILTER |
| FILT-XXX-102 | PFIL-2 FILTER |
| FILT-XXX-103 | PFIL-3 FILTER |
| FILT-XXX-113 | SFIL-2 FILTER |
| FILT-XXX-116 | SFIL-3S FILTER |
| FILT-XXX-120 | SFIL-3L FILTER |
| | |
| | |
| | |
| | |
| | |




Figure 1 CFIL-1 component drawing




Figure 2 PFIL-2 component drawing




Figure 3 PFIL-3 component drawing




Figure 4 SFIL-2 component drawing




Figure 5 SFIL-3S component drawing




Figure 6 SFIL-3L component drawing

SECTION 06 - Interface Drawings

INTERFACE DRAWING LIST

| Drawing No. | Title |
|--------------|------------------|
| FILT-XXX-101 | CFIL-1 FILTER |
| FILT-XXX-102 | PFIL-2 FILTER |
| FILT-XXX-103 | PFIL-3 FILTER |
| FILT-XXX-113 | SFIL-2 FILTER |
| FILT-XXX-116 | SFIL-3S FILTER |
| FILT-XXX-120 | SFIL-3L FILTER |
| 5264-921 | CFIL-1 INTERFACE |
| 5264-922 | PFIL-2 INTERFACE |
| 5264-918 | PFIL-3 INTERFACE |
| 5264-920 | SFIL-2 INTERFACE |
| 5264-919 | SFIL-3 INTERFACE |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |




Figure 7 CFIL-1 interface




Figure 8 PFIL-2 interface




Figure 9 PFIL-3 interface




Figure 10 SFIL-2 interface – sheet 1




Figure 11 SFIL-2 interface – sheet 2




Figure 12 SFIL-2 interface – sheet 3




Figure 13 SFIL-3 interface

SECTION 07 - Functional, Block & Mechanical Drawings

Not applicable.

FUNCTIONAL & BLOCK DRAWING LIST

| Drawing No. | Title |
|-------------|-------|
| | |
| | |
| | |
| | |
| | |
| | |
| | |

MECHANICAL COMPONENT DRAWING LIST

| Drawing No. | Title |
|-------------|-------|
| | |
| | |
| | |
| | |
| | |
| | |
| | |

SECTION 09 - As Built Configuration Items Status List

| Item | Reference | Location | Notes |
|---|-----------|---|-------|
| Filter drawings and manufacturing files | | \Darkstar\Astroworld\Projects\Spire\Cardiff_workpackages\Deliverables\Shipped\Filters\PFM-instrument-filters\Drawings\ | |
| Material certificates of conformance | | Available at Cardiff for inspection | |
| Filter manufacture | | All grids built according to "UWC Filter Fabrication Procedures.doc" [UWC internal document) located at \\Darkstar\Astroworld\Projects\filters\Filter Production procedures. Traceability of components through logbooks and "Filter database - Hundred Acre Wood" [UWC internal Access database located at \\Darkstar\Astroworld\Projects\filters\database. | |
| FILT-PFM-101 Spectroscopic test data CFIL-1 PFM assembly | B723 | \Darkstar\Astroworld\Projects\Spire\Cardiff_workpackages\Configured_Documents\Issued\Data\SPIRE_PFM_CFIL1.xls | |
| FILT-PFM-102 Spectroscopic test data PFIL-2 PFM assembly | B745 | \Darkstar\Astroworld\Projects\Spire\Cardiff_workpackages\Configured_Documents\Issued\Data\SPIRE_PFM_PFIL2.xls | |
| FILT-PFM-103 Spectroscopic test data PFIL-3 PFM assembly | W879 ARC | \Darkstar\Astroworld\Projects\Spire\Cardiff_workpackages\Configured_Documents\Issued\Data\SPIRE_PFM_PFIL3.xls | |
| FILT-PFM-113 Spectroscopic test data SFIL-2 PFM assembly | B705 | \Darkstar\Astroworld\Projects\Spire\Cardiff_workpackages\Configured_Documents\Issued\Data\SPIRE_PFM_SFIL2.xls | |
| FILT-PFM-120 Spectroscopic test data SFIL-3L PFM assembly | B731 | \Darkstar\Astroworld\Projects\Spire\Cardiff_workpackages\Configured_Documents\Issued\Data\SPIRE_PFM_SFIL3L.xls | |

| | | | |
|---|------|--|--|
| FILT-PFM-116 Spectroscopic test data SFIL-3S PFM assembly | B655 | \Darkstar\Astroworld\Projects\Spire\Cardiff_workpackages \Configured_Documents\Issued\Data\SPIRE_PFM_SFIL3S.xls | |
| | | | |
| | | | |

| Part number | Description | Details |
|--------------|--------------------------|---|
| FILT-PFM-101 | CFIL-1 FILTER – B723 | Common input filter. 100cm ⁻¹ blocker |
| FILT-PFM-102 | PFIL-2 FILTER – B745 | 80cm ⁻¹ blocker |
| FILT-PFM-103 | PFIL-3 FILTER – W879 ARC | 70cm ⁻¹ blocker. Anti-reflection coated. |
| FILT-PFM-113 | SFIL-2 FILTER – B705 | 80cm ⁻¹ blocker |
| FILT-PFM-116 | SFIL-3S FILTER – B655 | 65cm ⁻¹ blocker |
| FILT-PFM-120 | SFIL-3L FILTER – B731 | 60cm ⁻¹ blocker |
| | | |
| | | |
| | | |
| | | |
| | | |

SECTION 11 - List of Waivers

| | | |
|-----------------|--------------------------------|--------|
| HSO-CDF-RFW-063 | SPIRE PFM Blocking Filters RFW | Closed |
|-----------------|--------------------------------|--------|

SECTION 12 - Copies of Waivers

| | | | |
|---|---|---|----------|
|  Rutherford Appleton Laboratory REQUEST FOR WAIVER / DEVIATION (RFW/RFD) | | PRODUCT ASSURANCE Space Science and Technology Department | |
| RFW/RFD Number: | HR-SP-CDF-RFW-XXX , HSO-CDF-RFW-063 | | |
| Spacecraft / Project | HERSCHEL | | |
| System / Experiment / Model | SPIRE-PFM | | |
| Sub-System | Filters | | |
| Assembly | Organisation | | |
| Sub-Assembly | Ref. Doc. / Drwg No. | | |
| Item | All flight model blocking filters | | |
| Serial No. | References | | |
| RFW/RFD Title | Request for waiver against blocking filter edges | | |
| End Items(s) Affected (Hardware, Software) | | | |
| Name | CI-Number | Model(s) | |
| SPIRE PFM blocking filters | | Flight | |
| Requirement / Interface Documents Affected | | | |
| Specification/Drawing Title | Number | Issue | Date |
| Filters specification document | HSO-CDF-SP-002 | 2.2 | 29/10/02 |
| 3.2 table 1 3.3 table 2 | | | |
| Description of Deviation / Discrepancy / Non-Conformance | | | |
| This note requests a waiver on the nominal edge positions for the flight model instrument blocking filters. | | | |
| Other Items or Requirements (Potentially) Affected | | | |
| None | | | |
| Need for RFW/RFD and Rationale for Acceptance | | | |
| <p>The flight blocking filters have been tuned in such a way as to optimise the in-band transmission and out-of-band rejection for each SPIRE band. This means that the actual edge positions are not exactly as stated in HSO-CDF-SP-002 (filters spec. document). This is not important, as the band edges are defined by edge defining filters, which are all exactly to specification, and are not included in this request for waiver.</p> <p>The differences in edge position are summarised in Table 1.</p> <p>Informal MRB held by Eric Sawyer & Bruce Swinyard. 11th August 2004. This RFW is accepted / agreed by SPIRE PROJECT, No Agreement required from Industry or Customer.</p> | | | |
| Approved | Rejected | Name | Date |
| Engineering: |  | Bruce Swinyard | |
| Product Assurance: |  | Eric Clark | |
| CCB-Chairman: | | | |
| Principle Investigator: | | | |
| Product Assurance: | | | |
| Co-Investigator: | | | |
| Prime Contractor: | | | |
| ESA Project Office | | | |

| | | |
|--|---|--|
|  Rutherford Appleton Laboratory REQUEST FOR WAIVER / DEVIATION (RFW/RFD) | PRODUCT ASSURANCE Space Science and Technology Department | |
| RFW/RFD Number: | HR-SP-CDF-RFW-XXX , HSO-CDF-RFW-063 | |

Table 1 Comparison of nominal edges as stated in HSO-CDF-SP-002 with actual PFM blocker edge positions.

| Name | Filter type | Edges | | | Function | | Comments | PFM filter performance | | | Difference from specification | | |
|--------|---------------|-------|-------|-------|--------------|------------------|--|------------------------|------|-------|-------------------------------|--|--|
| | | | | | T = Transmit | | | | | | | | |
| | | Trans | cm-1 | μm | B | = Block; | | Trans | cm-1 | μm | | | |
| CFIL1 | Low-pass edge | 90% | 60.0 | 166.7 | T | 15 - 50 cm-1 | Thermal blocker. Common to Photometer and FTS. | 90% | 71.0 | 140.8 | 11.0 | | |
| | | 50% | 100.0 | 100.0 | | 666.7 - 200 μm | | 50% | 95.0 | 105.3 | -5.0 | | |
| | | 10% | 105.0 | 95.2 | B | 110.0 - UV cm-1 | | 10% | 98.0 | 102.0 | -7.0 | | |
| PFIL2 | Low-pass edge | 90% | 60.0 | 166.7 | T | 15 - 50 cm-1 | Thermal blocker. | 90% | 71.5 | 139.9 | 11.5 | | |
| | | 50% | 90.0 | 111.1 | | 666.7 - 200 μm | | 50% | 84.5 | 118.3 | -5.5 | | |
| | | 10% | 94.5 | 105.8 | B | 99.5 - UV cm-1 | | 10% | 86.8 | 115.2 | -7.7 | | |
| PFIL3 | Low-pass edge | 90% | 57.0 | 175.4 | T | 15 - 50 cm-1 | Thermal blocker. | 90% | 50.2 | 199.2 | -6.8 | | |
| | | 50% | 60.0 | 166.7 | | 666.7 - 200 μm | | 50% | 55.3 | 180.8 | -4.7 | | |
| | | 10% | 63.0 | 158.7 | B | 68.0 - UV cm-1 | | 10% | 56.9 | 175.7 | -6.1 | | |
| SFIL2 | Low-pass edge | 90% | 60.0 | 166.7 | T | 15 - 50 cm-1 | Thermal blocker. Identical to PFIL2. | 90% | 66.9 | 149.5 | 6.9 | | |
| | | 50% | 90.0 | 111.1 | | 666.7 - 200 μm | | 50% | 89.0 | 112.4 | -1.0 | | |
| | | 10% | 94.5 | 105.8 | B | 100 - UV cm-1 | | 10% | 91.0 | 109.9 | -3.5 | | |
| SFIL3S | Low-pass edge | 90% | 66.5 | 150.4 | T | 31.2 - 51.3 cm-1 | Blocker | 90% | 59.1 | 169.2 | -7.4 | | |
| | | 50% | 70.0 | 142.9 | | 320.5 - 195 μm | | 50% | 63.9 | 156.5 | -6.1 | | |
| | | 10% | 73.5 | 136.1 | B | 78.5 - UV cm-1 | | 10% | 65.8 | 152.0 | -7.7 | | |
| SFIL3L | Low-pass edge | 90% | 57.0 | 175.4 | T | 14.9 - 66.5 cm-1 | Blocker | 90% | 47.8 | 209.2 | -9.2 | | |
| | | 50% | 60.0 | 166.7 | | 671.1 - 150 μm | | 50% | 68.4 | 150.6 | 6.4 | | |
| | | 10% | 63.0 | 158.7 | B | 68.0 - UV cm-1 | | 10% | 68.2 | 146.6 | 5.2 | | |

SECTION 13 - Operations Manual

No operating manual is supplied.

SECTION 14 - Historical Record

The following table contains *brief* historical details of the manufacture, assembly and testing of the PFM filter set, including the levels of environmental cleanliness.

Refer also to section 25 – Test reports.

A *full* historical record of every stage of manufacture for each individual grid integral to the final mounted filter is traceable at UWC, in both hard copy log-book format and on a Microsoft Access database.

Filter CFIL1

| Date | Action | UWC Test reference |
|---------|--|--|
| 1/10/03 | Filter B723 manufactured in class 1000 clean room | |
| 2/10/03 | Filter B723 spectroscopically tested in the range 10-140cm-1 | T0192r4 |
| 2/10/03 | Filter B723 spectroscopically tested in the range 20-650cm-1 | T0192r13 |
| 8/10/03 | Filter B723 spectroscopically tested in the range 3-40cm-1 | T0195r35 |
| 16/1/04 | Filter B723 thermally shocked 5 times between 300K and 77K | THERM 0139 |
| 16/1/04 | Filter B723 cut to CFIL1 drawing | |
| 26/1/04 | PFM-CFIL1 spectroscopically tested in the range 10-145cm-1 at five locations over area | T0258r58, T0258r60, T0258r62, T0258r64, T0258r66 |
| 29/1/04 | PFM-CFIL1 spectroscopically tested in the range 20-650cm-1 | T0261r41, |
| 6/2/04 | PFM-CFIL1 filter thermally cycled 300K-77K-300K | THERM 0145 |
| 10/2/04 | PFM-CFIL1 spectroscopically tested in the range 20-650cm-1 | T0268r31 |
| | PFM-CFIL1 baked for 17hrs at 350K | |

Filter PFIL2

| Date | Action | UWC Test reference |
|---------|--|---------------------|
| 4/11/03 | Filter B745 manufactured in class 1000 clean room | |
| 5/11/03 | Filter B745 spectroscopically tested in the range 10-140cm-1 | T0216r13 |
| 6/11/03 | Filter B745 spectroscopically tested in the range 20-650cm-1 | T02172r13 |
| 16/1/04 | Filter B745 thermally shocked 5 times between 300K and 77K | THERM 0140 |
| 16/1/04 | Filter B745 cut to PFIL2 drawing | |
| 26/1/04 | PFM-PFIL2 spectroscopically tested in the range 10-145cm-1 at five locations over area | T0258r46, T0258r48, |

| | | |
|---------|--|---------------------------------|
| | | T0258r50, T0258r52, T0258r54 |
| 29/1/04 | PFM-PFIL2 spectroscopically tested in the range 20-650cm-1 | T0261r44, |
| 6/2/04 | PFM-PFIL2 filter thermally cycled 300K-77K-300K | THERM 0146 |
| 10/2/04 | PFM-PFIL2 spectroscopically tested in the range 20-650cm-1 | T0268r28 |
| | PFM-PFIL2 cleaned & baked for 17hrs at 350K | |

Filter PFIL3

| Date | Action | UWC Test reference |
|----------|--|---------------------------------|
| 12/08/04 | Filter W879 manufactured in class 1000 clean room | W879 |
| 13/08/04 | Filter W879 spectroscopically tested in transmission in the range 5-40cm-1 | T0407r13 |
| 14/08/04 | Filter W879 spectroscopically tested in transmission in the range 10-140cm-1 | T0408r4 |
| 20/08/04 | Filter W879 cut to PFIL3 drawing | |
| 20/09/04 | SPIRE PFM PFIL3 spectroscopically tested in transmission in the range 20-600cm-1 | T0423r13 |
| 20/09/04 | SPIRE PFM PFIL3 thermally cycled 3 times between 300K and 77K | THERM 0200 |
| 20/09/04 | SPIRE PFM PFIL3 spectroscopically tested for uniformity in the range 10-140cm-1 | T0423r22, T0423r25, T0423r28 |
| | SPIRE PFM PFIL3 cleaned with acetone, baked for 17hours at 350K | |
| | | |
| | | |

Filter SFIL2

| Date | Action | UWC Test reference |
|---------|---|---------------------------|
| 10/9/03 | Filter B705 manufactured in class 1000 clean room | |
| 16/9/03 | Filter B705 spectroscopically tested in the range 3-40cm-1 | T0178r13 |
| 17/9/03 | Filter B705 spectroscopically tested in the range 20-650cm-1 | T0179r10 |
| 16/1/04 | Filter B705 thermally shocked 5 times between 300K and 77K | THERM 0144 |
| 16/1/04 | Filter B705 cut to SFIL2 drawing | |
| 26/1/04 | PFM-SFIL2 spectroscopically tested in the range 10-145cm-1 at three locations over area | T0258r4, T0258r6, T0258r8 |
| 29/1/04 | PFM-SFIL2 spectroscopically tested in the range 20-650cm-1 | T0261r29, |
| 6/2/04 | PFM-SFIL2 filter thermally cycled 300K-77K-300K | THERM 0147 |
| 10/2/04 | PFM-SFIL2 spectroscopically tested in the range 20-650cm-1 | T0268r16 |
| | PFM-SFIL2 cleaned & baked for 17hrs at 350K | |

Filter SFIL3S

| Date | Action | UWC Test reference |
|---------|--|---------------------------------|
| 11/7/03 | Filter B655 manufactured in class 1000 clean room | |
| 15/7/03 | Filter B655 spectroscopically tested in the range 3-40cm-1 | T0XXXX |
| 15/7/03 | Filter B655 spectroscopically tested in the range 20-650cm-1 | T0XXXX |
| 16/1/04 | Filter B655 thermally shocked 5 times between 300K and 77K | THERM 0141 |
| 16/1/04 | Filter B655 cut to SFIL3S drawing | |
| 26/1/04 | PFM-SFIL3S spectroscopically tested in the range 10-145cm-1 at three locations over area | T0258r22, T0258r24, T0258r26 |
| 29/1/04 | PFM-SFIL3S spectroscopically tested in the range 20-650cm-1 | T0261r32, |
| 6/2/04 | PFM-SFIL3S filter thermally cycled 300K-77K-300K | THERM 0149 |
| 10/2/04 | PFM-SFIL3S spectroscopically tested in the range 20-650cm-1 | T0268r19 |
| | PFM-SFIL3S cleaned & baked for 17hrs at 350K | |

Filter SFIL3L

| Date | Action | UWC Test reference |
|---------|--|---------------------------------|
| 11/7/03 | Filter B731 manufactured in class 1000 clean room | |
| 15/7/03 | Filter B731 spectroscopically tested in the range 3-40cm-1 | T0126r19 |
| 15/7/03 | Filter B731 spectroscopically tested in the range 20-650cm-1 | T0127r4 |
| 16/1/04 | Filter B731 thermally shocked 5 times between 300K and 77K | THERM 0142 |
| 16/1/04 | Filter B731 cut to SFIL3L drawing | |
| 26/1/04 | PFM-SFIL3L spectroscopically tested in the range 10-145cm-1 at three locations over area | T0258r16, T0258r18, T0258r20 |
| 29/1/04 | PFM-SFIL3L spectroscopically tested in the range 20-650cm-1 | T0261r35, |
| 6/2/04 | PFM-SFIL3L filter thermally cycled 300K-77K-300K | THERM 0148 |
| 10/2/04 | PFM-SFIL3L spectroscopically tested in the range 20-650cm-1 | T0268r22 |
| | PFM-SFIL3L baked for 17hrs at 350K | |

SECTION 15 – Logbook / Diary of Events

Not provided – available from subsystem provider upon request.

SECTION 16 – Operating Time / Cycle Record

N/A – See historical record

SECTION 20 - Calibration Data Record

The data shown in this section are the recommended transmission curves to be used for calibration purposes.
These data can be found in the Microsoft Excel worksheets listed in section 09, under the sheet entitled “Calibration”.

CFIL-1

CFIL-1 PFM Calibration data




Figure 14 CFIL-1 PFM calibration curve – 0-600cm⁻¹




Figure 15 CFIL-1 PFM calibration curve - 0-120cm⁻¹

PFIL-2

PFIL-2 PFM Calibration data




Figure 16 PFIL-2 PFM 0-600cm⁻¹




Figure 17 PFIL-2 PFM 0-120cm⁻¹

PFIL-3




Figure 18 PFIL-3 PFM 0-600 cm^{-1}




Figure 19 PFIL-3 PFM 0-120 cm^{-1}

SFIL-2




Figure 20 SFIL-2 PFM 0-600cm⁻¹




Figure 21 SFIL-2 PFM 0-120cm⁻¹

SFIL-3S




Figure 22 SFIL-3S PFM 0-600 cm^{-1}




Figure 23 SFIL-3S PFM 0-120 cm^{-1}

SFIL-3L




Figure 24 SFIL-3L PFM 0-600cm⁻¹




Figure 25 SFIL-3L PFM 0-120cm⁻¹

SECTION 21 - Temporary Installation Record

SECTION 22 - Open Work / Deferred Work / Open Tests

- MIR to UV Spectroscopic test to be performed on the UWC Bomem spectrometer, on an off-cut of the supplied filters. This work has been delayed pending the arrival of a new MIR beam divider for the Cardiff Bomem spectrometer. At this higher frequency range UWC believe that all filter components behave in much the same manner. Therefore a similarity test made on an off-cut of filters at a later date will yield acceptable spectral information for all filters.

SECTION 23 - List of Non-Conformance Reports

SECTION 24 - Copies of Non-Conformance Reports

SECTION 25 - Test Reports

Spectroscopic tests

A series of required physical tests and spectral tests have been specified in the verification matrix defined in the “SPIRE Filters – Subsystem Development Plan” document (reference HSO-CDF-PL-005).

The FIR spectral tests were carried out using a Martin-Puplett polarizing Fourier transform interferometer in the laboratory at UWC. This spectrometer is able to operate in transmission and 30° specular reflectance modes at 300K. It is also possible to perform transmission measurements at 77K. The results of tests are detailed in this section.

Out-of-band transmission measurements *will be* performed, on selected components, from 20 μ m to 0.5 μ m, using the UWC Bomem FT spectrometer. This work has been delayed awaiting the installation and commissioning from Bomem of a new beam-splitter.

Thermal shocking of hot-pressed filters (300K - 77K - 300K) is performed using a liquid nitrogen bath. This cycle is performed 3 times. A spectroscopic transmission measurement is made thereafter to verify no filter delamination or degradation.

Thermal cycling (300K - 1.5K - 300K) of component off-cuts is performed within the UWC type MD800 liquid helium bath cryostat such that spectroscopic measurements can simultaneously be made. This cycle is performed once at a vacuum pressure of 10⁻² mBar.

During the evacuating of the Martin-Puplett FTS, the filter component is subjected to a differential pressure rate of change of at least 10mB/sec.

Spectroscopic tests were carried out according to standard UWC FTS procedures.

The uniformity of each component was checked by spectral measurements over three or more points distributed about the area. In each case, the diameter of the FTS geometric beam was approximately 7mm.

Refer to section 14 (Historical record) for the test indices.

Tests results for each filter are shown in this section

Filter CFIL1

All test data for CFIL1-PFM are stored in the following Microsoft Excel spreadsheet (configured file):-

\Darkstar\Astroworld\Projects\Spire\Cardiff_workpackages\Configured_Documents\Issued\Data\SPIRE_PFM_CFIL1.xls




Figure 26 CFIL-1 Uniformity

Filter PFIL2

All test data for PFIL2-PFM are stored in the following Microsoft Excel spreadsheet (configured file):-

\Darkstar\Astroworld\Projects\Spire\Cardiff_workpackages\Configured_Documents\Issued\Data\SPIRE_PFM_PFIL2.xls




Figure 27 PFIL-2 Uniformity

Filter PFIL3

All test data for PFIL3-PFM are stored in the following Microsoft Excel spreadsheet (configured file):-

\Darkstar\Astroworld\Projects\Spire\Cardiff_workpackages\Configured_Documents\Issued\Data\SPIRE_PFM_PFIL3.xls




Figure 28 PFIL-3 Uniformity

Filter SFIL2

All test data for SFIL2-PFM are stored in the following Microsoft Excel spreadsheet (configured file):-

\Darkstar\Astroworld\Projects\Spire\Cardiff_workpackages\Configured_Documents\Issued\Data\SPIRE_PFM_SFIL2.xls




Figure 29 SFIL-2 Uniformity

Filter SFIL3S

All test data for SFIL3S-PFM are stored in the following Microsoft Excel spreadsheet (configured file):-

\Darkstar\Astroworld\Projects\Spire\Cardiff_workpackages\Configured_Documents\Issued\Data\SPIRE_PFM_SFIL3S.xls




Figure 30 SFIL-3S Uniformity

Filter SFIL3L

All test data for SFIL3L-PFM are stored in the following Microsoft Excel spreadsheet (configured file):-

\Darkstar\Astroworld\Projects\Spire\Cardiff_workpackages\Configured_Documents\Issued\Data\SPIRE_PFM_SFIL3L.xls




Figure 31 SFIL-3L Uniformity

Radiation tests

We make the following statement with respect to the requirement that these items show no appreciable degradation due to high energy radiation:

Filters were flown on the ISO space platform, which were structurally and materially identical to those supplied here. Although the specification regarding radiation resistance for ISO was slightly less stringent than for SPIRE, the filters were acceptable for inclusion in the flight instrument.

We do not have the facilities to test this aspect of the specification and therefore wish to declare acceptance on grounds of similarity with the ISO, and other space missions.

Cold vibration qualification status

Identical components were supplied for SPIRE-CQM testing. All filters have survived cold vibration testing at SPIRE system level.

SECTION 27 – Reference List of EIDP's

Associated

| <u>Title</u> (Listed in alphabetical order) | <u>ID</u> (Serial No.) | <u>Acronym</u> | <u>Document No.</u> | <u>Issue</u> | <u>Date</u> |
|--|---------------------------|----------------|---------------------|--------------|-------------|
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

Lower Level

| <u>Title</u> (Listed in alphabetical order) | <u>ID</u> (Serial No.) | <u>Acronym</u> | <u>Document No.</u> | <u>Issue</u> | <u>Date</u> |
|--|---------------------------|----------------|---------------------|--------------|-------------|
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

SECTION 28 - Mass Records

| Component | Measured Mass (g) | Compliant? |
|----------------------|-------------------|------------|
| CFIL-1 FILT-PFM-101 | 1.728 | YES |
| PFIL-2 FILT-PFM-102 | 2.218 | YES |
| PFIL-3 FILT-PFM-103 | 0.727 | YES |
| SFIL-2 FILT-PFM-113 | 0.347 | YES |
| SFIL-3S FILT-PFM-116 | 0.269 | YES |
| SFIL-3L FILT-PFM-120 | 0.382 | YES |

SECTION 29 - Cleanliness Statement

Statement

The SPIRE PFM instrument filters listed herein have been cleaned and assembled within a class 1000 clean room to meet the requirements of the Cardiff PA plan (HSO-CDF-PL-007).

Signed Peter Hargrave, Technical Manager, Cardiff-SPIRE deliverables

Signed Carole Tucker, Cardiff Filter Production Manager

Signed Ian Walker, Programme Manager, Cardiff AIG.


Date 2nd November 2004

Extra Information

The manufacture of these filter elements took place within a class 1000 clean-room, following the procedures laid out in the UWC document, "UWC Filter Fabrication Procedures.doc". Although filter testing took place within a standard laboratory environment, the mounted filters were subsequently cleaned (using acetone and a de-ionised air-gun), in a class 100 laminar flow cabinet, prior to packaging.

SECTION 30 - Other Useful Information





SECTION 31 - DPL/DML

Refer to the Cardiff-SPIRE PFM deliverables lists.

| | |
|--------------------|----------------|
| Cardiff-SPIRE-DML | HSO-CDF-LI-074 |
| Cardiff-SPIRE-DMPL | HSO-CDF-LI-075 |
| Cardiff-SPIRE-DPL | HSO-CDF-LI-076 |

SECTION 32 – List of Appendices/Attachments

| <u>Appendix #</u> | <u>Title</u> (Listed in alphabetical order) | <u>Document No.</u> | <u>Issue</u> | <u>Date</u> | <u>Notes</u> |
|-------------------|--|---------------------|--------------|-------------|--------------|
| | | | | | |
| | | | | | |
| | | | | | |