



Test Report

HERSCHEL

Title: **SPIRE LPU Electrical Integration Test Report**

CI-No: **125200**

Prepared by:	A. Koppe <i>A. Koppe</i>	Date:	22.10.2007
Checked by:	S. Idler <i>S. Idler</i>		26.10.07
Product Assurance:	R. Stritter <i>R. Stritter</i>		26.10.07
Configuration Control:	W. Wietbrock <i>W. Wietbrock</i>		05.11.07
Project Management:	Dr. W. Fricke <i>W. Fricke</i>		06/11/2007

Distribution: See Distribution List (last page)

Copying of this document, and giving it to others and the use or communication of the contents thereof, are forbidden without express authority. Offenders are liable to the payment of damages. All rights are reserved in the event of the grant of a patent or the registration of a utility model or design.

0 Test Summary

Instrument tested: **SPIRE LPU**

Model: **FM**
S/N:
CI: **112 200**

Applied Test procedure:

HP-2-ASED-TP-0169, issue 1

Summary and Conclusion:

The procedure which covers the SVM power interface on connectors P/J41 and P/J42 to the SPIRE LPU has been successfully executed.

The bonding resistance of the LPU box to the panel ground has been improved from initially 21.9 mOhm to 3.7 mOhm by the integration of an additional bond strap (see HP-2-ASED-NC-3728).

The LPU high level pulse commands were not available on the HERSCHEL CCS and therefore PLANCK commands have been used instead without problems (see HP-2-ASED-NC-3703).

Following NCR's had been raised.

HP-2-ASED-NC-3703	SPIRE LPU High Level Pulse commands not executed
HP-2-ASED-NC-3728	SPIRE LPU Ground resistance too high

Open Issues:

none

Issue	Date	Sheet	Description of Change	Release
1	22.10.07		Initial issue	

Table of Content

0 TEST SUMMARY 2

1 SCOPE..... 5

2 OBJECTIVE..... 6

 2.1 GENERAL OVERVIEW 6

 2.2 TEST SPECIMEN 7

3 DOCUMENTS/DRAWINGS 8

 3.1 APPLICABLE DOCUMENTS 8

 3.2 REFERENCE DOCUMENTS 8

 3.3 OTHER DOCUMENTS 8

4 CONFIGURATION AND REQUIREMENTS 9

 4.1 PLM CONFIGURATION..... 9

 4.2 TEST SETUP..... 9

 4.2.1 *Test Environment*..... 9

 4.2.2 *ESD constraints* 9

 4.2.3 *QA Requirements*..... 9

 4.2.4 *Documentation Requirements*..... 10

5 CONDITIONS..... 11

 5.1 PERSONNEL 11

 5.2 ENVIRONMENTAL 11

 5.3 GSE EQUIPMENT AND TOOLS 12

 5.3.1 *EGSE* 12

 5.3.2 *Special Equipment for IDAS:*..... 13

 5.3.3 *Test Software Status*..... 13

6 VERIFICATION REQUIREMENTS AND STEP BY STEP PROCEDURE 14

 6.1 VERIFICATION REQUIREMENTS/TOLERANCES 14

 6.1.1 *Bonding Verification* 14

 6.1.2 *Voltage/Current Verification* 14

 6.2 PROCEDURE VARIATION SUMMARY..... 15

 6.3 NON CONFORMANCE REPORT (NCR) SUMMARY..... 16

 6.4 PROCEDURE SIGN OFF SHEET 17

7 STEP BY STEP PROCEDURE 18

1 Scope

This procedure details the general rules and necessary steps to be followed during the electrical integration and test of the Herschel SPIRE Launch Lock Unit on the SVM -Z panel. The LPU is directly mounted to the SPIRE FCU.

This procedure is relevant for the connection of the LPU to the SVM power interface on connectors P/J41 and P/J42. The electrical interface of the LPU to the FCU is covered by a respective instrument procedure (RD4) since it affects an instrument internal interface and is, hence, performed by SPIRE personnel with ASED support.

2 Objective

2.1 General Overview

The purpose of this integration steps is to install and test the relevant electrical interfaces of the SPIRE LPU and to mate the harness connectors to the units. A detailed electrical connection diagram of the SPIRE LPU is given in Fig. 2.1-1 below.




Figure 2.1-1: Electrical Connection Diagram of the Herschel SPIRE LPU

2.2 Test Specimen

The test specimen to be integrated by this procedure is the SPIRE LPU on the HERSCHEL satellite.

The details are listed in following "Test Article List".

Test Article List			
Name	HSLPU	CI Number	112 200
Serial No.		Model	FM
Drawing No.	SPI-MEC-82-DO-01-D	Change. St.	Iss. A
Remarks			

3 Documents/Drawings

3.1 Applicable Documents

No.	Document Name	Document Number	Issue/Revision
AD1	PA-Plan	HP-2-ASED-PL-0007	2-1
AD2	SPIRE-ICD	SCI-PT-IIDB/SPIRE- 02124	3-3 4
AD3	SPIRE Launch Lock Unit – SVM Electrical Integration Specification	H-P-2-ASP-TS-1431	1

3.2 Reference Documents

No.	Document Name	Document Number	Issue/Revision
RD1	SPIRE LPU Electrical Design	LAM.PJT.SPI.SPT.0 70724_01	1 rev.1
RD2	ESD – Regeln für HERSCHEL PLM und Integrations- Aktivitäten	HP-2-ASED-PR-0062	1
RD3	LPU Mounting Procedure on the SPIRE E-box	LAM.SSP.SPI.PRC.0 70911_02	1.0

3.3 Other Documents

NA

4 Configuration and Requirements

4.1 PLM Configuration

The SPIRE LPU is mounted to the SPIRE FCU acc. to RD3, the S/C Harness is prepared but not connected.

The S/C must be grounded.

4.2 Test Setup

IDAS-5 Configuration during tests:

IDAS-5 Test Heads are connected via test adapters to the relevant

"Unit under Test" - Connectors. For current measurements (Inrush and Steady-State) a current probe will be used.

The IDAS-Rack must be grounded to the SVM panel ground.

4.2.1 Test Environment

The tests shall be performed in Cl.100 000 Clean Room

4.2.2 ESD constraints

During handling and connection to the SPIRE LPU the ESD precautions acc. to RD2 have to be applied, e.g. personnel must be grounded.

ESD caps shall be installed on the SPIRE FCU as required.

The SVM must be grounded.

4.2.3 QA Requirements

In general the PA Plan shall be followed (see AD1).

Quality Assurance will be a major part of AIT activities in order to ensure that all activities are performed in a controlled manner and documented in accordance with the corresponding requirements.

The main AIT-QA tasks are as follows:

- assurance that activities are performed in accordance with released procedures
- release of hardware for integration/testing

- witnessing of all AIT activities and environmental conditions
- performance of visual inspections
- application of non-conformance reporting system and relevant logbooks
- preparation and performance of KIP's/MIP's/TRP's and PTR's
- to assure that materials/parts/units etc. are traceable
- hazard identification and tracking.

4.2.4 Documentation Requirements

All data, results and possible special events received during this test have to be entered into the integration report

- Sequence Diary

The obtained records shall be marked with

- date of the test
- title of the procedure
- identification number of procedure
- test article identification number

Each activity and operation has to be entered in the log sheets.

- Summary of Deviation

- In the event that the specimen exhibits any major failure or deviations from the requirement this procedure shall not be further executed and a NCR shall be raised.
- Testing shall be continued only upon authorisation of Product Assurance and Project engineering acc. to the NCR decision.

- Post Test Documentation

After performance of the activities the summary sheets must be filled-in.

A copy of the filled-in summary sheets (see para 6.2 and 6.3) has to be incorporated to the summary report for the integration.

After end of integration a test report shall be written.

5 Conditions

5.1 Personnel

Responsibility	Name / Organization
Test Manager	none
Test Engineer	A. Koppe / ASED
EGSE Operator	S. Hamer / Terma
Support Engineer	S. Sonn / ASED
PA Responsible	Th. Schmidt / ASED
Customer Representative	K. Goodey / ESA
SPIRE Representative	none

5.2 Environmental

Environmental	Nominal	Actual	P	N
Clean Room Class	100 000	100	√	
Temperature	(22±3) °C	19.9°C	√	
Rel. Humidity	40...60 %	48.5 %	√	
Pressure	ambient	ambient	√	

Note: Clean room class acc. to Federal Standard 209 E

5.3 GSE Equipment and Tools

5.3.1 EGSE

EGSE List					
Item	Manuf.	Model No.	SN No.	Invent No.	Next Calib.
Power-SCOE	Sat. Services	-	CI3A 2210-SE840/30	NA	NA
CDMU-SCOE	Sat. Services	-	CI3A 2200-SE841/01	NA	NA
TM/TC DFE					
CCS					

Test Equipment List					
Item	Manuf.	Model No.	SN No.	Invent No.	Next Calib.
IDAS-Rack	ASTRIUM	2			
Scope	LeCroy	LC584 AM	10539		21.02.08
Current-Probe	Tektronix	A6302XL	B0103879		10.10.07
Probe-Amplifier	Tektronix	TM5003	B030378		21.02.08
Test-Head 1	ASTRIUM				
Test-Head 2	ASTRIUM				
Multimeter					

5.3.2 Special Equipment for IDAS:

Test Adaptors for following connector-types shall be available:

- Connector : DEMA 9s/9p No. 9D

5.3.3 Test Software Status

The actual IDAS Software Status is:

Software Status	Version	Remark
IDAS5.	V4.6.1	(i.e. IDAS5.V4.6.1.exe)
CCS test S/W		
HPSDB		

6 Verification Requirements and Step by Step Procedure

6.1 Verification Requirements/Tolerances

6.1.1 Bonding Verification

Each bond strap shall have a resistance of $R \leq 2.5 \text{ m}\Omega$.

6.1.2 Voltage/Current Verification

Bus-Voltage:	27.5.....28.14 V
Inrush Current:	< 1.0 A for < 5 ms
Steady State Current:	< 0.17 A
Pin Allocation:	Conn. J41 -Prim. Power: Pin 4; Return: Pin 5 Conn. J42 -Prim. Power: Pin 4; Return: Pin 5 Conn. J41 -HL#5 Cmd: Pin 1; Return: Pin 2 Conn. J41 -HL#6 Cmd: Pin 7; Return: Pin 8 Conn. J42 -HL#21 Cmd: Pin 1; Return: Pin 2 Conn. J42 -HL#22 Cmd: Pin 7; Return: Pin 8

6.2 Procedure Variation Summary


	Test Change	Curr. No.:	
		Date: 18.10.07	
		Page 1	of 1
Test designation	Test Procedure	Issue	Rev.
LPU Input Power Verification	HP-2-ASED-TP-0169	1	
Test step changed	Reason for Change		
Step 7.1.1.4	Change of measurement type for wider range		
Step 7.1.1.5	Change of measurement type for wider range		
Step 7.2.1.5	Change of high level TC		
Step 7.2.1.7	Change of high level TC		
Step 7.2.1.9	Change of high level TC		
Step 7.2.1.11	Change of high level TC		
Step 7.2.2.2	Change of measurement type		
Step 7.2.2.3	Change of measurement type		
Step 7.2.2.4	Change of measurement type		
Step 7.2.2.5	Change of measurement type		
Step 7.3.1.6	Change of high level TC		
Step 7.3.1.16	Change of high level TC		
Step 7.3.1.19	Change of high level TC		
Step 7.3.1.21	Change of high level TC		
Step 7.3.2.2	Change of measurement type		
Step 7.3.2.3	Change of measurement type		
Step 7.3.2.4	Change of measurement type		
Step 7.3.2.5	Change of measurement type		
Step 7.3.2.6	Change of high level TC		
Step 7.3.2.7	Change of high level TC		
Prepared by:	Resp. Test Leader	Project Engineer 	
PA/QA	Prime	Customer	

Table 6.2-1: Procedure Variation Sheet

6.3 Non Conformance Report (NCR) Summary

NCR - No.	NCR - Title	Date	Open Closed	PA sig.
HP-2-ASED-NC-3703	SPIRE LPU High Level Pulse commands not executed	16.10.07	open	
HP-2-ASED-NC-3728	SPIRE LPU Ground Resistance too high	26.10.07	closed	

Table 6.3-1: Non-Conformance Record Sheet

6.4 Procedure Sign Off Sheet

This test has been successfully performed and all open issues are covered by NCR's or Procedure Variations.

	Date	Signature
Test Manager	18.10.07	<i>[Signature]</i>
Operator	18.10.07	<i>[Signature]</i>
PA Responsible	18.10.07	<i>[Signature]</i>
ESA Representative		

7 Step by Step Procedure

Step by Step Procedure created with IDAS.



**EADS
Astrium GmbH**

Herschel

Report

Doc. No.: HP-2-ASED-TR-0218

Unit: SPIRE-LPU

Filename: HP-2-ASED-TR-0218-1.doc

Issue: I

Date: 18.10.2007

Model: FM Par: 7.1 Grounding Measurement

Sheet: 19

St-No	Sub-St	Test – Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
1.1		Preconditions:							
1.2		Ensure that the SPIRE WIH is connected to all units							
1.3		Ensure that the SPIRE SIH is connected							
1.4		Measure according to a four-point measurement the resistance between: - HSLPU and HSFCU housing							
	1	RESISTANCE	000.022	0,00	30,00	mOhm	21,10	MA	P
1.5		Measure according to a four-point measurement the resistance between: - HSLPU and SVM panel GND							
	1	RESISTANCE	000.022	0,00	30,00	mOhm	21,90	MA	N
			After integration		of additional bond strap	mOhm	3,7	MA	P

Test-Location:
ASED-FN

PA_Resp.: Th. Schmidt

Test-Eng.: A. Koppe
OCOE-Operator: S. Hamer

Test_Manager:
A. Koppe

Date:
16.10.2007

St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
1.1		Verification of unloaded Input Power LPU							
1.2		Connect IDAS-5 Testhead-1 via 9-pole adapter No. 9D to the interface connector HSLPU P41							
1.3		Connect IDAS-5 Testhead -2 via 9-pole adapter No. 9D to the interface connector HSLPU P42							
1.4		Switch ON SVM							
1.5		Switch ON LCL #25 for the Nominal LPU Power issue TC: DC25B170 ZCI02999 - temporary							
1.6		Measure the voltage between the following pins aConnector: P/J41 4 5							
	1	VOLTAGE-DC	020.018	27,50	28,14	_Volt	28,14	CM	P
1.7		Switch OFF LCL #25 for the Nominal LPU Power issue TC: DC25B170 ZCI42999 - temporary							
1.8		Measure the voltage between the following pins aConnector: P/J41 4 5							
	1	VOLTAGE-DC	020.017	-0,50	0,50	_Volt	0,00	CM	P
1.9		Switch ON LCL #26 for the Nominal Redundant LPU Power issue TC: DC26D170 ZCA42999 - temporary							
1.10		Measure the voltage between the following pins bConnector: P/J42 4 5							
	1	VOLTAGE-DC	020.018	27,50	28,14	_Volt	28,14	CM	P

 Test-Location:
ASED-FN

PA_Resp.: Th. Schmidt

 Test-Eng.: A. Koppe
OCOE-Operator: S. Hamer

 Test_Manager:
A. Koppe

 Date:
16.10.2007



EADS
Astrium GmbH

Herschel

Report

Unit: SPIRE-LPU

Filename: HP-2-ASED-TR-0218-1.doc

Doc. No.: HP-2-ASED-TR-0218

Issue: 1

Date: 18.10.2007

Model: FM Par: 7.2 Unloaded Input Verification

Sheet: 21

St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
1.11		Switch OFF LCL #26 for the Nominal Redundant LPU Power issue TC: DC25B170 ZCA42999 - temporary							
1.12		Measure the voltage between the following pins bConnector: P/J42 4 5							
	1	VOLTAGE-DC	020.017	-0.50	0.50	_Volt	0,00	CM	P
2.1		Unloaded HL Command Input Verification							

Test-Location:
ASED-FN


PA_Resp.: Th. Schmidt


Test-Eng.: A. Koppe
OCOE-Operator: S. Hamer

Test_Manager:
A. Koppe

Date:
16.10.2007


St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
2.2		Measure and record the oscilloscope trace when activating the HL#5 "DCT01170 (HLC5)" command on P41 between pin 1 and 2 aConnector: P/J41							
	1	PULSDURATION	041.005	24,00	28,00	msec	26,67	PM	P
	2	UPPER-LEVEL	041.005	22,00	29,00	_Volt	25,31	PM	P
	3	LOWER-LEVEL	041.005	-0,10	2,00	_Volt	0,00	PM	P
	4	RISE-TIME	041.005	50,00	500,00	µsec	111,68	PM	P
	5	FALL-TIME	041.005	50,00	500,00	µsec	160,35	PM	P
	6	TRIGGERLEVEL	041.005	10,00	10,00	_Volt	10,00	PM	P
	7	TRIGGERSLOPE	041.005	1,00	1,00	_Pos	1,00	PM	P



St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
		<p>18-Oct-07 8:00:36 MT 041.005 Step 7.2.2.2</p> <p>REMOTE ENABLE</p>  <p>rellevel(A) 111.689 μs</p> <p>50 μs</p> <p>1 50 mV 500 μs 2 50 mV 500 μs 3 50 mV 500 μs 4 50 mV 500 μs</p> <p>500 MS/s</p> <p>1 DC 10.0 V</p> <p>STOPPED</p>							

St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
		<p>18-Oct-07 MT 041.006 Step 7.2.2.2</p> <p>8:00:54</p> <p>3.1-2-----</p> <p>50 ps</p> <p>10.0 V</p> <p>50 ps</p> <p>1 50 mV 500 %</p> <p>2 50 mV 500 %</p> <p>3 50 mV 500 %</p> <p>4 50 mV 500 %</p> <p>1 00 10.0 V</p> <p>STOPPED</p>							

St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
2.3		Measure and record the oscilloscope trace when activating the HL#6 "DCT01170 (HLC6)" command on P41 between pin 7 and 8 aConnector: P/J41 7 8							
	1	PULSDURATION	041.005	24,00	28,00	msec	26,67	PM	P
	2	UPPER-LEVEL	041.005	22,00	29,00	_Volt	25,31	PM	P
	3	LOWER-LEVEL	041.005	-0,10	2,00	_Volt	-0,10	PM	P
	4	RISE-TIME	041.005	50,00	500,00	µsec	109,81	PM	P
	5	FALL-TIME	041.005	50,00	500,00	µsec	161,53	PM	P
	6	TRIGGERLEVEL	041.005	10,00	10,00	_Volt	10,00	PM	P
	7	TRIGGERSLOPE	041.005	1,00	1,00	_Pos	1,00	PM	P



Herschel

Unit: SPIRE-LPU

Filename: HP-2-ASED-TR-0218-1.doc

Issue: 1

Date: 18.10.2007

Model: FM Par: 7.2 Unloaded Input Verification

Sheet: 26

St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
		<p>18-Oct-07 8:04:27 MT 041.005 Step 7.2.2.3 REMOTE ENABLE</p> <p>n@level(1) 109.813 ps</p> <p>50 ps 1 50 mV 500 ps 2 50 mV 500 ps 3 50 mV 500 ps 4 50 mV 500 ps</p> <p>1 DC 10.0 V</p> <p>500 MS/s</p> <p>STOPPED</p>							

Test-Location:
ASED-FN

PA_Resp.: Th. Schmidt

Test-Eng.: A. Koppe
 OCOE-Operator: S. Hamer

Test_Manager:
A. Koppe

Date:
16.10.2007



EADS
Astrium GmbH

Report

Doc. No.: HP-2-ASED-TR-0218

Unit: SPIRE-LPU

Filename: HP-2-ASED-TR-0218-1.doc

Issue: 1

Date: 18.10.2007

Herschel

Model: FM Par: 7.2 Unloaded Input Verification

Sheet: 27

St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
		<p>18-Oct-07 02:04:44 MT 041.005 Step 7.2.2.3</p> <p>REMOTE ENABLE</p> <p>161.525 µs</p> <p>50 µs</p> <p>1 50 mV 500 µs</p> <p>2 50 mV 500 µs</p> <p>3 50 mV 500 µs</p> <p>4 50 mV 500 µs</p> <p>500 MS/s</p> <p>1 DC 10.0 V</p> <p>STOPPED</p>							

Test-Location:
ASED-FN


PA_Resp.: Th. Schmidt


Test-Eng.: A. Koppe
OCOE-Operator: S. Hamer

Test_Manager:
A. Koppe

Date:
16.10.2007


St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
2.4		Measure and record the oscilloscope trace when activating the HL#21 "DCT01170 (HLC21)" command on P42 between pin 1 and 2 bConnector: P/J42							
	1	PULSDURATION	041.005	24,00	28,00	msec	26,66	PM	P
	2	UPPER-LEVEL	041.005	22,00	29,00	_Volt	25,36	PM	P
	3	LOWER-LEVEL	041.005	-0,10	2,00	_Volt	-0,10	PM	P
	4	RISE-TIME	041.005	50,00	500,00	µsec	112,48	PM	P
	5	FALL-TIME	041.005	50,00	500,00	µsec	159,17	PM	P
	6	TRIGGERLEVEL	041.005	10,00	10,00	_Volt	10,00	PM	P
	7	TRIGGERSLOPE	041.005	1,00	1,00	_Pos	1,00	PM	P




St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
		<p>18-Oct-07 08:05:22 MT 041 005 Step 7.2.2.4</p> <p>REMOTE ENABLE</p>  <p>n@level(8) 112.479 µs</p> <p>50 µs</p> <p>1 50 mV 500 % 50 mV 500 % 50 mV 500 % 4 50 mV 500 %</p> <p>500 MS/s</p> <p>1 DC 10.0 V</p> <p>STOPPED</p>							

St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
		<p>18-Oct-07 08:05:36 MT 041.005 Step 7.2.2.4</p> <p>REMOTE ENABLE</p> <p>LeCroy</p> <p>GO TO LOCAL</p> <p>50 ps</p> <p>1 50 mV 500 ps</p> <p>2 50 mV 500 ps</p> <p>3 50 mV 500 ps</p> <p>4 50 mV 500 ps</p> <p>500 ns/s</p> <p>1 DC 10.0 V</p> <p>STOPPED</p> <p>Cursor: 159.168 ps</p>							

St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
2.5		Measure and record the oscilloscope trace when activating the HL#22 "DCT01170 (HLC22)" command on P42 between pin 7 and 8 bConnector: P/J42 7 8							
	1	PULSDURATION	041.005	24,00	28,00	msec	26,66	PM	P
	2	UPPER-LEVEL	041.005	22,00	29,00	_Volt	25,36	PM	P
	3	LOWER-LEVEL	041.005	-0,10	2,00	_Volt	-0,10	PM	P
	4	RISE-TIME	041.005	50,00	500,00	µsec	111,59	PM	P
	5	FALL-TIME	041.005	50,00	500,00	µsec	159,25	PM	P
	6	TRIGGERLEVEL	041.005	10,00	10,00	_Volt	10,00	PM	P
	7	TRIGGERSLOPE	041.005	1,00	1,00	_Pos	1,00	PM	P




St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
		<p>18-Oct-07 MT 041.006 Step 7.2.2.5</p> <p>2:06:04</p> <p>1-2----- 50 ps 10.0 V</p> <p>n8level(A) 111.567 ps</p> <p>50 ps</p> <p>1 50 mV 500 ps</p> <p>2 50 mV 500 ps</p> <p>3 50 mV 500 ps</p> <p>4 50 mV 500 ps</p> <p>500 MS/s</p> <p>1 00 10.0 V</p> <p>STOPPED</p>							


St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
		<p>18-Oct-07 8:05:13 MT 041.005 Step 7.2.2.5 REMOTE ENABLE</p>  <p>50 ps 50 mV 500 ns 50 mV 500 ns 50 mV 500 ns 50 mV 500 ns</p> <p>1 DC 10.0 V 500 ns/s STOPPED</p>							

St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
1.1		Loaded Power Input Verification							
1.2		Connect IDAS-5 Testhead-1 via 9-pole adapter No. 9D between the interface connectors HSLPU P/J41							
1.3		Connect IDAS-5 Testhead-2 via 9-pole adapter No. 9D between the interface connectors HSLPU P/J42							
1.4		Clip current probe to pin 04 of the adapter between P/J41, direction: into box							
1.5		Record inrush and steady state current on TC request							

St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
1.6		Inrush current measurement after request of IDAS Switch ON LCL #25 for the Nominal FCU Power issue TC: DC25D170 ZCI02999 - temporary expected values: 0 A (0 A before HL cmd activation, max. inrush < 1.0 A and < 5msec, steady state < 0.17 A)							
	1	aConnector: P/J41 004 ---							
	1	CURR-dl/dt	034.014	0,00	0,50	_A/us	0,00	PM	P
	2	CURRENT-PEAK	034.014	0,00	1,00	_Amp	0,01	PM	P
	3	CURRENT-DC	034.014	0,00	0,20	_Amp	0,00	PM	P
	4	TRIGGERLEVEL	034.014	0,10	0,10	_Amp	0,10	PM	P
<p>17-Oct-07 MT 034.014 Step 7.3.1.6 Curr. 0.050 A/Div REMOTE ENABLE 11:50:33</p> <p>2 ms 10 mV</p> <p>1 10 mV 500 2 50 mV AC 3 50 mV AC 4 50 mV AC</p> <p>1 DC 20.0mV</p> <p>10 MS/s D AUTO</p> <p>First(C) -2.00000 ms last(C) 18.00000 ms maximum(C) 2.5mV minimum(C) -2.5mV</p>									


St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
1.7	1	<p>Steady State Current Measurement aConnector: P/J41 004 ---</p> <p>CURRENT-DC 17-Oct-07 MT 030.011 Step 7.3.1.7 Curr. 0.010 A/Div REMOTE ENABLE 12:19:48</p>  <p>pkpk(1) 5.0mV mean(1) 46.28mV stdev(1) 0.52mV rms(1) 46.28mV empl(1) 5.0mV</p> <p>10 kS/s STOPPED</p>	030.011	0,00	170,00	mAmp	46,28	PM	P
1.8	1	<p>Measure the voltage between the following pins aConnector: P/J41 4 5 VOLTAGE-DC</p>	020.018	27,50	28,14	_Volt	28,10	CM	P


St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
1.9		Inrush current measurement after request of IDAS Activation of HL#5 cmd Issue TC: DCT01170 (HL5) aConnector: P/J41 004 --- 1 CURR-dt/dt 2 CURRENT-PEAK 3 CURRENT-DC 4 TRIGGERLEVEL 17-Oct-07 50mA/div 12:54:33							
	1	CURR-dt/dt	034.014	0,00	0,50	_A/us	0,00	PM	P
	2	CURRENT-PEAK	034.014	0,00	1,00	_Amp	0,01	PM	P
	3	CURRENT-DC	034.014	0,00	0,20	_Amp	0,00	PM	P
	4	TRIGGERLEVEL	034.014	0,10	0,10	_Amp	0,10	PM	P




St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
1.10	1	Steady State Current Measurement aConnector: P/J41 004 --- CURRENT-DC 17-Oct-07 MT 039.011 Step 7.3.1.7 Curr. 0.010 A/Div REMOTE ENABLE 12:19:48 	030.011	0,00	170,00	mAmp	46,28	PM	P

St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
1.11		Inrush current measurement after request of IDAS Activation of HL#6 cmd Issue TC: DCT01170 (HL6) aConnector: P/J41 004 ---							
	1	CURR-dI/dt	034.014	0,00	0,60	_A/μs	0,00	PM	P
	2	CURRENT-PEAK	034.014	0,00	1,00	_Amp	0,01	PM	P
	3	CURRENT-DC	034.014	0,00	0,20	_Amp	0,00	PM	P
	4	TRIGGERLEVEL	034.014	0,10	0,10	_Amp	0,10	PM	P




St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
1.12	1	Steady State Current Measurement aConnector: P/J41 004 --- CURRENT-DC 17-Oct-07 MT 030.011 Step 7.3.1.12 Curr. 0.050 A/Div REMOTE ENABLE 12:59:28  <p>pkpk [1] 4.4mV mean [1] -0.74mV stdev [1] 0.40mV rms [1] 0.27mV ampl [1] 20</p> <p>1 10 mV 500 2 50 mV AC 3 50 mV AC 4 50 mV AC</p> <p>100 P5/s STOPPED</p>	030.011	0,00	170,00	mAmp	-0,74	PM	N
1.13		Remove current probe							
1.14		Clip current probe to pin 04 of the adapter between P/J42, direction: into box							
1.15		Record inrush and steady state current on TC request							

St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P
1.16		Inrush current measurement after request of IDAS Switch ON LCL #26 for the Nominal FGLPU Power issue TC: DC26D170 ZCA02999 - temporary expected values: 0 A (0 A before HL cmd activation, max. inrush < 1.0 A and < 5msec, steady state < 0.17 A) bConnector: P/J42 004 --- 1 CURR-dI/dt 2 CURRENT-PEAK 3 CURRENT-DC 4 TRIGGERLEVEL 17-Oct-97 50mA/div 12:53:01							
									
			034.014	0,00	0,50	_A/us	0,00	PM	P
			034.014	0,00	1,00	_Amp	0,01	PM	P
			034.014	0,00	0,20	_Amp	0,00	PM	P
			034.014	0,10	0,10	_Amp	0,10	PM	P

St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
1.17	1	<p>Steady State Current Measurement bConnector: P/J42 004</p> <p>--- CURRENT-DC 17-Oct-07 MT 039.011 Step 7.3.1.17 Curr. 0.059 A/0iv REMOTE ENABLE 13:03:36</p> <p>pkpk() 4.4mV mean() -0.70mV sdev() 0.45mV rms() 0.34mV amp() 4.4mV</p> <p>1 10 mV 500 2 50 mV AC 3 50 mV AC 4 50 mV AC</p> <p>1 DC 30.0mV 100 x5/s AUTO</p>	030.011	0,00	170,00	mAmp	-0,70	PM	N
1.18	1	<p>Measure the voltage between the following pins bConnector: P/J42 004 005</p> <p>VOLTAGE-DC</p>	020.018	27,50	28,14	_Volt	28,14	CM	P

St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
1.19		Inrush current measurement after request of IDAS Activation of HL#21 cmd Issue TC: DCT01170 (HL21) aConnector: P/J42 004 ---							
	1	CURR-dI/dt	034.014	0,00	0,50	_A/μs	0,00	PM	P
	2	CURRENT-PEAK	034.014	0,00	1,00	_Amp	0,01	PM	P
	3	CURRENT-DC	034.014	0,00	0,20	_Amp	0,00	PM	P
	4	TRIGGERLEVEL	034.014	0,10	0,10	_Amp	0,10	PM	P



St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
1.20	1	<p>Steady State Current Measurement bConnector: P/J42 004</p> <p>CURRENT-DC 17-Oct-07 MT 839.011 Step 7.3 1.20 Curr.: 0.050 A/Div REMOTE ENABLE 13:12:11</p> <p>pkp1(1) 4.4 mV mean(1) 33.87 mV sdev(1) 0.46 mV res(1) 33.87 mV ampl(1) 4.4 mV</p> <p>100 kV/s</p>	030.011 *) needs to be multiplied by a factor of 3 due to probe amplifier setting	0.00	170.00	mAmp	33.87 *)	PM	P

Test-Location:
ASED-FN

PA_Resp.: Th. Schmidt

Test-Eng.: A. Koppe
OCOE-Operator: S. Hamer

Test_Manager:
A. Koppe

Date:
17.10.2007



**EADS
Astrium GmbH**

Herschel

Report

Doc. No.: HP-2-ASED-TR-0218


Unit: SPIRE-LPU Filename: HP-2-ASED-TR-0218-1.doc

Issue: 1 Date: 18.10.2007

Model: FM Par: 7.3 Loaded Input Verification

Sheet: 45

St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
1.21		Inrush current measurement after request of IDAS Activation of HL#22 cmd Issue TC: DCT01170 (HL22) aConnector: P/J42 004 ---							
	1	CURR-dI/dt	034.014	0,00	0,50	_A/μs	0,00	PM	P
	2	CURRENT-PEAK	034.014	0,00	1,00	_Amp	0,01	PM	P
	3	CURRENT-DC	034.014	0,00	0,20	_Amp	0,00	PM	P
	4	TRIGGERLEVEL	034.014	0,10	0,10	_Amp	0,10	PM	P



Test-Location: ASEd-FN

PA_Resp.: Th. Schmidt


Test-Eng.: A. Koppe
OCOe-Operator: S. Hamer


Test_Manager: A. Koppe

Date: 17.10.2007

St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
1.22	1	<p>Steady State Current Measurement bConnector: P/J42 004 ---</p> <p>CURRENT-DC 17-Oct-07 MT 039.011 Step 7.3.1.22 Curr. 0.658 A/Div REMOTE ENABLE 13:17:27</p> <p>pkpk() 4.4mV mean() -0.67mV sdev() 0.46mV rms() 0.51mV amp() 4.4mV</p> <p>10 mV 500 2 50 mV AC 3 50 mV AC 4 50 mV AC</p> <p>100 kS/s AUTO</p>	030.011	0,00	170,00	mAmp	-0,67	PM	N
1.23		Remove current probe							


St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
2.1		Loaded HL Command Input Verification							
2.2		Measure and record the oscilloscope trace when activating the HL#5 "DCT01170 (HL5)" command on P41 between pin 1 and 2 aConnector: P/J41							
	1	PULSDURATION	041.005	24,00	28,00	msec	26,66	PM	P
	2	UPPER-LEVEL	041.005	22,00	29,00	_Volt	24,69	PM	P
	3	LOWER-LEVEL	041.005	-0,10	2,00	_Volt	-0,10	PM	P
	4	RISE-TIME	041.005	50,00	500,00	µsec	112,70	PM	P
	5	FALL-TIME	041.005	50,00	500,00	µsec	143,69	PM	P
	6	TRIGGERLEVEL	041.005	10,00	10,00	_Volt	10,00	PM	P
	7	TRIGGERSLOPE	041.005	1,00	1,00	_Pos	1,00	PM	P



St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
		<p>18-Oct-07 8:19:12 MT 041.005 Step 7.3.2.2</p> <p>REMOTE ENABLE</p>  <p>release (H): 112.704 µs</p> <p>50 µs</p> <p>1 50 mV 500 ns</p> <p>2 50 mV 500 ns</p> <p>3 50 mV 500 ns</p> <p>4 50 mV 500 ns</p> <p>500 ns/s</p> <p>1 00 16.0 V</p> <p>STOPPED</p>							

St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
		<p>18-Oct-07 MT 041.005 Step 7.3.2.2</p> <p>8:10:27</p> <p>1-2</p> <p>50 μs</p> <p>10.0 V</p> <p>REMOTE ENABLE</p> <p>GO TO LOCAL</p> <p>F@level(R) 143.692 μs</p> <p>50 μs</p> <p>50 mV 500 μs</p> <p>50 mV 500 μs</p> <p>50 mV 500 μs</p> <p>50 mV 500 μs</p> <p>1 DC 10.0 V</p> <p>500 MS/s</p> <p>STOPPED</p>							


St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
2.3		Measure and record the oscilloscope trace when activating the HL#6 "DCT01170 (HL6)" command on P41 between pin 7 and 8 aConnector: P/J41 7 8							
	1	PULSDURATION	041.005	24,00	28,00	msec	26,65	PM	P
	2	UPPER-LEVEL	041.005	22,00	29,00	_Volt	24,69	PM	P
	3	LOWER-LEVEL	041.005	-0,10	2,00	_Volt	0,00	PM	P
	4	RISE-TIME	041.005	50,00	500,00	µsec	112,57	PM	P
	5	FALL-TIME	041.005	50,00	500,00	µsec	146,11	PM	P
	6	TRIGGERLEVEL	041.005	10,00	10,00	_Volt	10,00	PM	P
	7	TRIGGERSLOPE	041.005	1,00	1,00	_Pos	1,00	PM	P



St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
		<p>18-Oct-07 MT 041.005 Step 7.3.2.3</p> <p>8:11:00</p> <p>1-2</p> <p>50 ps</p> <p>10.0 V</p> <p>REMOTE ENABLE</p> <p>GO TO LOCAL</p> <p>r@level (R) 112.573 ps</p> <p>50 ps</p> <p>1 50 mV 500 %</p> <p>2 50 mV 500 %</p> <p>3 50 mV 500 %</p> <p>4 50 mV 500 %</p> <p>500 MS/s</p> <p>1 DC 10.0 V</p> <p>STOPPED</p>							

St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
		<p>18-Oct-07 8:11:09 MT 041.005 Step 7.3 2.3</p> <p>REMOTE ENABLE</p> <p>50 ps</p> <p>10.0 V</p> <p>LaCroy</p> <p>50 ps</p> <p>10.0 V</p> <p>F@level(0) 146.109 ps</p> <p>50 ps</p> <p>1 50 mV 500 %</p> <p>2 50 mV 500 %</p> <p>3 50 mV 500 %</p> <p>4 50 mV 500 %</p> <p>500 MS/s</p> <p>1 00 10.0 V</p> <p>STOPPED</p>							

St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
2.4		Measure and record the oscilloscope trace when activating the HL#21 "DCT01170 (HL21)" command on P42 between pin 1 and 2 bConnector: P/J42							
	1	PULSDURATION	041.005	24,00	28,00	msec	26,65	PM	P
	2	UPPER-LEVEL	041.005	22,00	29,00	_Volt	24,94	PM	P
	3	LOWER-LEVEL	041.005	-0,10	2,00	_Volt	-0,10	PM	P
	4	RISE-TIME	041.005	50,00	500,00	µsec	114,86	PM	P
	5	FALL-TIME	041.005	50,00	500,00	µsec	141,24	PM	P
	6	TRIGGERLEVEL	041.005	10,00	10,00	_Volt	10,00	PM	P
	7	TRIGGERSLOPE	041.005	1,00	1,00	_Pos	1,00	PM	P



St-No	Sub-St	Test - Step - Description	Meas. Type	Min. Nom. Value	Max. Nom. Value	Phys. Unit	Actual Value	C-St	P N
		<p>18-Oct-07 08:11:45 MT 041.865 Step 7.3.2.4</p> <p>1-2----- 50 ps 10.0 V</p> <p>REMOTE ENABLE</p> <p>GO TO LOCAL</p> <p>m@level: (A) 114.866 ps</p> <p>50 ps</p> <p>1 50 mV 500 ps</p> <p>2 50 mV 500 ps</p> <p>3 50 mV 500 ps</p> <p>4 50 mV 500 ps</p> <p>1 DC 10.0 V</p> <p>500 MS/s</p> <p>STOPPED</p>							



EADS
Astrium GmbH

Herschel

Report

Doc. No.: HP-2-ASED-TR-0218

Unit: SPIRE-LPU

Filename: HP-2-ASED-TR-0218-1.doc

Issue: 1

Date: 18.10.2007

Model: FM Par: 7.3 Loaded Input Verification

Sheet: 55

St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
		<p>18-Oct-07 MT 041.005 Step 7.3.2.4 REMOTE ENABLE</p> <p>2:11:57</p> <p>1-2</p> <p>50 μs</p> <p>10.0 V</p> <p>F@level(8) 141.245 μs</p> <p>50 μs</p> <p>1 50 mV 500 μs</p> <p>2 50 mV 500 μs</p> <p>3 50 mV 500 μs</p> <p>4 50 mV 500 μs</p> <p>500 MS/s</p> <p>1 DC 10.0 V</p> <p>STOPPED</p>							

Test-Location:
ASED-FN


PA_Resp.: Th. Schmidt

Test-Eng.: A. Koppe
OCOE-Operator: S. Hamer

Test_Manager:
A. Koppe

Date:
17.10.2007

St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
2.5		Measure and record the oscilloscope trace when activating the HL#22 "DCT01170 (HL22)" command on P42 between pin 7 and 8 bConnector: P/J42 7 8							
	1	PULSDURATION	041.005	24,00	28,00	msec	26,65	PM	P
	2	UPPER-LEVEL	041.005	22,00	29,00	_Volt	24,94	PM	P
	3	LOWER-LEVEL	041.005	-0,10	2,00	_Volt	-0,10	PM	P
	4	RISE-TIME	041.005	50,00	500,00	µsec	115,16	PM	P
	5	FALL-TIME	041.005	50,00	500,00	µsec	143,78	PM	P
	6	TRIGGERLEVEL	041.005	10,00	10,00	_Volt	10,00	PM	P
	7	TRIGGERSLOPE	041.005	1,00	1,00	_Pos	1,00	PM	P



St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
		<p>18-Oct-07 MT 041 005 Step 7.3.2.5</p> <p>8:14:48</p> <p>1-2</p> <p>50 ps</p> <p>10.0 V</p> <p>REMOTE ENABLE</p> <p>GO TO LOCAL</p> <p>r@level(1) 115.161 ps</p> <p>50 ps</p> <p>1 50 mV 500 %</p> <p>2 50 mV 500 %</p> <p>3 50 mV 500 %</p> <p>4 50 mV 500 %</p> <p>1 DC 10.0 V</p> <p>500 MS/s</p> <p>STOPPED</p>							

St-No	Sub-St	Test - Step - Description	Meas. Type	Min.Nom. Value	Max.Nom. Value	Phys. Unit	Actual Value	C-St	P N
		<p>18-Oct-07 8:14:56 MT 041.005 Step 7.3.2.5 REMOTE ENABLE</p> <p>F@level(8) 140.783 us</p> <p>50 ps 1 50 mV 500 ns 2 50 mV 500 ns 3 50 mV 500 ns 4 50 mV 500 ns 500 MS/s STOPPED</p>							
2.6		Switch OFF LCL #25 for the Nominal LPU Power issue TC: DC25B170							
2.7		Switch OFF LCL #26 for the Nominal LPU Power issue TC: DC26B170							
2.8		Disconnect IDAS-5 Testhead-1 and 9-pole adapter No. 9D between connectors HSLPU P/J41 and connect directly							
2.9		Disconnect IDAS-5 Testhead-2 and 9-pole adapter No. 9D between connectors HSLPU P/J42 and connect directly							

END OF DOCUMENT

Name	Dep./Comp.		Name	Dep./Comp.
Alberti von Mathias Dr.	ASG23	✗	Schmidt Thomas	AED15
Baldock Richard	FAE12		Schweickert Gunn	ASG23
Barlage Bernhard	AED13		Sonn Nico	ASG51
Bayer Thomas	ASA42		Steininger Eric	AED32
Brune Holger	ASA45	✗	Stritter Rene	AED11
Edelhoff Dirk	AED2		Suess Rudi	OTN/ASA44
Fehringer Alexander	ASG13		Theunissen Martijn	DSSA
Fricke Wolfgang Dr.	AED 65	✗	Vascotto Riccardo	HE Space
Geiger Hermann	ASA42		Wagner Klaus	ASG23
Grasl Andreas	OTN/ASA44	✗	Wietbrock Walter	AET12
Grasshoff Brigitte	AET12		Wöhler Hans	ASG23
Hamer Simon	Terma		Wussner Ulrich	ASE252
Hanka Erhard	FIS52		Zunstein Armin	ASQ42
Hendrikse Jeffrey	HE Space			
Hendry David	Terma	✗		
Hengstler Reinhold	ASA42			
Hinger Jürgen	ASG23			
Hohn Rüdiger	AED65			
Hölzle Edgar Dr.	AED32			
Hopfgarten Michael	AED32			
Huber Johann	ASA42			
Hund Walter	ASE252	✗		
Idler Siegmund	AED312	✗		
Iványi von András	FAE12			
Jahn Gerd Dr.	ASG23			
Kalde Clemens	ASM2	✗	ESA/ESTEC	ESA
Kettner Bernhard	AET42	✗	Thales Alenia Space Cannes	TAS-F
Kienke Uwe	ASG72		Thales Alenia Space Torino	TAS-I
Knoblauch August	AET32			
Koelle Markus	ASA43		Instruments:	
Koppe Axel	AED312	✗	MPE (PACS)	MPE
Kroeker Jürgen	AED65	✗	RAL (SPIRE)	RAL
La Giota Valentina	Terma		SRON (HIFI)	SRON
Lang Jürgen	ASE252	✗		
Langenstein Rolf	AED15	✗		
Langfermann Michael	ASA41		Subcontractors:	
Martin Olivier	ASA43		Austrian Aerospace	AAE
Maukisch Jan	ASA43		Austrian Aerospace	AAEM
Much Christoph	ASA43		BOC Edwards	BOCE
Müller Jörg	ASA42		Dutch Space Solar Arrays	DSSA
Müller Martin	ASA43	✗	EADS Astrium Sub-Subsyst. & Equipment	ASSE
Pietroboni Karin	AED65		EADS CASA Espacio	CASA
Platzler Wilhelm	AED2		EADS CASA Espacio	ECAS
Reichle Konrad	ASA42		European Test Services	ETS
Runge Axel	OTN/ASA44		Patria New Technologies Oy	PANT
Sauer Maximilian Dr.	AED65		SENER Ingenieria SA	SEN
Schink Dietmar	AED32		Thales Alenia Space, Antwerp	TAS-ETCA