



Test Report

Herschel

Title: **Final Mating of SPIRE FM SIH-IS and SIH-SS after LPU Integration**

CI-No: 125 200

Prepared by: A. Koppe *A. Koppe* Date: 25.10.07

Checked by: S. Idler *S. Idler* 25.10.07

Product Assurance: S. Stritter *S. Stritter* 26.10.07

Configuration Control: W. Wietbrock *W. Wietbrock* 06.11.07

Project Management: Dr. W. Fricke *W. Fricke* 06/11/2007

Distribution: See Distribution List (last page)

Copying of this document, and giving it to others and the use or communication of the contents thereof, are forbidden without express authority. Offenders are liable to the payment of damages. All rights are reserved in the event of the grant of a patent or the registration of a utility model or design.

| Issue | Date | Sheet | Description of Change | Release |
|-------|------------|-------|-----------------------|---------|
| 1 | 25.10.2007 | All | First issue | |

Table of Content

| | | |
|----------|---------------------------------|----------|
| 1 | Scope | 4 |
| 1.1 | Objective | 4 |
| 2 | Test Report Summary | 5 |
| 2.1 | Operations | 5 |
| 2.2 | Test Procedure | 5 |
| 2.3 | Procedure Variations | 5 |
| 2.4 | Non Conformances | 5 |
| 2.5 | Conclusion | 5 |
| | Annex 1 AS RUN PROCEDURE | 6 |

1 Scope

1.1 Objective

This report describes the final mating of the SPIRE FM SIH-IS and SIH-SS required after the LPU integration at the SVM connector brackets CB 312 100, CB 312 200, CB 312 300, mounted on the SVM upper closure panel.

2 Test Report Summary

2.1 Operations

Execution of step-by-step procedure for the mating of the SPIRE SIH-IS and SIH-SS at SVM CBs 312 100, 312 200, 312 300.

2.2 Test Procedure

HP-2-ASED-TP-0166, issue 1, chapter 9

2.3 Procedure Variations

Only chapter 9 of the as-run procedure is applicable

2.4 Non Conformances

None

2.5 Conclusion

The final mating of the SPIRE FM SIH-SS and SIH-IS after the LPU integration has been successfully completed according to chapter 9 of the step-by-step procedure.

Note: Chapters 7 and 8 of the as-run-procedure are not applicable for this activity.

The securing of the connectors has not been performed yet but has been implemented as OPEN WORK item in the SVM Open Work list, ref. item 432.

Annex 1 AS RUN PROCEDURE

Title:

SPIRE PFM Final Electrical Integration Procedure

CI-No:

125 200

Prepared by:

A. Koppe & S. Hamer

Date:

10.09.2007

Checked by:

S. Jdler

12.09.2007

Product Assurance: for R. Striffler

B. Bulage

12.09.2007

Configuration Control:

W. Wietbrock

15.09.2007

Project Management:

Dr. W. Fricke

02/10/2007

Distribution:

See Distribution List (last page)

Copying of this document, and giving it to others and the use or communication of the contents thereof, are forbidden without express authority. Offenders are liable to the payment of damages. All rights are reserved in the event of the grant of a patent or the registration of a utility model or design.

| Issue | Date | Sheet | Description of Change | Release |
|-------|----------|-------|-----------------------|---------|
| 1 | 10.09.07 | all | Initial issue | |

Table of Content

| | | |
|----------|---|-----------|
| 1 | Scope | 7 |
| 2 | Documents/Drawings | 8 |
| 2.1 | Applicable Documents | 8 |
| 2.2 | Reference Documents | 8 |
| 2.3 | Other Documents | 8 |
| 3 | Personnel | 9 |
| 4 | Mating of SIH-IS to CVV-CB and SVM-CB | 10 |
| 4.1 | Prerequisites | 10 |
| 4.2 | End State | 10 |
| 4.3 | Notes | 10 |
| 5 | Conditions | 11 |
| 5.1 | Personnel | 11 |
| 5.2 | Environmental | 11 |
| 5.3 | General Precautions and Safety | 11 |
| 5.4 | Special Equipment | 12 |
| 5.5 | Test Configuration | 12 |
| 6 | Verification Requirements and Test Criteria | 13 |
| 7 | Step by Step Procedure | 14 |
| 8 | De-mating of SIH-IS and SIH-SS for LPU Integration | 39 |
| 8.1 | Prerequisites | 39 |
| 8.2 | End State | 39 |
| 8.3 | Notes | 39 |
| 9 | Step by Step Procedure for Mating of SIH-IS and SIH-SS after LPU Integration | 43 |
| 9.1 | Prerequisites | 43 |
| 9.2 | Notes | 43 |

| | | |
|-----------|--|-----------|
| 10 | Summary Sheets | 49 |
| 10.1 | Procedure Variation Summary | 49 |
| 10.2 | Non Conformance Report (NCR) Summary | 50 |
| 10.3 | Sign-off Sheet | 50 |
| 11 | APPENDICES | 51 |
| 11.1 | Procedure SPIRE Power On | 51 |
| 11.2 | Procedure SPIRE-FM-SFT-DPU-ON-P | 51 |
| 11.3 | Procedure SPIRE-FM-SFT-DRCU-ON-P | 53 |
| 11.4 | Procedure SPIRE-FM-SFT-FUNC-SCU-01-P | 55 |
| 11.5 | Procedure SPIRE-FM-SFT-FUNC-SCU-03-P | 56 |
| 11.6 | Procedure SPIRE-FM-SFT-FUNC-SCU-06-P | 58 |
| 11.7 | Procedure SPIRE-FM-SFT-FUNC-SCU-07-P | 60 |
| 11.8 | Procedure SPIRE-FM-SFT-FUNC-SCU-04-P | 62 |
| 11.9 | Procedure SPIRE-FM-SFT-FUNC-SCU-05-P | 63 |
| 11.10 | Procedure SPIRE-FM-SFT-FUNC-MCU-01-P | 64 |
| 11.11 | Procedure: SPIRE-FM-SFT-FUNC-MCU-02-P | 65 |
| 11.12 | Procedure SPIRE-FM-SFT-FUNC-BSM-01-P | 66 |
| 11.13 | Procedure SPIRE-FM-SFT-BSM-OFF-P | 67 |
| 11.14 | Procedure SPIRE-FM-SFT-FUNC-SMEC-01-P | 68 |
| 11.15 | Procedure SPIRE-FM-SFT-SMEC-OFF-P | 69 |
| 11.16 | Procedure SPIRE-FM-SFT-FUNC-DCU-01-P | 70 |
| 11.17 | Procedure: SPIRE-FM-SFT-FUNC-DCU-04-PHOT-P | 71 |
| 11.18 | Procedure: SPIRE-FM-SFT-PHOT-JFET-ON-01 | 72 |
| 11.19 | Procedure: SPIRE-FM-SFT-PHOT-JFET-ON-02 | 74 |
| 11.20 | Procedure: SPIRE-FM-SFT-PHOT-JFET-OFF | 76 |
| 11.21 | Procedure: SPIRE-FM-SFT-PLIA-OFF-P | 78 |
| 11.22 | Procedure: SPIRE-FM-SFT-FUNC-DCU-04-SPEC-P | 79 |
| 11.23 | Procedure: SPIRE-FM-SFT-SPEC-JFET-ON-01 | 80 |
| 11.24 | Procedure: SPIRE-FM-SFT-SPEC-JFET-ON-02 | 81 |
| 11.25 | Procedure: SPIRE-FM-SFT-SPEC-JFET-OFF | 82 |
| 11.26 | Procedure: SPIRE-FM-SFT-SLIA-OFF-P | 84 |
| 11.27 | Procedure SPIRE-FM-SFT-MCU-OFF-P | 85 |



Test Procedure

Herschel

| | | |
|-------|------------------------------------|----|
| 11.28 | Procedure SPIRE-FM-SFT-SCU-OFF-P | 86 |
| 11.29 | Procedure SPIRE Power OFF | 87 |
| 11.30 | Procedure: SPIRE-FM-SFT-DRCU-OFF-P | 87 |
| 11.31 | Procedure: SPIRE-FM-SFT-DPU-OFF-P | 88 |
| 11.32 | SPIRE-SAFE-SWITCH-OFF | 89 |

List of Tables

| | |
|--|----|
| Table 1: Applicable Documents | 8 |
| Table 2: Reference Documents | 8 |
| Table 10.1-1: Procedure Variation Sheet | 49 |
| Table 10.2-1: Non-Conformance Record Sheet | 50 |

1 Scope

This document establishes a cover procedure which incorporates the detailed step-by-step procedure, prerequisites and conditions, copied from RD1, to be followed for the final electrical integration of the SPIRE Warm Units and their associated harness on the SVM panel with the SPIRE FPU and its SIH at the CVV CB.

It should be noted that the LPU integration is performed later during the HERSCHEL PFM AIT flow. Therefore, a separate chapter is given for the integration once this unit is available.

The following activities are to be performed:

- Mating of the SIH-IS to CVV-CB and SVM-CB covers the following activities:

1. The mating of the SIH-IS and SIH-CS harnesses at the CVV-CB vacuum feedthrus
2. The mating of the SIH-IS and SIH-SS harnesses at the SVM-CB
3. Integration electrical tests whereby the balance of I_{ds} and I_{ss} for the JFET modules is measured

- De-mating of SIH-IS and SIH-SS for LPU Integration has been included because it is foreseen that the LPU will have to be integrated after initial electrical integration and UFT of SPIRE. This requires that the SIH-SS-11 is de-mated from the SIH-IS-11 and SIH-SS-13 is de-mated from the SIH-IS-13 at the SVM-CB and the SPIRE SVM panel is opened.

- Step by Step Procedure for Mating of SIH-IS and SIH-SS after LPU Integration has been included to document the procedure for the final mating of the SIH-SS-XX and SIH-IS-XX after integration and test of the LPU.

2 Documents/Drawings

2.1 Applicable Documents

| No. | Document Name | Document Number | Iss./Rev. |
|-----|--|----------------------|-----------|
| AD1 | SPIRE FPU Handling and Mechanical Integration Procedure | SPIRE-RAL-PRC-002802 | 2 |
| AD2 | Making SPIRE ESD Safe | SPIRE-RAL-NOT-002028 | 2 |
| AD3 | ESD Regeln für HERSCHEL PLM und Integrations-Aktivitäten | HP-2-ASED-PR-0062 | 1 |
| AD3 | PA Plan | HP-2-ASED-PL-0007 | 2.1 |

Table 1: Applicable Documents

2.2 Reference Documents

| No. | Document Name | Document Number | Iss./Rev. |
|-----|---|--------------------|-----------|
| RD1 | PFM FINAL SIH ELECTRICAL INTEGRATION/CHECKOUT PROCEDURE | SPIRE-RAL-PRC-2951 | 2.1 |
| RD2 | SPIRE FM SHORT FUNCTIONAL TEST PROCEDURE | SPIRE-RAL-PRC-2494 | 2.4 |
| RD3 | PFM CVV INTERNAL SPIRE-SIH ELECTRICAL INTEGRATION PROCEDURE | HP-2-ASED-TP-0150 | 1.0 |
| RD4 | PFM CVV EXTERNAL CHH AND SIH RE-MATING | HP-2-ASED-TP-0158 | 1.0 |

Table 2: Reference Documents

2.3 Other Documents

None

3 Personnel

The attendance of the following personnel is requested for the SPIRE PFM final electrical integration:

- SPIRE Engineer
- ASED Engineer
- ASED PA

4 Mating of SIH-IS to CVV-CB and SVM-CB

4.1 Prerequisites

1. The DCU, FCU and DPU have been mechanically and electrically integrated to the SVM panel and the SIH-SS harnesses are all integrated but not mated to the SVM-CB.
2. If the LPU is not integrated to the FCU, **make sure that the dummy LPU simulator plugs are mated to FCU P43/P44** once the harness modifications on the SPIRE panel has been made.
3. The SIH-CS harnesses have been mated to the SPIRE FPU + JFP/JFS
4. The SPIRE SVM panel has been closed
5. The PLM has been mechanically integrated to the SVM
6. The SIH-IS-XX harnesses (XX = 1...13) are mechanically integrated onto the outside of the cryostat.
 - a. They are mated at the CVV internal FTTH connectors
 - b. They are temporary mechanically integrated to the SVM-CB without electrical termination
7. The SPIRE UFT has been successfully completed.
8. The Ground strap (red tag) from the FPU shall be removed.

4.2 End State

The electrical integration tests have been completed

The instrument is ready for SFT

4.3 Notes

1. SPIRE is ESD sensitive. Handling of these units is to be carried out by personnel suitably trained and equipped. Prior to carrying out the mating operations detailed below, the Pxx and Jxx connectors are to put in an ionized air stream continuously to discharge the harness.
2. If an anomaly is detected during the integration test, then the instrument can be switched off from any state using the procedure in §11.32 – SPIRE-SAFE-SWITCH-OFF.

5 Conditions

5.1 Personnel

The treatment process will be conducted by the following personnel:

| <i>Personnel</i> | <i>Date</i> | <i>Name</i> |
|----------------------|-------------|--------------|
| AIT Manager | 22. 10. 07 | M. Müller |
| AIT Engineer | 22. 10. 07 | R. Hengstler |
| Harness Engineer | 22. 10. 07 | U. Wössner |
| SPIRE Representative | ✓ | ✓ |
| Product Assurance | 22. 10. 07 | B. Barlage |

The performers are requested to follow the procedure step-by step and mark the execution of each test step in the allocated column. Results shall be plotted and marked by the concerned test step and figure number. Any deviations which may be necessary shall be described on the assigned pages in chapter 10.1 with a reference at the concerned position in the text where the deviation occurred.

All mating shall be recorded in the test procedure ref. HP-2-ASED-TP-0158 (RD4) too!

5.2 Environmental

There are no specific environmental conditions for treatment process other than in the step by step procedure

5.3 General Precautions and Safety

All safety precautions concerning the personnel and the hardware and must be observed during the whole test.

All operations have to be in accordance to the ESD rules as per AD2 and AD3.

The test responsible confirms with his signature in chapter 5.1 above that all participants are aware of these precautions.

5.4 Special Equipment

| Qty. | Equipment | Supplier |
|-------------|------------------------|----------|
| 1 | BoB, 128 way | ASED |
| 1 | Resistor, 1 MOhm (5%) | SPIRE |
| As required | Resistors, 47 Ohm (5%) | SPIRE |

5.5 Test Configuration

The following test configuration on the HERSCHEL EGSE shall be selected:

CDMU:

- The Bus IF selected on the HCDMU should be for SPIRE PRIME Instrument, (i.e., 27 TM slots allocated for SPIRE telemetry). For the PRIME side tests the BUS Configuration should be SPIRE Prime (i.e. RT=21) and for the REDUNDANT side test the BUS Configuration should be SPIRE Redundant (i.e. RT=22)
- The HCDMU and CCS should be interconnected.

CCS & IEGSE:

- The CCS and the IEGSE should be interconnected via the Pipe GW.
- The SPIRE MIB should be imported on the CCS.
- The CCS Handler application software should be running on the IEGSE.
- IEGSE system is up and running.(Database, SCOS , QLA, EGSE Router and Gateway, TM ingestion)

6 Verification Requirements and Test Criteria

As per step-by-step procedure

7 Step by Step Procedure

| Step-No. | Integration-Step-Description | Results/Remarks | Sign Off |
|----------|--|---|----------|
| | Mating of SIH-IS to SIH-CS | | |
| 1 | Prepare a 128-way BOB to short all contacts to spacecraft chassis via a 1MOhm resistor | Alternatively a IDAS shorting plug with 1 MOhm to GND can be used | |
| 2 | SIH-04 Short contacts of 312100 J03 to spacecraft chassis with BOB | | |
| 3 | Remove Type-VII safeing plug from 211121 J22 | | |
| 4 | Mate 211121 P22 to J22 | | |
| 5 | Demate BOB from 312110 J03 | | |
| 6 | Mate Type-VII safeing plug to 312100 J03 | | |
| 7 | SIH-05 Short contacts of 312100 J02 to spacecraft chassis with BOB | | |
| 8 | Remove Type-VII safeing plug from 211121 J23 | | |
| 9 | Mate 211121 P23 to J23 | | |
| 10 | Demate BOB from 312100 J02 | | |
| 11 | Mate Type-VII safeing plug to 312100 J02 | | |
| 12 | SIH-06 Short contacts of 312200 J03 to spacecraft chassis with BOB | | |
| 13 | Remove Type-VII safeing plug from 211121 J24 | | |
| 14 | Mate 211121 P24 to J24 | | |
| 15 | Demate BOB from 312200 J03 | | |
| 16 | Mate Type-VII safeing plug to 312200 J03 | | |
| 17 | SIH-07 Short contacts of 312200 J04 to spacecraft chassis with BOB | | |
| 18 | Remove Type-VII safeing plug from 211121 J25 | | |
| 19 | Mate 211121 P25 to J25 | | |

Doc. No: HP-2-ASED-TP-0166

Issue: 1

Date: 10.09.07

File: SPIRE PFM Final Electrical Integration Procedure HP-2-ASED-TP-0166 1.doc

| | | | |
|----|---|--|--|
| 20 | Demate BOB from 312200 J04 | | |
| 21 | Mate Type-VII safeing plug to 312200 J04 | | |
| 22 | SIH-08 Short contacts of 312200 J01 to spacecraft chassis with BOB | | |
| 23 | Remove Type-VII safeing plug from 211121 J27 | | |
| 24 | Mate 211121 P27 to J27 | | |
| 25 | Demate BOB from 312200 J01 | | |
| 26 | Mate Type-VII safeing plug to 312200 J01 | | |
| 27 | SIH-09 Short contacts of 312200 J02 to spacecraft chassis with BOB | | |
| 28 | Remove Type-VII safeing plug from 211121 J28 | | |
| 29 | Mate 211121 P28 to J28 | | |
| 30 | Demate BOB from 312200 J02 | | |
| 31 | Mate Type-VII safeing plug to 312200 J02 | | |
| 32 | SIH-10 Short contacts of 312300 J06 to spacecraft chassis with BOB | | |
| 33 | Remove Type-VII safeing plug from 211121 J34 | | |
| 34 | Mate 211121 P34 to J34 | | |
| 35 | Demate BOB from 312300 J06 | | |
| 36 | Mate Type-VII safeing plug to 312300 J06 | | |
| 37 | SIH-12 Short contacts of 312300 J05 to spacecraft chassis with BOB | | |
| 38 | Remove Type-VII safeing plug from 211121 J33 | | |
| 39 | Mate 211121 P33 to J33 | | |
| 40 | Demate BOB from 312300 J05 | | |
| 41 | Mate Type-VII safeing plug to 312300 J05 | | |
| 42 | SIH-02 Short contacts of 312200 J05 to spacecraft chassis with BOB | | |
| 43 | Remove Type-VII safeing plug from 211121 J31 | | |



| | | | |
|----|---|--|--|
| 44 | Mate 211121 P31 to J31 | | |
| 45 | Demate BOB from 312200 J05 | | |
| 46 | Mate Type-VII safeing plug to 312200 J05 | | |
| 47 | SIH-11 Short contacts of 312300 J04 to spacecraft chassis with BOB | | |
| 48 | Remove Type-VIII safeing plug from 211121 J30 | | |
| 49 | Mate 211121 P30 to J30 | | |
| 50 | Demate BOB from 312300 J04 | | |
| 51 | Mate Type-VIII safeing plug to 312300 J04 | | |
| 52 | SIH-13 Short contacts of 312300 J03 to spacecraft chassis with BOB | | |
| 53 | Remove Type-VIII safeing plug from 211121 J29 | | |
| 54 | Mate 211121 P29 to J29 | | |
| 55 | Demate BOB from 312300 J03 | | |
| 56 | Mate Type-VIII safeing plug to 312300 J03 | | |
| 57 | SIH-01 Short contacts of 312200 J06 to spacecraft chassis with BOB | | |
| 58 | Remove Type-VI safeing plug from 211121 J32 | | |
| 59 | Mate 211121 P32 to J32 | | |
| 60 | Demate BOB from 312200 J06 | | |
| 61 | Mate Type-VI safeing plug to 312200 J06 | | |
| 62 | SIH-03 Short contacts of 312100 J04 to spacecraft chassis with BOB | | |
| 63 | Remove Type-V safeing plug from 211121 J26 | | |
| 64 | Mate 211121 P26 to J26 | | |
| 65 | Demate BOB from 312100 J04 | | |
| 66 | Mate Type-V safeing plug to 312100 J04 | | |
| | Idd/Iss measurement Preparation | | |

| | | | | |
|---|--|-----------------------|--|--|
| 67 | Prepare a 128-way BOB for inline insertion in CB312200 P06/J06 with 47Ω(5%) inline series resistors in the following contacts: | | | |
| | Function | Contact number | | |
| | PTC JFETV Bias A +ve | 24 | | |
| | PTC JFETV Bias A -ve | 35 | | |
| | SLW JFETV A1 +ve | 92 | | |
| | SLW JFETV A1 -ve | 91 | | |
| | SLW JFETV A2 +ve | 103 | | |
| | SLW JFETV A2 -ve | 113 | | |
| | SSW JFETV1 A +ve | 66 | | |
| | SSW JFETV1 A -ve | 57 | | |
| | SSW JFETV2 A +ve | 70 | | |
| | SSW JFETV2 A -ve | 81 | | |
| The remaining contacts have inline "bridges" Temporarily label BOB as SPIRE Spect Test | | | | |

01 SEP 07
 09:40:00 (P. CB3-312200 P06/J06) 0011
 10:00:00 (P. CB3-312200 P06/J06) 0011

| | | | |
|----|--|----------|------------------|
| 68 | Measure and record the resistance of the inline resistors in the BOB prepared for CB312200 P06/J06. The measured resistance is to be $47 \pm 2.3 \Omega$ | Function | Resistance (Ohm) |
| | | 24 | |
| | | 35 | |
| | | 92 | |
| | | 91 | |
| | | 103 | |
| | | 113 | |
| | | 68 | |
| | | 57 | |
| | | 70 | |
| | | 81 | |

Prepare a 128-way BOB for inline insertion in CB312100 P04/J04 with 47Ω(5%) inline series resistors in the following contacts:

| Function | Contact number |
|----------------|----------------|
| PSW_JFETV1 A + | 26 |
| PSW_JFETV1 A - | 37 |
| PSW_JFETV2 A + | 38 |
| PSW_JFETV2 A - | 49 |
| PSW_JFETV3 A + | 48 |
| PSW_JFETV3 A - | 60 |
| PSW_JFETV4 A + | 59 |
| PSW_JFETV4 A - | 71 |
| PSW_JFETV5 A + | 50 |
| PSW_JFETV5 A - | 61 |
| PSW_JFETV6 A + | 62 |
| PSW_JFETV6 A - | 51 |
| PMW_JFETV1 A + | 86 |
| PMW_JFETV1 A - | 87 |
| PMW_JFETV2 A + | 97 |
| PMW_JFETV2 A - | 98 |
| PMW_JFETV3 A + | 108 |
| PMW_JFETV3 A - | 109 |
| PMW_JFETV4 A + | 116 |
| PMW_JFETV4 A - | 117 |
| PLW_JFETV1 A + | 99 |
| PLW_JFETV1 A - | 100 |
| PLW_JFETV2 A + | 110 |
| PLW_JFETV2 A - | 111 |

69

The remaining contacts have inline "bridges"

Temporarily label BOB as SPIRE Phot Test

Doc. No:

Issue:

Date:

HP-2-ASED-TP-016

1

Integration Procedure HP-2-ASED-TP-016

| 70 | <p>Measure and record the resistance of the inline resistors in the BOB prepared for CB312200 P06/J06. The measured resistance is to be $47 \pm 2.3 \Omega$</p> | <table border="1"> <thead> <tr> <th>Contact number</th> <th>Resistance</th> </tr> </thead> <tbody> <tr><td>28</td><td></td></tr> <tr><td>37</td><td></td></tr> <tr><td>38</td><td></td></tr> <tr><td>49</td><td></td></tr> <tr><td>48</td><td></td></tr> <tr><td>60</td><td></td></tr> <tr><td>59</td><td></td></tr> <tr><td>71</td><td></td></tr> <tr><td>50</td><td></td></tr> <tr><td>61</td><td></td></tr> <tr><td>62</td><td></td></tr> <tr><td>51</td><td></td></tr> <tr><td>86</td><td></td></tr> <tr><td>87</td><td></td></tr> <tr><td>97</td><td></td></tr> <tr><td>98</td><td></td></tr> <tr><td>108</td><td></td></tr> <tr><td>109</td><td></td></tr> <tr><td>116</td><td></td></tr> <tr><td>117</td><td></td></tr> <tr><td>99</td><td></td></tr> <tr><td>100</td><td></td></tr> <tr><td>110</td><td></td></tr> <tr><td>111</td><td></td></tr> </tbody> </table> | Contact number | Resistance | 28 | | 37 | | 38 | | 49 | | 48 | | 60 | | 59 | | 71 | | 50 | | 61 | | 62 | | 51 | | 86 | | 87 | | 97 | | 98 | | 108 | | 109 | | 116 | | 117 | | 99 | | 100 | | 110 | | 111 | | |
|----------------|--|---|----------------|------------|----|--|----|--|----|--|----|--|----|--|----|--|----|--|----|--|----|--|----|--|----|--|----|--|----|--|----|--|----|--|----|--|-----|--|-----|--|-----|--|-----|--|----|--|-----|--|-----|--|-----|--|--|
| Contact number | Resistance | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 28 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 37 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 38 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 49 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 48 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 60 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 59 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 71 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 50 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 61 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 62 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 51 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 86 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 87 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 97 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 98 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 108 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 109 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 116 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 117 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 99 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 100 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 110 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 111 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| | Grounding Check | | |
|----|---|--|--|
| 71 | Remove SPIRE Safeing Plug Type-V from SVM-CB 312100 J04 | | |
| 72 | Remove SPIRE Safeing Plug Type-VI from SVM-CB 312200 J06. | | |
| 73 | Remove SPIRE Safeing Plug Type-VIII from SVM-CB 312300 J04. | | |
| 74 | Remove SPIRE Safeing Plug Type-VIII from SVM-CB 312300 J03. | | |
| 75 | Prepare a 128-way BOB and short contacts to remove charge | | |
| 76 | Mate BOB to 312200 J06 | | |
| 77 | Verify FPU Isolation from OBA by measuring Pin 5 to Chassis: s.b. > 1 MOhm | | |
| 78 | Verify Analogue Ground Isolation from OBA by measuring Pin 93 to Chassis: s.b. > 1 MOhm | | |
| 79 | Demate BOB from 312200 J06 | | |
| 80 | Mate BOB to 312100 J04 | | |
| 81 | Verify FPU Isolation from OBA by measuring Pin 2 to Chassis: s.b. > 1 MOhm | | |
| 82 | Verify Analogue Ground Isolation from OBA by measuring Pin 36 to Chassis: s.b. > 1 MOhm | | |
| 83 | Demate BOB from 312100 J04 | | |
| 84 | Mate SPIRE Safeing Plug Type-V to SVM-CB 312100 J04 | | |
| 85 | Mate SPIRE Safeing Plug Type-VI to SVM-CB 312200 J06. | | |
| 86 | Mate SPIRE Safeing Plug Type-VIII to SVM-CB 312300 J04. | | |
| 87 | Mate SPIRE Safeing Plug Type-VIII to SVM-CB 312300 J03. | | |
| | Subsystem harness mating | | |
| 88 | Verify that CB 312300 J01 is mated with CB 312300 P01 | | |
| 89 | Verify that CB 312300 J02 is mated with CB 312300 P02 | | |
| 90 | Remove and store protective cover from CB 312300 P06 | | |

| | | | |
|-----|--|--|--|
| 91 | Remove and store SPIRE Safeing Plug Type-VII from CB 312300 J06 | | |
| 92 | Mate CB 312300 P06 to 312300 J06 | | |
| 93 | Remove and store protective cover from CB 312300 P05 | | |
| 94 | Remove and store SPIRE Safeing Plug Type-VII from CB 312300 J05 | | |
| 95 | Mate CB 312300 P05 to 312300 J05 | | |
| 96 | Remove and store protective cover from CB 312300 P04 | | |
| 97 | Remove and store SPIRE Safeing Plug Type-VIII from CB 312300 J04 | | |
| 98 | Mate CB 312300 P04 to 312300 J04 | | |
| 99 | Remove and store protective cover from CB 312300 P03 | | |
| 100 | Remove and store SPIRE Safeing Plug Type-VIII from CB 312300 J03 | | |
| 101 | Mate CB 312300 P03 to 312300 J03 | | |
| | Spectrometer Initial Mating | | |
| 102 | Short the contacts of the BOB for 312200 J06/P06 to chassis to remove any charge | | |
| 103 | Remove and store the protective cover from 312200 P06 | | |
| 104 | Mate the BOB prepared for 312200 J06/P06 to 312200 P06 | | |
| 105 | Demate and store the SPIRE Safeing Plug Type-VI from SVM-CB 312200 J06 | | |
| 106 | Mate the inline BOB prepared for 312200 J06/P06 to 312200 J06 | | |
| 107 | Remove and store the protective cover from 312200 P05 | | |
| 108 | Demate the SPIRE Safeing Plug Type-VII from SVM-CB 312200 J05 | | |
| 109 | Mate 312200 P05 to 312200 J05 | | |
| 110 | Mate 312100 P01A to J01A | | |
| | Photometer Initial Mating | | |

| | | | |
|-----|--|--|--|
| | <i>SIH-03</i> | | |
| 111 | Short the contacts of the BOB for 312100 J04/P04 to chassis to remove any charge | | |
| 112 | Remove and store the protective cover from 312100 P04 | | |
| 113 | Mate the BOB prepared for 312100 J04/P04 to 312200 P04 | | |
| 114 | Demate the SPIRE Safeing Plug Type-V from SVM-CB 3122100 J04 | | |
| 115 | Mate the inline BOB prepared for 312100 J04/P04 to 312100 J04 | | |
| | <i>SIH-04</i> | | |
| 116 | Remove and store the protective cover from 312100 P03 | | |
| 117 | Demate the SPIRE Safeing Plug Type-VII from SVM-CB 312100 J03 | | |
| 118 | Mate 312100 P03 to 312200 J03 | | |
| 119 | Mate 312100 P01B to J01B | | |
| | <i>SIH-05</i> | | |
| 120 | Remove and store the protective cover from 312100 P02 | | |
| 121 | Demate the SPIRE Safeing Plug Type-VII from SVM-CB 312100 J02 | | |
| 122 | Mate 312100 P02 to 312200 J02 | | |
| | <i>SIH-06</i> | | |
| 123 | Remove and store the protective cover from 312200 P03 | | |
| 124 | Demate the SPIRE Safeing Plug Type-VII from SVM-CB 312200 J03 | | |
| 125 | Mate 312200 P03 to 312200 J03 | | |
| | <i>SIH-07</i> | | |
| 126 | Remove and store the protective cover from 312200 P04 | | |
| 127 | Demate the SPIRE Safeing Plug Type-VII from SVM-CB 312200 J04 | | |

| | | | |
|-----|---|---|--|
| 128 | Mate 312200 P04 to 312200 J04 <i>SIH-08</i> | | |
| 129 | Remove and store the protective cover from 312200 P01 | | |
| 130 | Demate the SPIRE Safeing Plug Type-VII from SVM-CB 312200 J01 | | |
| 131 | Mate 312200 P01 to 312200 J01 <i>SIH-09</i> | | |
| 132 | Remove and store the protective cover from 312200 P02 | | |
| 133 | Demate the SPIRE Safeing Plug Type-VII from SVM-CB 312200 J02 | | |
| 134 | Mate 312200 P02 to 312200 J02 | | |
| | Instrument switch-on (Phot. JFETs) | | |
| 135 | Execute Procedure: SPIRE-FM-SFT-DPU-ON-P | Nominal HK packets: Critical HK packets: THSK refresh: TM2N refresh: TM1N refresh: SPIRE/CCS time sync: SCOS/THSK/QLA sync: | |

| | | | |
|------------|--|---|--|
| <p>136</p> | <p>Execute Procedure: SPIRE-FM-SFT-DRCU-ON-P</p> | <p>THSK stop: TM2N stop: THSK start: TM2N start: SCUP5V (~ 5.2 ± 0.5V); SCUP9V (~ 9.0 ± 0.2V); SCUM9V (~ -9.0 ± 0.2V); BIASP5V (~ 5.1 ± 0.5V); BIASP9V (~ 9.0 ± 0.2V); BIASM9V (~ -9.0 ± 0.2V);</p> | |
| <p>137</p> | <p>Execute Procedure: SPIRE-FM-SFT-FUNC-SCU-01-P</p> | <p>SCUFRAMECNT: TM5N:</p> | |
| <p>138</p> | <p>Execute Procedure: SPIRE-FM-SFT-FUNC-SCU-03-P</p> | <p>SCUTEMPSTAT: PUMPHTRTEMP: PUMPHSTEMP: EVAPHSTEMP: SHUNTTEMP: EMCFILTEMP: SL0TEMP: PL0TEMP: OPTTEMP: BAFTEMP: BSMIFTEMP: SCAL2TEMP: SCAL4TEMP: SCALTEMP: SMECIFTEMP: SMECTEMP: BSMTEMP:</p> | |

| | | | |
|-----|--|--|--|
| 139 | Execute Procedure: SPIRE-FM-SFT-FUNC-SCU-06-P | SUBKSTAT: SUBKTEMP: | |
| 140 | Execute Procedure: SPIRE-FM-SFT-FUNC-SCU-07-P | SPHSV: EVHSV: SPHTRV: | |
| 141 | Execute Procedure: SPIRE-FM-SFT-FUNC-SCU-04-P | PCALV: PCALCURR: | |
| 142 | Execute Procedure: SPIRE-FM-SFT-FUNC-SCU-05-P | SCAL4CURR: SCAL4V: SCAL2CURR: SCAL2V: | |
| 143 | Execute Procedure: SPIRE-FM-SFT-FUNC-MCU-01-P | MCUBITSTAT: MCUP5V: MCUP14V: MCUM14V: MCUP15V: MCUM15V: MCUMACTEMP: MCUSMECTEMP: MCUBSMTEMP: | |
| 144 | Execute Procedure: SPIRE-FM-SFT-FUNC-MCU-02-P | MCUFRAMECNT: | |
| 145 | Execute Procedure: SPIRE-FM-SFT-FUNC-BSM-01-P | CHOPSENSPWR: JIGGSENSPWR: | |
| 146 | Execute Procedure: SPIRE-FM-SFT-BSM-OFF-P | CHOPSENSPWR: JIGGSENSPWR: | |
| 147 | Execute Procedure: SPIRE-FM-SFT-FUNC-SMEC-01-P | SMECENCNPPWR: SMECLVDTPWR: | |
| 148 | Execute Procedure: SPIRE-FM-SFT-SMEC-OFF-P | SMECENCNPPWR: SMECLVDTPWR: | |



Test Procedure

Herschel

| | | | |
|----------------------------|--|---|--|
| 149 | Execute Procedure: SPIRE-FM-SFT-FUNC-DCU-01-P | DCUFRAMECNT: | |
| 150 | Execute Procedure: SPIRE-FM-SFT-FUNC-DCU-04-PHOT-P | PLIABITSTAT: PLIAP5V: PLIAP9V: PLIAM9V: LIAP1TEMP to LIAP9TEMP: | |
| 151 | Execute Procedure: SPIRE-FM-SFT-PHOT-JFET-ON-01 | PSWJFETSTAT: PMLWJFETSTAT: PSWJFET1V: PSWJFET2V: PSWJFET3V: PSWJFET4V: PSWJFET5V: PSWJFET6V: PMWJFET1V: PMWJFET2V: PMWJFET3V: PMWJFET4V: PLWJFET1V: PLWJFET2V: TCJFETV: | |
| Photometer and PTC Idd/Iss | | | |

| <p>152</p> <p>Measure the voltage drop with a DVM across the inline resistors in the BOB prepared for CB312100 P04/J04. The expected values should lie between 55 and 100mV</p> <p>(PLW, PSW and PMW)</p> | <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 60%;">Contact number</th> <th style="width: 40%;">Voltage drop</th> </tr> </thead> <tbody> <tr><td style="text-align: center;">26</td><td></td></tr> <tr><td style="text-align: center;">37</td><td></td></tr> <tr><td style="text-align: center;">38</td><td></td></tr> <tr><td style="text-align: center;">49</td><td></td></tr> <tr><td style="text-align: center;">48</td><td></td></tr> <tr><td style="text-align: center;">60</td><td></td></tr> <tr><td style="text-align: center;">59</td><td></td></tr> <tr><td style="text-align: center;">71</td><td></td></tr> <tr><td style="text-align: center;">50</td><td></td></tr> <tr><td style="text-align: center;">61</td><td></td></tr> <tr><td style="text-align: center;">62</td><td></td></tr> <tr><td style="text-align: center;">51</td><td></td></tr> <tr><td style="text-align: center;">66</td><td></td></tr> <tr><td style="text-align: center;">87</td><td></td></tr> <tr><td style="text-align: center;">97</td><td></td></tr> <tr><td style="text-align: center;">98</td><td></td></tr> <tr><td style="text-align: center;">108</td><td></td></tr> <tr><td style="text-align: center;">109</td><td></td></tr> <tr><td style="text-align: center;">116</td><td></td></tr> <tr><td style="text-align: center;">117</td><td></td></tr> <tr><td style="text-align: center;">99</td><td></td></tr> <tr><td style="text-align: center;">100</td><td></td></tr> <tr><td style="text-align: center;">110</td><td></td></tr> <tr><td style="text-align: center;">111</td><td></td></tr> </tbody> </table> | Contact number | Voltage drop | 26 | | 37 | | 38 | | 49 | | 48 | | 60 | | 59 | | 71 | | 50 | | 61 | | 62 | | 51 | | 66 | | 87 | | 97 | | 98 | | 108 | | 109 | | 116 | | 117 | | 99 | | 100 | | 110 | | 111 | |
|---|---|----------------|--------------|----|--|----|--|----|--|----|--|----|--|----|--|----|--|----|--|----|--|----|--|----|--|----|--|----|--|----|--|----|--|----|--|-----|--|-----|--|-----|--|-----|--|----|--|-----|--|-----|--|-----|--|
| | Contact number | Voltage drop | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 26 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 37 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 38 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 49 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 48 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 60 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 59 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 71 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 50 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 61 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 62 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 51 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 66 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 87 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 97 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 98 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 108 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 109 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 116 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 117 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 99 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 100 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 110 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 111 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| | | | |
|-----|--|----------------|--------------|
| 153 | Measure the voltage drop with a DVM across the inline resistors in the BOB prepared for CB312200 P06/J06. The expected values should lie between 55 and 100mV (PTC) | | |
| | | Contact number | Voltage drop |
| | | 24 | |
| | | 35 | |

IN PROGRESS
 UNDER REVIEW
 PROVISIONAL

| | | | | | | |
|-----|--|--|---|---|----------------------------|--|
| 154 | <p>Measure the voltage drop along the cryoharness for the PMW/PSW/PLW arrays using the contacts form the BOB prepared for CB312100 P04/J04</p> | | <p>Contact A</p> <p>26 37 38 49 48 60 59 71 50 61 62 51 86 87 97 98 108 109 116 117 99 100 110 111</p> | <p>Contact B</p> <p>42 54 53 52 41 30 10 11 19 29 16 27 7 14 24 35 23 34 33 45 70 81 69 80</p> | <p>Voltage Drop</p> | |
| 155 | <p>Measure the voltage drop along the cryoharness for the PTC arrays using the contacts form the BOB prepared for CB312200 P06/J06</p> | | <p>Contact A</p> <p>24 35</p> | <p>Contact B</p> <p>3 2</p> | <p>Voltage Drop</p> | |

| | | | |
|------------|----------------------------|--|--|
| <p>156</p> | <p>Execute (§0, p. 75)</p> | <p>PSWJFETSTAT: PMLWJFETSTAT: PSWJFET1V: PSWJFET2V: PSWJFET3V: PSWJFET4V: PSWJFET5V: PSWJFET6V: PMWJFET1V: PMWJFET2V: PMWJFET3V: PMWJFET4V: PLWJFET1V: PLWJFET2V: TCJFETV:</p> | |
|------------|----------------------------|--|--|

| | | |
|---|-----------------------|---------------------|
| <p>157</p> <p>Measure the voltage drop with a DVM across the inline resistors in the BOB prepared for CB312100 P04/J04. The expected values should lie between 55 and 100mV</p> <p>(PLW, PSW and PMW)</p> | Contact number | Voltage drop |
| | 26 | |
| | 37 | |
| | 38 | |
| | 49 | |
| | 48 | |
| | 60 | |
| | 59 | |
| | 71 | |
| | 50 | |
| | 61 | |
| | 62 | |
| | 51 | |
| | 86 | |
| | 87 | |
| | 97 | |
| | 98 | |
| | 108 | |
| | 109 | |
| | 116 | |
| 117 | | |
| 99 | | |
| 100 | | |
| 110 | | |
| 111 | | |

| | | | | | | |
|-----|--|--|--|--|----------------------------|--|
| 159 | <p>Measure the voltage drop along the cryoharness for the PMW/PSW/PLW arrays using the contacts form the BOB prepared for CB312100 P04/J04</p> | | <p>Contact A 26 37 38 49 48 60 59 71 50 61 62 51 86 87 97 98 108 109 116 117 99 100 110 111</p> | <p>Contact B 42 54 53 52 41 30 10 11 19 29 16 27 7 14 24 35 23 34 33 45 70 61 69 80</p> | <p>Voltage Drop</p> | |
| 160 | <p>Measure the voltage drop along the cryoharness for the PTC arrays using the contacts form the BOB prepared for CB312200 P06/J06</p> | | <p>Contact A 24 35</p> | <p>Contact B 3 2</p> | <p>Voltage Drop</p> | |

| | | | |
|-------------------------------|--|---|--|
| 161 | Execute Procedure: SPIRE-FM-SFT-PHOT-JFET-OFF | PSWJFETSTAT: PMLWJFETSTAT: PSWJFET1V: PSWJFET2V: PSWJFET3V: PSWJFET4V: PSWJFET5V: PSWJFET6V: PMWJFET1V: PMWJFET2V: PMWJFET3V: PMWJFET4V: PLWJFET1V: PLWJFET2V: TCJFETV: | |
| 162 | Execute Procedure: SPIRE-FM-SFT-PLIA-OFF-P | PLIABITSTAT: PLIAP5V: PLIAP9V: PLIAM9V: LIAP1TEMP to LIAP9TEMP: | |
| 163 | Execute Procedure: SPIRE-FM-SFT-FUNC-DCU-04-SPEC-P | SLIABITSTAT: SLIAP5V: SLIAP9V: SLIAM9V: LIAS1TEMP to LIAS3TEMP: | |
| Measure Spect. Idd/Iss | | | |

| 164 | Execute Procedure: SPIRE-FM-SFT-SPEC-JFET-ON-01 | SPECJFETSTAT: SSWJFET1V: SSWJFET2V: SLWJFET1V: | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|-----------|---|---|-----------|--------------|--------------|----|----|--|-----|----|-----|-----|----|--|-----|----|----|----|----|--|----|----|--|----|----|--|----|----|--|--|
| 165 | Measure the voltage drop with a DVM across the inline resistors in the BOB prepared for CB312200 P06/J06. The expected values should lie between 25 and 50mV for contacts 91, 92, 103 and 113 and between 55 and 100mV for contacts 57, 68, 70 and 81 | <table border="1"> <thead> <tr> <th data-bbox="1108 528 1451 564">Function</th> <th data-bbox="1451 528 1794 564">Voltage drop</th> </tr> </thead> <tbody> <tr><td data-bbox="1108 564 1451 601">92</td><td data-bbox="1451 564 1794 601"></td></tr> <tr><td data-bbox="1108 601 1451 638">91</td><td data-bbox="1451 601 1794 638"></td></tr> <tr><td data-bbox="1108 638 1451 675">103</td><td data-bbox="1451 638 1794 675"></td></tr> <tr><td data-bbox="1108 675 1451 711">113</td><td data-bbox="1451 675 1794 711"></td></tr> <tr><td data-bbox="1108 711 1451 748">68</td><td data-bbox="1451 711 1794 748"></td></tr> <tr><td data-bbox="1108 748 1451 785">57</td><td data-bbox="1451 748 1794 785"></td></tr> <tr><td data-bbox="1108 785 1451 821">70</td><td data-bbox="1451 785 1794 821"></td></tr> <tr><td data-bbox="1108 821 1451 858">81</td><td data-bbox="1451 821 1794 858"></td></tr> </tbody> </table> | Function | Voltage drop | 92 | | 91 | | 103 | | 113 | | 68 | | 57 | | 70 | | 81 | | | | | | | | | | | |
| Function | Voltage drop | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 92 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 91 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 103 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 113 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 68 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 57 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 70 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 81 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 166 | Measure the voltage drop with a DVM between the contacts indicated on the BOB prepared for CB312200 P06/J06. | <table border="1"> <thead> <tr> <th data-bbox="1108 943 1384 979">Contact A</th> <th data-bbox="1384 943 1570 979">Contact B</th> <th data-bbox="1570 943 1794 979">Voltage Drop</th> </tr> </thead> <tbody> <tr><td data-bbox="1108 979 1384 1016">92</td><td data-bbox="1384 979 1570 1016">31</td><td data-bbox="1570 979 1794 1016"></td></tr> <tr><td data-bbox="1108 1016 1384 1053">91</td><td data-bbox="1384 1016 1570 1053">43</td><td data-bbox="1570 1016 1794 1053"></td></tr> <tr><td data-bbox="1108 1053 1384 1090">103</td><td data-bbox="1384 1053 1570 1090">42</td><td data-bbox="1570 1053 1794 1090"></td></tr> <tr><td data-bbox="1108 1090 1384 1126">113</td><td data-bbox="1384 1090 1570 1126">54</td><td data-bbox="1570 1090 1794 1126"></td></tr> <tr><td data-bbox="1108 1126 1384 1163">68</td><td data-bbox="1384 1126 1570 1163">19</td><td data-bbox="1570 1126 1794 1163"></td></tr> <tr><td data-bbox="1108 1163 1384 1200">57</td><td data-bbox="1384 1163 1570 1200">29</td><td data-bbox="1570 1163 1794 1200"></td></tr> <tr><td data-bbox="1108 1200 1384 1236">70</td><td data-bbox="1384 1200 1570 1236">53</td><td data-bbox="1570 1200 1794 1236"></td></tr> <tr><td data-bbox="1108 1236 1384 1273">81</td><td data-bbox="1384 1236 1570 1273">52</td><td data-bbox="1570 1236 1794 1273"></td></tr> </tbody> </table> | Contact A | Contact B | Voltage Drop | 92 | 31 | | 91 | 43 | | 103 | 42 | | 113 | 54 | | 68 | 19 | | 57 | 29 | | 70 | 53 | | 81 | 52 | | |
| Contact A | Contact B | Voltage Drop | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 92 | 31 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 91 | 43 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 103 | 42 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 113 | 54 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 68 | 19 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 57 | 29 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 70 | 53 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 81 | 52 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| 167 | Execute Procedure: SPIRE-FM-SFT-SPEC-JFET-ON-02 | SPECJFETSTAT: SSWJFET1V: SSWJFET2V: SLWJFET1V: | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|-----------|---|---|-----------|-----------|--------------|----|----|----|----|-----|--|-----|----|----|-----|----|--|----|----|----|----|----|--|----|----|--|----|----|--|--|--|--|
| 168 | Measure the voltage drop with a DVM across the inline resistors in the BOB prepared for CB312200 P06/J06. The expected values should lie between 25 and 50mV for contacts 91, 92, 103 and 113 and between 55 and 100mV for contacts 57, 68, 70 and 81 | <table border="1"> <thead> <tr> <th data-bbox="1093 528 1451 564">Function</th> <th data-bbox="1451 528 1794 564">Voltage drop</th> </tr> </thead> <tbody> <tr><td data-bbox="1093 564 1451 601">92</td><td data-bbox="1451 564 1794 601"></td></tr> <tr><td data-bbox="1093 601 1451 638">91</td><td data-bbox="1451 601 1794 638"></td></tr> <tr><td data-bbox="1093 638 1451 675">103</td><td data-bbox="1451 638 1794 675"></td></tr> <tr><td data-bbox="1093 675 1451 711">113</td><td data-bbox="1451 675 1794 711"></td></tr> <tr><td data-bbox="1093 711 1451 748">68</td><td data-bbox="1451 711 1794 748"></td></tr> <tr><td data-bbox="1093 748 1451 785">57</td><td data-bbox="1451 748 1794 785"></td></tr> <tr><td data-bbox="1093 785 1451 821">70</td><td data-bbox="1451 785 1794 821"></td></tr> <tr><td data-bbox="1093 821 1451 858">81</td><td data-bbox="1451 821 1794 858"></td></tr> </tbody> </table> | | Function | Voltage drop | 92 | | 91 | | 103 | | 113 | | 68 | | 57 | | 70 | | 81 | | | | | | | | | | | | |
| Function | Voltage drop | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 92 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 91 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 103 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 113 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 68 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 57 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 70 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 81 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 169 | Measure the voltage drop with a DVM between the contacts indicated on the BOB prepared for CB312200 P06/J06. | <table border="1"> <thead> <tr> <th data-bbox="1093 943 1384 979">Contact A</th> <th data-bbox="1384 943 1563 979">Contact B</th> <th data-bbox="1563 943 1794 979">Voltage Drop</th> </tr> </thead> <tbody> <tr><td data-bbox="1093 979 1384 1016">92</td><td data-bbox="1384 979 1563 1016">31</td><td data-bbox="1563 979 1794 1016"></td></tr> <tr><td data-bbox="1093 1016 1384 1053">91</td><td data-bbox="1384 1016 1563 1053">43</td><td data-bbox="1563 1016 1794 1053"></td></tr> <tr><td data-bbox="1093 1053 1384 1090">103</td><td data-bbox="1384 1053 1563 1090">42</td><td data-bbox="1563 1053 1794 1090"></td></tr> <tr><td data-bbox="1093 1090 1384 1126">113</td><td data-bbox="1384 1090 1563 1126">54</td><td data-bbox="1563 1090 1794 1126"></td></tr> <tr><td data-bbox="1093 1126 1384 1163">68</td><td data-bbox="1384 1126 1563 1163">19</td><td data-bbox="1563 1126 1794 1163"></td></tr> <tr><td data-bbox="1093 1163 1384 1200">57</td><td data-bbox="1384 1163 1563 1200">29</td><td data-bbox="1563 1163 1794 1200"></td></tr> <tr><td data-bbox="1093 1200 1384 1236">70</td><td data-bbox="1384 1200 1563 1236">53</td><td data-bbox="1563 1200 1794 1236"></td></tr> <tr><td data-bbox="1093 1236 1384 1273">81</td><td data-bbox="1384 1236 1563 1273">52</td><td data-bbox="1563 1236 1794 1273"></td></tr> </tbody> </table> | Contact A | Contact B | Voltage Drop | 92 | 31 | | 91 | 43 | | 103 | 42 | | 113 | 54 | | 68 | 19 | | 57 | 29 | | 70 | 53 | | 81 | 52 | | | | |
| Contact A | Contact B | Voltage Drop | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 92 | 31 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 91 | 43 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 103 | 42 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 113 | 54 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 68 | 19 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 57 | 29 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 70 | 53 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 81 | 52 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| | | | |
|-----|--|---|--|
| 170 | Execute Procedure: SPIRE-FM-SFT-SPEC-JFET-OFF | SPECJFETSTAT: SSWJFET1V: SSWJFET2V: SLWJFET1V: | |
| 171 | Execute Procedure: SPIRE-FM-SFT-SLIA-OFF-P | SLIABITSTAT SLIAP5V SLIAP9V SLIAM9V | |
| 172 | Execute Procedure SPIRE-FM-SFT-MCU-OFF-P | MCUBITSTAT | |
| 173 | Execute Procedure SPIRE-FM-SFT-SCU-OFF-P | SCUTEMPSTAT SUBKSTAT | |
| 174 | Execute SPIRE-FM-SFT-DRCU-OFF-P | THSK: TM2N: | |
| 175 | Execute | | |
| 176 | Carry out near real time analysis of the data to verify that: 0% < (Idd-Iss) / Idd < 8% | | |
| | Final Spectrometer Connection | | |
| 177 | Demate the 128-way BOB from CB 312200 P06 | | |
| 178 | Demate the 128-way BOB from CB 312200 J06 | | |
| 179 | Mate CB 312200 J06/P06 | | |
| 180 | Final Photometer Connection | | |
| 181 | Demate the 128-way BOB from CB 312100 P04 | | |
| 182 | Demate the 128-way BOB from CB 312100 J04 | | |
| 183 | Mate CB 312100 J04/P04 | | |
| 184 | End of procedure | | |

8 De-mating of SIH-IS and SIH-SS for LPU Integration

8.1 Prerequisites

1. The pre-requisites outlined in chapter 4.1 of this procedure have been completed.

8.2 End State

The SIH is disconnected at the SVM-CB.

The FPU is protected from ESD damage by the safeing plugs on SVM-CB connectors.

The SPIRE SVM panel has been opened.

8.3 Notes

1. SPIRE is ESD sensitive. Handling of these units is to be carried out by personnel suitably trained and equipped. Prior to carrying out the mating operations detailed below, the Pxx and Jxx connectors are to put in an ionized air stream continuously to discharge the harness.

| Step- No. | Integration-Step-Description | Results/Remarks | Sign Off |
|--------------|--|-----------------|----------|
| 1 | De-mating of SIH-IS and SIH-SS | | |
| | SIH-SH-03 | | |
| | Demate 312100 P04 | | |
| | Mate SPIRE Safeing Plug Type-V to SVM-CB 312100 J04 | | |
| | Cover 312100 P04 with ESD dust cover | | |
| | SIH-SH-01 | | |
| | Demate 312200 P06 | | |
| | Mate SPIRE Safeing Plug Type-VI to SVM-CB 312200 J06 | | |

| | | | |
|--|--|--|--|
| | Cover 312200 P06 with ESD dust cover | | |
| | SIH-SH-11 | | |
| | Demate 312300 P04 | | |
| | Mate SPIRE Safeing Plug Type-VIII to SVM-CB 312300 J04 | | |
| | Cover 312300 P04 with ESD dust cover | | |
| | Demate 312300 P01 | | |
| | Cover 312300 P01 with ESD dust cover | | |
| | SIH-SH-13 | | |
| | Demate 312300 P03 | | |
| | Mate SPIRE Safeing Plug Type-VIII to SVM-CB 312300 J03 | | |
| | Cover 312300 P03 with ESD dust cover | | |
| | Demate 312300 P02 | | |
| | Cover 312300 P02 with ESD dust cover | | |
| | SIH-SH-02 | | |
| | Demate 312200 P05 | | |
| | Mate SPIRE Safeing Plug Type-VII to SVM-CB 312200 J05 | | |
| | Cover 312200 P05 with ESD dust cover | | |
| | Demate 312100 P01A | | |
| | Cover 312100 P01A with ESD dust cover | | |
| | SIH-SH-04 | | |

| | | | |
|--|---|--|--|
| | Demate 312100 P01B | | |
| | Cover 312100 P01B with ESD dust cover | | |
| | Demate 312100 P03 | | |
| | Mate SPIRE Safeing Plug Type-VII to SVM-CB 312100 J03 | | |
| | Cover 312100 P03 with ESD dust cover | | |
| | SIH-SH-05 | | |
| | Demate 312100 P02 | | |
| | Mate SPIRE Safeing Plug Type-VII to SVM-CB 312100 J02 | | |
| | Cover 312100 P02 with ESD dust cover | | |
| | SIH-SH-06 | | |
| | Demate 3121200 P03 | | |
| | Mate SPIRE Safeing Plug Type-VII to SVM-CB 312200 J03 | | |
| | Cover 312200 P03 with ESD dust cover | | |
| | SIH-SH-07 | | |
| | Demate 3121200 P04 | | |
| | Mate SPIRE Safeing Plug Type-VII to SVM-CB 312200 J04 | | |
| | Cover 312200 P04 with ESD dust cover | | |
| | SIH-SH-08 | | |
| | Demate 3121200 P01 | | |
| | Mate SPIRE Safeing Plug Type-VII to SVM-CB 312200 J01 | | |

| | | | |
|--|---|--|--|
| | Cover 312200 P01 with ESD dust cover | | |
| | SIH-SH-09 | | |
| | Demate 3121200 P02 | | |
| | Mate SPIRE Safeing Plug Type-VII to SVM-CB 312200 J02 | | |
| | Cover 312200 P02 with ESD dust cover | | |
| | SIH-SH-10 | | |
| | Demate 3121300 P06 | | |
| | Mate SPIRE Safeing Plug Type-VII to SVM-CB 312300 J06 | | |
| | Cover 312300 P06 with ESD dust cover | | |
| | SIH-SH-12 | | |
| | Demate 3121300 P05 | | |
| | Mate SPIRE Safeing Plug Type-VII to SVM-CB 312300 J05 | | |
| | Cover 312300 P05 with ESD dust cover | | |
| | End of procedure | | |

9 Step by Step Procedure for Mating of SIH-IS and SIH-SS after LPU Integration

9.1 Prerequisites

- ✓1. The DCU, FCU and DPU have been mechanically and electrically integrated to the SVM panel and the SIH-SS-XX harnesses are all integrated but not mated to the SVM-CB.
- ✓2. The SIH-CS harnesses are still mated to the SPIRE FPU + JFP/JFS.
- ✓3. The SPIRE SVM panel has been closed.
- ✓4. The PLM has been mechanically integrated to the SVM
- ✓5. The SIH-IS-XX harnesses (XX= 1...13) are mechanically integrated onto the outside of the cryostat.
 - a. They are mated at the CVV internal FTHR connectors.
 - b. They are mated at the CVV-CB.
 - c. They are mechanically integrated to the SVM-I/F-CB's with the designated ESD safeing plugs and the UFT has been successfully completed.
- ✓6. The LPU Integration has been successfully completed.

9.2 Notes

1. SPIRE is ESD sensitive. Handling of these units is to be carried out by personnel suitably trained and equipped. Prior to carrying out the mating operations detailed below, the Pxx and Jxx connectors are to put in an ionized air stream for > 30 sec to discharge the harness.

| No: | Activity | Remarks/Results | Sign off |
|-----|---------------------------------------|-----------------|----------|
| | Mating of SIH-SS to SIH-IS | 22.10.07 | |
| 1 | SIH-SS-12 | | |
| 2 | Remove ESD dust cover from 312300 P05 | | ✓ |



Test Procedure

Herschel

| No: | Activity | Remarks/Results | Sign off |
|-----|--|-----------------|----------|
| 3 | Demate SPIRE Safeing Plug Type-VII from SVM-CB 312300 J05 | | ✓ |
| 4 | Mate 312300 J05 to P05 | | ✓ |
| 5 | SIH-SS-10 | | |
| 6 | Remove ESD dust cover from 312/300 P06 | | ✓ |
| 7 | Demate SPIRE Safeing Plug Type-VII from SVM-CB 312300 J06 | | ✓ |
| 8 | Mate 312300 J06 to P06 | | ✓ |
| 9 | SIH-SS-11 | | |
| 10 | Remove ESD dust cover from 312300 P04 | | ✓ |
| 11 | Demate SPIRE Safeing Plug Type-VIII from SVM-CB 312300 J04 | | ✓ |
| 12 | Mate 312300 P04 to J04 | | ✓ |
| 13 | Remove ESD dust cover from 312300 P01 | | ✓ |
| 14 | Mate 312300 P01 to J01 | | ✓ |

Doc. No: HP-2-ASED-TP-0166

Issue: 1

Date: 10.09.07

File: SPIRE PFM Final Electrical Integration Procedure HP-2-ASED-TP-0166 1.doc



Test Procedure

Herschel

| No: | Activity | Remarks/Results | Sign off |
|-----|--|-----------------|----------|
| 15 | SIH-SS-13 | | |
| 16 | Remove ESD dust cover from 312300 P03 | | ✓ |
| 17 | Demate SPIRE Safeing Plug Type-VIII from SVM-CB 312300 J03 | | ✓ |
| 18 | Mate 312300 P03 to J03 | | ✓ |
| 19 | Remove ESD dust cover from 312300 P02 | | ✓ |
| 20 | Mate 312300 P02 to J02 | | ✓ |
| 21 | SIH-SS-04 | | |
| 22 | Remove ESD dust cover from 312100 P01B | | ✓ |
| 23 | Mate 312100 P01B to J01B | | ✓ |
| 24 | Remove ESD dust cover from 312100 P03 | | ✓ |
| 25 | Demate SPIRE Safeing Plug Type-VII from SVM-CB 312100 J03 | | ✓ |
| 26 | Mate 312100 P03 to J03 | | ✓ |

| No: | Activity | Remarks/Results | Sign off |
|-----|---|-----------------|----------|
| 27 | SIH-SS-02 | | |
| 28 | Remove ESD dust cover from 312200 P05 | | ✓ |
| 29 | Demate SPIRE Safeing Plug Type-VII from SVM-CB 312200 J05 | | ✓ |
| 30 | Mate 312200 P05 to J05 | | ✓ |
| 31 | Remove ESD dust cover from 312100 P01A | | ✓ |
| 32 | Mate 312100 P01A to J01A | | ✓ |
| 33 | SIH-01 | | |
| 34 | Remove ESD dust cover from 312200 P06 | | ✓ |
| 35 | Demate SPIRE Safeing Plug Type-VI from SVM-CB 312200 J06 | | ✓ |
| 36 | Mate 312200 P06 to J06 | | ✓ |
| 37 | SIH-SS-05 | | |
| 38 | Remove ESD dust cover from 312100 P02 | | ✓ |

| No: | Activity | Remarks/Results | Sign off |
|-----|---|-----------------|----------|
| 39 | Demate SPIRE Safeing Plug Type-VII from SVM-CB 312100 J02 | | ✓ |
| 40 | Mate 312100 P02 to J02 | | ✓ |
| 41 | SIH-SS-06 | | |
| 42 | Remove ESD dust cover from 312/200 P03 | | ✓ |
| 43 | Demate SPIRE Safeing Plug Type-VII from SVM-CB 312200 J03 | | ✓ |
| 44 | Mate 312200 P03 to J03 | | ✓ |
| 45 | SIH-SS-07 | | |
| 46 | Remove ESD dust cover from 312/200 P04 | | ✓ |
| 47 | Demate SPIRE Safeing Plug Type-VII from SVM-CB 312200 J04 | | ✓ |
| 48 | Mate 312200 P04 to J04 | | ✓ |
| 49 | SIH-SS-08 | | |
| 50 | Remove ESD dust cover from 312/200 P01 | | ✓ |



Test Procedure

Herschel

| No: | Activity | Remarks/Results | Sign off |
|-----|---|-----------------|----------|
| 51 | Demate SPIRE Safeing Plug Type-VII from SVM-CB 312200 J01 | | ✓ |
| 52 | Mate 312200 P01 to J01 | | ✓ |
| 53 | SIH-SS-09 | | |
| 54 | Remove ESD dust cover from 312/200 P02 | | ✓ |
| 55 | Demate SPIRE Safeing Plug Type-VII from SVM-CB 312200 J02 | | ✓ |
| 56 | Mate 312200 P02 to J02 | | ✓ |
| 57 | SIH-SS-03 | | |
| 58 | Demate 312100 P04 | | ✓ |
| 59 | Mate SPIRE Safeing Plug Type-V to SVM-CB 312100 J04 | | ✓ |
| 60 | Mate 312100 P04 to J04 | | ✓ |
| 61 | End of procedure | | |

10 Summary Sheets

10.1 Procedure Variation Summary

Herein are all changes of the procedure are shown.

| No. | Para. | Variation Description | Action req. |
|-----|-------|---|-------------|
| 1 | 9 | para. 9 is the only procedure to be executed after LPU integration, all others are not applicable | none |

Table 10.1-1: Procedure Variation Sheet

10.2 Non Conformance Report (NCR) Summary

| NCR - No. | NCR - Title | Date | Open Closed | PA sig. |
|-----------|-------------|------|----------------|------------|
| | <i>none</i> | | | |

Table 10.2-1: Non-Conformance Record Sheet

10.3 Sign-off Sheet

This test has been successfully performed and all open issues are covered by NCR's or Procedure Variations.

| | Date | Signature |
|----------------|-----------------|-------------------|
| Test Manager | <i>22.10.07</i> | <i>A. Gagne</i> |
| Operator | <i>22.10.07</i> | <i>R. F. ...</i> |
| PA Responsible | <i>22.10.07</i> | <i>D. Balange</i> |

11 APPENDICES

11.1 Procedure SPIRE Power On

| Step | Description | Parameter | Expected Values Before/After | Actual Values Before/After | Pass/Fail |
|------|---|-----------|------------------------------|----------------------------|-----------|
| 1 | Execute TCL script S102999SCVT005_ASDFSFTSPIR_P WR_ON_P.tcl | --- | --- | --- | |

Note: This script powers up the instrument DPU and DRCU prime. Therefore, the next two procedures, 11.2 and 11.3, are not executed manually.

11.2 Procedure SPIRE-FM-SFT-DPU-ON-P

| | |
|------------------------------|---|
| Version | 2.3 |
| Date | 28 Aug 2007 |
| Purpose | To switch on the SPIRE DPU PRIME and start generating housekeeping |
| Initial configuration | SPIRE DPU and DRCU PRIME are switched off |
| Final configuration | SPIRE DPU PRIME is ON and SPIRE HK is being produced , SPIRE DRCU PRIME is OFF |
| Preconditions | <ul style="list-style-type: none"> • SPIRE FM DPU is electrically integrated with the Herschel Satellite • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • FUNCTIONAL TEST PARAMETERS display is selected on the CCS |
| Duration | 5 minutes |
| Pass/Fail Criteria | Nominal and critical HK reports start being generated at their nominal rates of 1Hz and 0.5Hz respectively. |

| Step | Description | Parameter | Expected Values Before/After | Actual Values Before/After | Pass/Fail |
|------|--|-----------|------------------------------|----------------------------|-----------|
| 1 | Select DPU AND OBS PARAMETERS display is on the CCS | --- | --- | --- | |
| 2 | Power ON the SPIRE DPU PRIME unit using the dedicated spacecraft LCL line and configure 1553 Spacecraft bus for SPIRE DPU PRIME (RT = 21) | --- | --- | --- | |
| 3 | Wait for the boot software to produce at least 2 event packets (5,1) | | | | |

| Step | Description | Parameter | Expected Values Before/After | Actual Values Before/After | Pass/Fail |
|---------------------------------|--|-----------|------------------------------|----------------------------|-----------|
| 4 | Execute TCL script SPIRE-FM-SFT-DPU-START-P-SP.tcl | --- | --- | --- | |
| 5 | Check that Nominal and Critical HK packets are arriving at the CCS: SPIRE Nominal HK: <ul style="list-style-type: none"> • (type ,subtype) : (3,25) • APID : 0x502 SPIRE Critical HK: <ul style="list-style-type: none"> • (type ,subtype) : (3,25) • APID: 0x500 | | | | |
| 6 | Check that THSK parameter is refreshing every second | THSK | Refreshing @ 1 Hz | --- | |
| 7 | Check that TM2N parameter is incrementing by 1 every second | TM2N | Incrementing by 1 @ 1Hz | --- | |
| 8 | Check that TM1N parameter is incrementing by 1 every 2 second | TM1N | Incrementing by 1 @ 0.5Hz | | |
| Test Result (Pass/Fail): | | | | | |

* Assuming that OBT is provided by the HCDMU is TAI, there should be a 33 second difference between OBS and CCS time (assuming CCS is using UTC). In the case the HCDMU is using UTC to specify the on board time, there should be no difference between THSK and the CCS/IEGSE system time.

11.3 Procedure SPIRE-FM-SFT-DRCU-ON-P

| | |
|------------------------------|--|
| Version | 2.3 |
| Date | 28 nd August 2007 |
| Purpose | To switch on the SPIRE DRCU PRIME and start generating housekeeping |
| Initial configuration | SPIRE DPU PRIME is ON and DRCU PRIME is switched OFF |
| Final configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced |
| Preconditions | <ul style="list-style-type: none"> • SPIRE FM DRCU is electrically integrated with the Herschel Satellite • SPIRE DRCU is switched OFF • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • FUNCTIONAL TEST PARAMETERS display is selected on the CCS |
| Duration | 4 minutes |
| Pass/Fail Criteria | DRCU voltages show expected 'ON' values |

| Step | Description | Parameter | Expected Values Before/After | Actual Values Before/After | Success/Failure |
|---------------------------------|--|---|--|----------------------------|-----------------|
| 1 | Execute TCL script SPIRE-FM-SFT-DRCU-START-P-STEP1.tcl | --- | --- | --- | |
| 2 | Check that THSK parameter is not refreshing anymore | THSK | Not refreshing | --- | |
| 3 | Check that TM2N parameter is not incrementing anymore | TM2N | Not incrementing | --- | |
| 4 | Power ON the SPIRE DRCU PRIME unit using the dedicated spacecraft LCL line. | --- | --- | --- | |
| 5 | Execute TCL script SPIRE-FM-SFT-DRCU-START-P-STEP2.tcl | --- | --- | --- | |
| 6 | Check that THSK parameter is again refreshing every second | THSK | Refreshing @ 1Hz | | |
| 7 | Check that TM2N parameter is again incrementing every second | TM2N | Incrementing by 1 @ 1Hz | --- | |
| 8 | Check that the SCU/DCU voltages show nominal values | SCUP5V SCUP9V SCUM9V BIASP5V BIASP9V BIASM9V | ~ 5.2 ± 0.5V ~ 9.0 ± 0.2V ~ -9.0 ± 0.2V ~ 5.1 ± 0.5V ~ 9.0 ± 0.2V ~ -9.0 ± 0.2V | --- | |
| Test Result (Pass/Fail): | | | | | |

11.4 Procedure SPIRE-FM-SFT-FUNC-SCU-01-P

| | |
|------------------------------|---|
| Version | 2.3 |
| Date | 28 nd August 2007 |
| Purpose | SCU science packet generation check |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced |
| Final configuration | Unchanged |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • SFT PARAMETERS display is selected on the CCS |
| Duration | 3 minutes |
| Pass/Fail Criteria | Specified SCU HK parameters show expected increment. |

Procedure Steps:

| Step | Description | Parameter | Expected Values Before/ After | Actual Values Before /After | Success/ Failure |
|---------------------------------|---|---------------------|-------------------------------|-----------------------------|------------------|
| 1 | Execute TCL script SPIRE-FM-SFT-FUNC-SCU-01-P.tcl | SCUFRAMECNT TM5N | 0/31 0x3FFF/1 | | |
| Test Result (Pass/Fail): | | | | | |

11.5 Procedure SPIRE-FM-SFT-FUNC-SCU-03-P

| | |
|------------------------------|---|
| Version | 2.3 |
| Date | 28 nd August 2007 |
| Purpose | SCU DC thermometry check |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced |
| Final configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and DC thermometry is ON |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • SFT PARAMETERS display is selected on the CCS |
| Duration | 8 minutes |
| Pass/Fail Criteria | DC Thermometry channels show temperature readings according to the actual instrument temperature* *: At warm temperatures all channels should show short circuit RAW readings of -32768 |

Procedure Steps:

| Step | Description | Parameter - Unit | Expected Values Before/ During/ After | Actual Values Before/ During/ After | Success/ Failure |
|------|---|---|---|-------------------------------------|------------------|
| 1 | Execute TCL script SPIRE-FM-SFT-FUNC-SCU-03-P.tcl | --- | --- | --- | --- |
| 2 | Wait for the parameter BBFULLTYPE to get set to SCU DC Therm | | | | |
| 3 | A few seconds later record the value of parameter SCUTEMPSTAT | SCUTEMPSTAT | 0/FFFF/FFFF | | |
| 4 | If the instrument is warm: Configure the SFT PARAMETERS display to show the RAW values of SCU DC thermometry channels. Record the RAW values of SCU DC thermometry | PUMPHTRTEMP PUMPHSTEMP EVAPHSTEMP SHUNTTEMP EMCFILTEMP SL0TEMP PL0TEMP OPTTEMP BAFTEMP BSMIFTEMP | - - - - - - - - - | | |

| Step | Description | Parameter - Unit | Expected Values Before/ During/ After | Actual Values Before/ During/ After | Success/ Failure |
|---------------------------------|---|---|--|--|---------------------|
| | channels. Nominal values should show a short circuit status (or RAW -32768). Non Nominal (Open Circuit Criterion): RAW reading in the range [0,-100] | SCAL2TEMP SCAL4TEMP SCALTEMP SMECIFTEMP SMECTEMP BSMTEMP | - - - - - - | | |
| Test Result (Pass/Fail): | | | | | |

11.6 Procedure SPIRE-FM-SFT-FUNC-SCU-06-P

| | |
|------------------------------|---|
| Version | 2.3 |
| Date | 28 th August 2007 |
| Purpose | SCU AC thermometry check |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and DC thermometry is ON |
| Final configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • SFT PARAMETERS display is selected on the CCS |
| Duration | 2 minutes |
| Pass/Fail Criteria | AC Thermometry channel shows temperature readings according to the actual instrument temperature |

Procedure Steps:

| Step | Description | Parameter - Unit | Expected Values Before/ During/ After | Actual Values Before/ During/ After | Success/ Failure |
|---------------------------------|--|------------------|---------------------------------------|-------------------------------------|------------------|
| 1 | Execute TCL script SPIRE-FM-SFT-FUNC-SCU-06-P.tcl | --- | --- | --- | --- |
| 2 | Wait for the parameter BBFULLTYPE to get set to SCU_AC Therm | | | | |
| 3 | A few seconds later record the value of parameter SUBKSTAT | SUBKSTAT | 0/1/1 | | |
| 4 | <p>If the instrument is warm:</p> <p>Configure the SFT PARAMETERS display to show the RAW values of SCU AC thermometry channel.</p> <p>Only record the values of SCU AC thermometry channel if it indicates an open circuit.</p> <p>Open Circuit Criterion: RAW reading in the range [0, -100]</p> | SUBKTEMP | --- | | |
| Test Result (Pass/Fail): | | | | | |

11.7 Procedure SPIRE-FM-SFT-FUNC-SCU-07-P

| | |
|------------------------------|---|
| Version | 2.2 |
| Date | 2 nd January 2007 |
| Purpose | Sorption Cooler Heater Check |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and DC thermometry is ON |
| Final configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • SFT PARAMETERS display is selected on the CCS |
| Duration | 5 minutes |
| Pass/Fail Criteria | Sorption cooler heat switches and pump heater show expected voltages |

Procedure Steps:

| Step | Description | Parameter - Unit | Expected Values Before/ During/ After | Actual Values Before/ During/ After | Success/ Failure |
|---------------------------------|---|------------------|---------------------------------------|-------------------------------------|------------------|
| 1 | Execute TCL script SPIRE-FM-SFT-FUNC-SCU-07-P.tcl | --- | --- | --- | --- |
| 2 | Wait for the parameter BBFULLTYPE to get set to Cooler_Htr_Chk | BBFULLTYPE | Cooler_Htr_Chk | | |
| 3 | Record the value of parameter SPHSV – the Sorption Pump Heat Switch Voltage. <i>This voltage stays on for ~20 seconds. Wait for the voltage to go to zero to continue.</i> | SPHSV - mV | 0/~323/0 | | |
| 4 | Record the value of parameter EVHSV – the Evaporator Heat Switch Voltage. <i>This voltage stays on for ~20 seconds. Wait for the voltage to go to zero to continue.</i> | EVHSV - mV | 0/~323/0 | | |
| 5 | Record the value of parameter SPHTRV – the Sorption Pump Heater Voltage. <i>This voltage stays on for ~20 seconds. Wait for the voltage to go to zero to continue.</i> | SPHTRV - V | 0/~8.8/0 | | |
| Test Result (Pass/Fail): | | | | | |

11.8 Procedure SPIRE-FM-SFT-FUNC-SCU-04-P

| | |
|------------------------------|---|
| Version | 2.3 |
| Date | 28 nd August 2007 |
| Purpose | Photometer Calibration Check (PRIME) |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON |
| Final configuration | Unchanged |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • SFT PARAMETERS display is selected on the CCS |
| Duration | 3 minutes |
| Pass/Fail Criteria | PCAL voltage and current agree with expected values |

Procedure Steps:

| Step | Description | Parameter Name - Unit | Expected Values Before/ During/ After | Actual Values Before/ During/ After | Success/ Failure |
|---------------------------------|--|--|--|-------------------------------------|------------------|
| 1 | Execute TCL script SPIRE-FM-SFT-FUNC-SCU-04-P.tcl The expected values during the test should be monitored when parameter BBFULLTYPE in the SFT PARAMETERS display is set to PCAL_Check. This usually happens about 30 seconds from the start of test execution. | PCALCURR - mA PCALV - V BBFULLTYPE | 0.0/0.1/0.0 0.0/0.026/0.0 PCAL_Check | | |
| Test Result (Pass/Fail): | | | | | |

11.9 Procedure SPIRE-FM-SFT-FUNC-SCU-05-P

| | |
|------------------------------|---|
| Version | 2.3 |
| Date | 28 th August 2007 |
| Purpose | Spectrometer Calibration Check (PRIME) |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON |
| Final configuration | Unchanged |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • SFT PARAMETERS display is selected on the CCS |
| Duration | 5 minutes |
| Pass/Fail criteria | SCAL2 and SCAL4 voltage and currents agree with expected values |

Procedure Steps:

| Step | Description | Parameter - Unit | Expected Values Before/ During/ After | Actual Values Before/ During/ After | Success/ Failure |
|---------------------------------|---|------------------------------|---------------------------------------|-------------------------------------|------------------|
| 1 | Execute TCL script SPIRE-FM-SFT-FUNC-SCU-05-P.tcl | --- | --- | --- | |
| 2 | Wait for the parameter BBFULLTYPE to get set to SCAL4 Check | BBFULLTYPE | SCAL4_Check | | |
| 3 | A few seconds later record the value of parameters SCAL4CURR and SCAL4V <i>These parameters are set back to 0 after ~20 seconds</i> | SCAL4CURR – mA SCAL4V – V | 0.0/0.10/0.0 0.0/0.05/0.0 | | |
| 4 | Wait for the parameter BBFULLTYPE to get set to SCAL2 Check | BBFULLTYPE | SCAL2_Check | | |
| 5 | A few seconds later record the values of parameters SCAL2CURR and SCAL2V <i>These parameters are set back to 0 after ~20 seconds</i> | SCAL2CURR – mA SCAL2V – V | 0.0/0.10/0.0 0.0/0.05/0.0 | | |
| Test Result (Pass/Fail): | | | | | |

11.10 Procedure SPIRE-FM-SFT-FUNC-MCU-01-P

| | |
|------------------------------|---|
| Version | 2.3 |
| Date | 28 th August 2007 |
| Purpose | MCU (PRIME) Boot Check |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON |
| Final configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON and MCU PRIME is booted. |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • SFT PARAMETERS display is selected on the CCS |
| Duration | 5 minutes |
| Pass/Fail criteria | MCU voltages and board temperatures show expected 'ON' values |

| Step | Description | Parameter - Unit | Expected Values Before/ During/ After | Actual Values Before/ During/ After | Success/ Failure |
|---------------------------------|--|---|---|-------------------------------------|------------------|
| 1 | Execute TCL script SPIRE-FM-SFT-FUNC-MCU-01-P.tcl | --- | --- | --- | --- |
| 2 | Check that the MCU is booted up successfully. | MCUBITSTAT | 0/1/1 | | |
| 3 | Check MCU HK parameter values and ensure that the values are refreshing. | MCUP5V MCUP14V MCUM14V MCUP15V MCUM15V MCUMACTEMP MCUSMECTEMP MCUBSMTEMP | ~ 5.0 ± 0.2V ~ 14.0 ± 0.5V ~ -14.0 ± 0.5V ~ 15.0 ± 0.5V ~ -15.0 ± 0.7V ~300K ~300K ~300K | | |
| Test Result (Pass/Fail): | | | | | |

11.11 Procedure: SPIRE-FM-SFT-FUNC-MCU-02-P

| | |
|------------------------------|---|
| Version | 2.2 |
| Date | 2 nd January 2007 |
| Purpose | MCU Nominal Frame Generation Check |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON and MCU PRIME is booted. |
| Final configuration | Unchanged. |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • SFT PARAMETERS display is selected on the CCS |
| Duration | 5 minutes |
| Pass/Fail criteria | Specified MCU HK parameters show expected increment |

Procedure Steps:

| Step | Description | Parameter - Unit | Expected Values Before/ During/ After | Actual Values Before/ During/ After | Success/ Failure |
|---------------------------------|---|------------------|---------------------------------------|-------------------------------------|------------------|
| 1 | Execute TCL script SPIRE-FM-SFT-FUNC-MCU-02-P.tcl | MCUFRAMECNT | FM : 0/297 | --- | --- |
| Test Result (Pass/Fail): | | | | | |

11.12 Procedure SPIRE-FM-SFT-FUNC-BSM-01-P

| | |
|------------------------------|---|
| Version | 2.3 |
| Date | 28 th August 2007 |
| Purpose | BSM (PRIME) Chop/Jiggle Sensor Check. |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON and MCU PRIME is booted. |
| Final configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON and MCU PRIME is booted. BSM Chop/Jiggle sensors are ON. |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • SPIRE MCU PRIME is booted. • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • SFT PARAMETERS display is selected on the CCS |
| Duration | 3 minutes |
| Pass/Fail criteria | HK Parameters CHOPSENSPWR and JIGGSENSPWR show expected ON values. |

Procedure Steps:

| Step | Description | Parameter - Unit | Expected Values Before/ During/ After | Actual Values Before/ During/ After | Success/ Failure |
|---------------------------------|---|----------------------------|---------------------------------------|-------------------------------------|------------------|
| 1 | Execute TCL script SPIRE-FM-SFT-FUNC-BSM-01-P.tcl | --- | --- | --- | --- |
| 2 | Check that the Chop and Jiggle sensors have switched on | CHOPSENSPWR JIGGSENSPWR | 0/1/1 0/1/1 | | |
| Test Result (Pass/Fail): | | | | | |

11.13 Procedure SPIRE-FM-SFT-BSM-OFF-P

| | |
|------------------------------|---|
| Version | 2.3 |
| Date | 28 nd August 2007 |
| Purpose | BSM (PRIME) Switch OFF |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON and MCU PRIME is booted. BSM Chop/Jiggle sensors are ON. |
| Final configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON and MCU PRIME is booted. BSM Chop/Jiggle sensors are OFF. |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • SPIRE MCU PRIME is booted. • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • SFT PARAMETERS display is selected on the CCS |
| Duration | 3 minutes |
| Pass/Fail criteria | HK Parameters CHOPSENSPWR and JIGGSENSPWR show expected OFF values. |

Procedure Steps:

| Step | Description | Parameter – Unit | Expected Values Before/ During/ After | Actual Values Before/ During/ After | Success/ Failure |
|---------------------------------|---|----------------------------|---------------------------------------|-------------------------------------|------------------|
| 1 | Execute SPIRE-FM-SFT-BSM-OFF-P.tcl | — | — | — | — |
| 2 | Check that the power to the BSM sensors is switched off | CHOPSENSPWR JIGGSENSPWR | 1/-/0 1/-/0 | | |
| Test Result (Pass/Fail): | | | | | |

11.14 Procedure SPIRE-FM-SFT-FUNC-SMEC-01-P

| | |
|------------------------------|---|
| Version | 2.3 |
| Date | 28 th August 2007 |
| Purpose | SMEC (PRIME) Encoder/LVDT Sensor Check. |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON and MCU PRIME is booted. |
| Final configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON and MCU PRIME is booted. SMEC Encoder and LVDT are ON. |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • SPIRE MCU PRIME is booted. • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • SFT PARAMETERS display is selected on the CCS |
| Duration | 3 minutes |
| Pass/Fail criteria | HK Parameters SMECENCPWR and SMECLVDTPWR show expected ON values. |

Procedure Steps:

| Step | Description | Parameter – Unit | Expected Values Before/ During/ After | Actual Values Before/ During/ After | Success/ Failure |
|---------------------------------|--|------------------|---------------------------------------|-------------------------------------|------------------|
| 1 | Execute TCL script SPIRE-FM-SFT-FUNC-SMEC-01-P.tcl | --- | --- | --- | --- |
| 2 | Check that power to the SMEC LED and LVDT sensor is on | SMECENCPWR | 0/-/1 | | |
| | | SMECLVDTPWR | 0/1/1 | | |
| Test Result (Pass/Fail): | | | | | |

11.15 Procedure SPIRE-FM-SFT-SMEC-OFF-P

| | |
|------------------------------|---|
| Version | 2.3 |
| Date | 28 th August 2007 |
| Purpose | SMEC (PRIME) Switch OFF |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON and MCU PRIME is booted. SMEC Encoder and LVDT are ON. |
| Final configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON and MCU PRIME is booted. SMEC Encoder and LVDT are OFF. |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • SPIRE MCU PRIME is booted. • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • SFT PARAMETERS display is selected on the CCS |
| Duration | 3 minutes |
| Pass/Fail criteria | HK Parameters SMECENCPWR and SMECLVDPWR show expected OFF values. |

Procedure Steps:

| Step | Description | Parameter – Unit | Expected Values Before/ During/ After | Actual Values Before/ During/ After | Success/ Failure |
|------|--|--------------------------|---------------------------------------|-------------------------------------|------------------|
| 1 | Execute SPIRE-FM-SFT-SMEC-OFF-P.tcl | --- | --- | --- | --- |
| 2 | Check that the power to the SMEC sensors is switched off | SMECENCPWR SMECLVDPWR | 1/-0 1/-0 | | |

Test Result (Pass/Fail):

11.16 Procedure SPIRE-FM-SFT-FUNC-DCU-01-P

| | |
|------------------------------|---|
| Version | 2.2 |
| Date | 2 nd January 2007 |
| Purpose | DCU science packet generation check for all Photometer and Spectrometer packet types (PF, PSW, PMW, PLW, SF, SSW and SLW) |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON and MCU PRIME is booted. |
| Final configuration | Unchanged |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • SFT PARAMETERS display is selected on the CCS |
| Duration | 5 minutes |
| Pass/Fail criteria | Specified DCU HK parameter shows expected increment |

Procedure Steps:

| Step | Description | Parameter | Expected Values Before/ After | Actual Values Before /After | Success/ Failure |
|---------------------------------|---|-------------|-------------------------------|-----------------------------|------------------|
| 1 | Execute TCL script SPIRE-FM-SFT-FUNC-DCU-01-P.tcl | DCUFRAMECNT | 0/700 | | |
| Test Result (Pass/Fail): | | | | | |

11.17 Procedure: SPIRE-FM-SFT-FUNC-DCU-04-PHOT-P

| | |
|------------------------------|---|
| Version | 2.4 |
| Date | 10 th September 2007 |
| Purpose | Photometer LIAs PRIME Check |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON and MCU PRIME is booted. |
| Final configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON and MCU PRIME is booted. Photometer LIAs are ON |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • Photometer LIAs are OFF • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • DCU PARAMETERS & SFT PARAMETERS displays are selected on the CCS |
| Duration | 5 minutes |
| Pass/Fail criteria | Specified Photometer LIA HK parameters show expected ON values |

| Step | Description | Parameter | Expected Values Before/ After | Actual Values Before /After | Success/ Failure |
|---------------------------------|--|-------------------------------|--|-----------------------------|------------------|
| 1 | Execute TCL script SPIRE-FM-SFT-FUNC-DCU-04-PHOT-P.tcl | PLIABITSTAT | 0/1/1 | | |
| 2 | Check Photometer LIA HK parameter values and ensure that the values are refreshing | PLIAP5V PLIAP9V PLIAM9V | 0.0/-/ 5.2 ± 0.2V 0.0/-/ 11.5 ± 0.5V 0.0/-/11.5 ± 0.5V | | |
| 3 | On the DCU PARAMETERS display check that the LIA temperatures are slowly warming up. At switch-on it is possible that some of the LIA temperatures will be in soft or even hard limits. No action is required. | LIAP1TEMP to LIAP9TEMP | ~ 290-300 K | | |
| 4 | Wait for ~3 minutes before continuing with the SFTs | — | — | — | — |
| Test Result (Pass/Fail): | | | | | |

11.18 Procedure: SPIRE-FM-SFT-PHOT-JFET-ON-01

| | |
|------------------------------|---|
| Version | 1.1 |
| Date | 10 th September 2007 |
| Purpose | Photometer JFETs Switch On |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced AC/DC thermometry is ON MCU PRIME is booted Photometer LIAs are ON |
| Final configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced AC/DC thermometry is ON MCU PRIME is booted Photometer LIAs are ON Photometer JFETs are ON |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • DCU PARAMETERS display is selected on the CCS |
| Duration | 5 minutes |
| Pass/Fail criteria | Photometer JFET HK parameters show expected ON values |

| Step | Description | Parameter | Expected Values Before/ After | Actual Values Before /After | Success/ Failure |
|------|---|-----------|-------------------------------|-----------------------------|------------------|
| 1 | Execute TCL script SPIRE-FM-SFT-PHOT-JFET-ON-01.tcl Wait for the script to finish executing before proceeding with the next step | --- | --- | --- | --- |

| Step | Description | Parameter | Expected Values Before/After | Actual Values Before/After | Success/Failure |
|---------------------------------|---|--|---|----------------------------|-----------------|
| 2 | <p>On the DCU PARAMETERS display check the JFET HK parameters</p> <p>Check with Instrument Team before proceeding with the next test.</p> | PSWJFETSTAT PMLWJFETSTAT PSWJFET1V PSWJFET2V PSWJFET3V PSWJFET4V PSWJFET5V PSWJFET6V PMWJFET1V PMWJFET2V PMWJFET3V PMWJFET4V PLWJFET1V PLWJFET2V TCJFETV | 0x3F 0x7F -1.49 ± 0.1 V -1.49 ± 0.1 V -1.49 ± 0.1 V -1.49 ± 0.1 V -1.49 ± 0.1 V -1.49 ± 0.1 V -1.49 ± 0.1 V -1.49 ± 0.1 V -1.49 ± 0.1 V -1.49 ± 0.1 V -1.49 ± 0.1 V -1.49 ± 0.1 V -1.49 ± 0.1 V | | |
| Test Result (Pass/Fail): | | | | | |

11.19 Procedure: SPIRE-FM-SFT-PHOT-JFET-ON-02

| | |
|------------------------------|---|
| Version | 1.1 |
| Date | 10 th September 2007 |
| Purpose | Photometer JFETs Switch On |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced AC/DC thermometry is ON MCU PRIME is booted Photometer LIAs are ON |
| Final configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced AC/DC thermometry is ON MCU PRIME is booted Photometer LIAs are ON Photometer JFETs are ON |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • DCU PARAMETERS display is selected on the CCS |
| Duration | 5 minutes |
| Pass/Fail criteria | Photometer JFET HK parameters show expected ON values |

| Step | Description | Parameter | Expected Values Before/ After | Actual Values Before /After | Success/ Failure |
|------|---|-----------|-------------------------------|-----------------------------|------------------|
| 1 | Execute TCL script SPIRE-FM-SFT-PHOT-JFET-ON-02.tcl Wait for the script to finish executing before proceeding with the next step | --- | --- | --- | --- |

| Step | Description | Parameter | Expected Values Before/ After | Actual Values Before /After | Success/ Failure |
|---------------------------------|---|--|--|-----------------------------|------------------|
| 2 | <p>On the DCU PARAMETERS display check the JFET HK parameters</p> <p>Check with Instrument Team before proceeding with the next test.</p> | PSWJFETSTAT PMLWJFETSTAT PSWJFET1V PSWJFET2V PSWJFET3V PSWJFET4V PSWJFET5V PSWJFET6V PMWJFET1V PMWJFET2V PMWJFET3V PMWJFET4V PLWJFET1V PLWJFET2V TCJFETV | 0x3F 0x7F -1.68 ± 0.02 V -1.59 ± 0.02 V -1.59 ± 0.02 V -1.68 ± 0.02 V -1.78 ± 0.02 V -1.68 ± 0.02 V -1.68 ± 0.02 V -1.88 ± 0.02 V -1.59 ± 0.02 V -1.88 ± 0.02 V -1.78 ± 0.02 V -1.59 ± 0.02 V -1.49 ± 0.02 V | | |
| Test Result (Pass/Fail): | | | | | |

11.20 Procedure: SPIRE-FM-SFT-PHOT-JFET-OFF

| | |
|------------------------------|---|
| Version | 1.0 |
| Date | 29 th August 2007 |
| Purpose | Photometer JFETs Switch Off |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced AC/DC thermometry is ON MCU PRIME is booted Photometer LIAs are ON Photometer JFETs are ON |
| Final configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced AC/DC thermometry is ON MCU PRIME is booted Photometer LIAs are ON Photometer JFETs are OFF |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • DCU PARAMETERS display is selected on the CCS |
| Duration | 5 minutes |
| Pass/Fail criteria | Photometer JFET HK parameters show expected OFF values |

| Step | Description | Parameter | Expected Values Before/ After | Actual Values Before /After | Success/ Failure |
|------|---|-----------|-------------------------------|-----------------------------|------------------|
| 1 | Execute TCL script SPIRE-FM-SFT-PHOT-JFET-OFF.tcl Wait for the script to finish executing before proceeding with the next step | --- | --- | --- | --- |

| Step | Description | Parameter | Expected Values Before/ After | Actual Values Before /After | Success/ Failure |
|--------------------------|--|--|--|-----------------------------|------------------|
| 2 | On the DCU PARAMETERS display check the JFET HK parameters | PSWJFETSTAT PMLWJFETSTAT | 0 0 | | |
| | | PSWJFET1V PSWJFET2V PSWJFET3V PSWJFET4V PSWJFET5V PSWJFET6V | 0.0 V 0.0 V 0.0 V 0.0 V 0.0 V 0.0 V | | |
| | | PMWJFET1V PMWJFET2V PMWJFET3V PMWJFET4V | 0.0 V 0.0 V 0.0 V 0.0 V | | |
| | | PLWJFET1V PLWJFET2V | 0.0 V 0.0 V | | |
| | | TCJFETV | 0.0 V | | |
| | Check with Instrument Team before proceeding with the next test. | | | | |
| Test Result (Pass/Fail): | | | | | |

11.21 Procedure: SPIRE-FM-SFT-PLIA-OFF-P

| | |
|------------------------------|---|
| Version | 2.4 |
| Date | 10 th September 2007 |
| Purpose | Photometer LIAs PRIME Switch OFF |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON and MCU PRIME is booted. Photometer LIAs are ON |
| Final configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON and MCU PRIME is booted. Photometer LIAs are OFF |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • Photometer LIAs are ON • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • SFT PARAMETERS display is selected on the CCS |
| Duration | 2 minutes |
| Pass/Fail criteria | Specified Photometer LIA HK parameters show expected OFF values |

| Step | Description | Parameter | Expected Values Before/ After | Actual Values Before /After | Success/ Failure |
|---------------------------------|--|-------------------------------|--|-----------------------------|------------------|
| 1 | Execute TCL script SPIRE-FM-SFT-PLIA-OFF-P.tcl | PLIABITSTAT | 1/-0 | | |
| 2 | Check Photometer LIA HK parameter values | PLIAP5V PLIAP9V PLIAM9V | 5.2 ± 0.2V/-0.0 11.5 ± 0.5V/-0.0 -11.5 ± 0.5V/-0.0 | | |
| Test Result (Pass/Fail): | | | | | |

11.22 Procedure: SPIRE-FM-SFT-FUNC-DCU-04-SPEC-P

| | |
|-----------------------|---|
| Version | 2.4 |
| Date | 10 th September 2007 |
| Purpose | Spectrometer LIAs PRIME Check |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON and MCU PRIME is booted. |
| Final configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON and MCU PRIME is booted. Spectrometer LIAs are ON |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • Spectrometer LIAs are OFF • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • SFT PARAMETERS & DCU PARAMETERS displays are selected on the CCS |
| Duration | 5 minutes |
| Pass/Fail criteria | Specified Spectrometer LIA HK parameters show expected ON values |

Procedure Steps for FM:

| Step | Description | Parameter | Expected Values Before/ After | Actual Values Before /After | Success/ Failure |
|---------------------------------|---|-------------------------------|--|-----------------------------|------------------|
| 1 | Execute TCL script SPIRE-FM-SFT-FUNC-DCU-04-SPEC-P.tcl | SLIABITSTAT | 0/1/1 | | |
| 2 | Check Spectrometer LIA HK parameter values and ensure that the values are refreshing | SLIAP5V SLIAP9V SLIAM9V | 0.0/-/ 5.2 ± 0.2V 0.0/-/ 11.5 ± 0.5V 0.0/-/ -11.5 ± 0.5V | | |
| 3 | On the DCU PARAMETERS display check that the LIA temperatures are slowly warming up. At switch-on it is possible that some of the LIA temperatures will be in soft or even hard limits. No action is required. | LIAS1TEMP to LIAS3TEMP | ~ 290-300 K | | |
| 4 | Wait for ~3 minutes before continuing with the SFTs | — | — | — | — |
| Test Result (Pass/Fail): | | | | | |

11.23 Procedure: SPIRE-FM-SFT-SPEC-JFET-ON-01

| | |
|------------------------------|---|
| Version | 1.1 |
| Date | 10 th September 2007 |
| Purpose | Spectrometer JFETs Switch On |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced AC/DC thermometry is ON MCU PRIME is booted Spectrometer LIAs are ON |
| Final configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced AC/DC thermometry is ON MCU PRIME is booted Spectrometer LIAs are ON Spectrometer JFETs are ON |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • DCU PARAMETERS display is selected on the CCS |
| Duration | 5 minutes |
| Pass/Fail criteria | Spectrometer JFET HK parameters show expected ON values |

| Step | Description | Parameter | Expected Values Before/ After | Actual Values Before /After | Success/ Failure |
|---------------------------------|---|---|--|-----------------------------|------------------|
| 1 | Execute TCL script SPIRE-FM-SFT-SPEC-JFET-ON-01.tcl Wait for the script to finish executing before proceeding with the next step | --- | --- | --- | --- |
| 2 | On the DCU PARAMETERS display check the JFET HK parameters Check with Instrument Team before proceeding with the next test. | SPECJFETSTAT SSWJFET1V SSWJFET2V SLWJFET1V | 7 -1.49 ± 0.1 V -1.49 ± 0.1 V -1.49 ± 0.1 V | | |
| Test Result (Pass/Fail): | | | | | |

11.24 Procedure: SPIRE-FM-SFT-SPEC-JFET-ON-02

| | |
|------------------------------|---|
| Version | 1.1 |
| Date | 10 th September 2007 |
| Purpose | Spectrometer JFETs Switch On |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced AC/DC thermometry is ON MCU PRIME is booted Spectrometer LIAs are ON |
| Final configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced AC/DC thermometry is ON MCU PRIME is booted Spectrometer LIAs are ON Spectrometer JFETs are ON |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • DCU PARAMETERS display is selected on the CCS |
| Duration | 5 minutes |
| Pass/Fail criteria | Spectrometer JFET HK parameters show expected ON values |

| Step | Description | Parameter | Expected Values Before/ After | Actual Values Before /After | Success/ Failure |
|------|---|---|---|-----------------------------|------------------|
| 1 | Execute TCL script SPIRE-FM-SFT-SPEC-JFET-ON-02.tcl Wait for the script to finish executing before proceeding with the next step | --- | --- | --- | --- |
| 2 | On the DCU PARAMETERS display check the JFET HK parameters Check with Instrument Team before proceeding with the next test. | SPECJFETSTAT SSWJFET1V SSWJFET2V SLWJFET1V | 7 -1.68 ± 0.02 V -2.07 ± 0.02 V -1.59 ± 0.02 V | | |

11.25 Procedure: SPIRE-FM-SFT-SPEC-JFET-OFF

| | |
|------------------------------|---|
| Version | 1.0 |
| Date | 29 th August 2007 |
| Purpose | Spectrometer JFETs Switch Off |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced AC/DC thermometry is ON MCU PRIME is booted Spectrometer LIAs are ON Spectrometer JFETs are ON |
| Final configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced AC/DC thermometry is ON MCU PRIME is booted Spectrometer LIAs are ON Spectrometer JFETs are OFF |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • DCU PARAMETERS display is selected on the CCS |
| Duration | 5 minutes |
| Pass/Fail criteria | Spectrometer JFET HK parameters show expected OFF values |

| Step | Description | Parameter | Expected Values Before/ After | Actual Values Before /After | Success/ Failure |
|------|---|-----------|-------------------------------|-----------------------------|------------------|
| 1 | Execute TCL script SPIRE-FM-SFT-SPEC-JFET-OFF.tcl Wait for the script to finish executing before proceeding with the next step | --- | --- | --- | --- |

| Step | Description | Parameter | Expected Values Before/After | Actual Values Before/After | Success/Failure |
|--|---|--|---|----------------------------|-----------------|
| 2 | <p>On the DCU PARAMETERS display check the JFET HK parameters</p> <p>Check with Instrument Team before proceeding with the next test.</p> | <p>SPECJFETSTAT</p> <p>SSWJFET1V</p> <p>SSWJFET2V</p> <p>SLWJFET1V</p> | <p>0</p> <p>0.0 V</p> <p>0.0 V</p> <p>0.0 V</p> | | |
| <p>Test Result (Pass/Fail):</p> | | | | | |

11.26 Procedure: SPIRE-FM-SFT-SLIA-OFF-P

| | |
|------------------------------|---|
| Version | 2.4 |
| Date | 10 th September 2007 |
| Purpose | Spectrometer LIAs PRIME Switch OFF |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON and MCU PRIME is booted. Spectrometer LIAs are ON |
| Final configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON and MCU PRIME is booted. Spectrometer LIAs are OFF |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • Spectrometer LIAs are ON • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • SFT PARAMETERS display is selected on the CCS |
| Duration | 2 minutes |
| Pass/Fail criteria | Specified Spectrometer LIA HK parameters show expected OFF values |

| Step | Description | Parameter | Expected Values Before/ After | Actual Values Before /After | Success/ Failure |
|---------------------------------|--|-------------------------------|--|-----------------------------|------------------|
| 1 | Execute TCL script SPIRE-FM-SFT-SLIA-OFF-P.tcl | SLIABITSTAT | 1/-0 | | |
| 2 | Check Photometer LIA HK parameter values | SLIAP5V SLIAP9V SLIAM9V | 5.2 ± 0.2V/-0.0 11.5 ± 0.5V/-0.0 -11.5 ± 0.5V/-0.0 | | |
| Test Result (Pass/Fail): | | | | | |

11.27 Procedure SPIRE-FM-SFT-MCU-OFF-P

| | |
|------------------------------|---|
| Version | 2.3 |
| Date | 28 nd August 2007 |
| Purpose | MCU PRIME Switch OFF |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON and MCU PRIME is booted. |
| Final configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON and MCU PRIME is OFF. |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • SPIRE MCU PRIME is ON. • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • SFT PARAMETERS display is selected on the CCS |
| Duration | 2 minutes |
| Pass/Fail criteria | Specified MCU HK Parameter shows expected value. |

Procedure Steps:

| Step | Description | Parameter – Unit | Expected Values Before/ During/ After | Actual Values Before/ During/ After | Success/ Failure |
|------|------------------------------------|------------------|---------------------------------------|-------------------------------------|------------------|
| 1 | Execute SPIRE-FM-SFT-MCU-OFF-P.tcl | --- | --- | --- | --- |
| 2 | Check that the MCU is switched off | MCUBITSTAT | 1/-/0 | | |

Test Result (Pass/Fail):

11.28 Procedure SPIRE-FM-SFT-SCU-OFF-P

| | |
|------------------------------|---|
| Version | 2.3 |
| Date | 28 nd August 2007 |
| Purpose | SCU PRIME Switch OFF |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON. |
| Final configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is OFF |
| Constraints | <ul style="list-style-type: none"> • SPIRE DRCU PRIME is switched ON • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • SFT PARAMETERS display is selected on the CCS |
| Duration | 2 minutes |
| Pass/Fail criteria | Specified SCU HK Parameters show expected value. |

Procedure Steps:

| Step | Description | Parameter - Unit | Expected Values Before/ During/ After | Actual Values Before/ During/ After | Success/ Failure |
|---------------------------------|---|------------------|---------------------------------------|-------------------------------------|------------------|
| 1 | Execute TCL script SPIRE-FM-SFT-SCU-OFF-P.tcl | — | — | — | — |
| 2 | A few seconds later record the value of parameter SCUTEMPSTAT | SCUTEMPSTAT | FFFF/-0 | | |
| 3 | A few seconds later record the value of parameter SUBKSTAT | SUBKSTAT | 1/-0 | | |
| Test Result (Pass/Fail): | | | | | |

11.29 Procedure SPIRE Power OFF

| Step | Description | Parameter | Expected Values Before/After | Actual Values Before/After | Pass/Fail |
|------|---|-----------|------------------------------|----------------------------|-----------|
| 1 | Execute TCL script S102999SCVT007_ASDFSFTSPIR_PWR_OFF_P.tcl | --- | --- | --- | |

Note: This script powers down the instrument DPU and DRCU prime. Therefore, the next two procedures, 11.30 and 11.31, are not executed manually.

11.30 Procedure: SPIRE-FM-SFT-DRCU-OFF-P

| | |
|------------------------------|--|
| Version | 2.2 |
| Date | 2 nd January 2007 |
| Purpose | DRCU PRIME Switch OFF |
| Initial configuration | SPIRE DPU and DRCU PRIME are ON and SPIRE HK is being produced and AC/DC thermometry is ON. |
| Final configuration | SPIRE DPU PRIME is ON, SPIRE DRCU PRIME is OFF and SPIRE HK is not being produced . |
| Constraints | <ul style="list-style-type: none"> • SPIRE-FM-SFT-SCU-OFF has been executed. • SPIRE DRCU PRIME is switched ON • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • SFT PARAMETERS display is selected on the CCS |
| Duration | 5 minutes |
| Pass/Fail criteria | THSK and TM2N stop refreshing/incrementing |

| Step | Description | Parameter - Unit | Expected Values Before/ During/ After | Actual Values Before/ During/ After | Success/ Failure |
|---------------------------------|---|------------------|---------------------------------------|-------------------------------------|------------------|
| 1 | Execute TCL script SPIRE-FM-SFT-DRCU-OFF.tcl | --- | --- | --- | |
| 2 | Check that THSK parameter is not refreshing anymore | THSK | Not refreshing | --- | |
| 3 | Check that TM2N parameter is not incrementing anymore | TM2N | Not incrementing | --- | |
| 4 | Power OFF the SPIRE DRCU PRIME unit. | --- | --- | --- | |
| Test Result (Pass/Fail): | | | | | |

11.31 Procedure: SPIRE-FM-SFT-DPU-OFF-P

| | |
|------------------------------|--|
| Version | 2.2 |
| Date | 2 nd January 2007 |
| Purpose | DPU PRIME Switch OFF |
| Initial configuration | SPIRE DPU PRIME is ON but not generating HK. |
| Final configuration | SPIRE DPU PRIME is OFF. |
| Constraints | <ul style="list-style-type: none"> • SPIRE-FM-SFT-DRCU-OFF has been executed. • SPIRE DPU PRIME is switched ON • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • SFT PARAMETERS display is selected on the CCS |
| Duration | 5 minutes |
| Pass/Fail criteria | Power to SPIRE DPU PRIME is OFF |

Procedure Steps:

| Step | Description | Parameter – Unit | Expected Values Before/ During/ After | Actual Values Before/ During/ After | Success/ Failure |
|--------------------------|-------------------------------------|------------------|---------------------------------------|-------------------------------------|------------------|
| 1 | Power OFF the SPIRE DPU PRIME unit. | --- | --- | --- | |
| Test Result (Pass/Fail): | | | | | |

11.32 SPIRE-SAFE-SWITCH-OFF

| | |
|------------------------------|---|
| Version | 2.3 |
| Date | 10 th September 2007 |
| Purpose | To switch OFF the SPIRE instrument if an anomaly should occur |
| Initial configuration | SPIRE can be on ANY configuration as specified on the procedure steps |
| Final configuration | SPIRE is OFF |
| Preconditions | <ul style="list-style-type: none"> • SPIRE FM DPU is electrically integrated with the Herschel Satellite • SPIRE MIB PRIME is imported in the CCS database. • CCS is up and running • FUNCTIONAL TEST PARAMETERS display is selected on the CCS |
| Duration | ~5-8 minutes |
| Pass/Fail Criteria | SPIRE is OFF. All instrument subsystems are completely powered OFF. |

Note:

All HK parameters relevant to this procedure can be located on the FUNCTIONAL TEST PARAMETERS CCS display. The exact name of the script to be executed at each step depends on whether the Prime or Redundant instrument is switched on.

| Step | Description | Parameter - Unit | Display | Actual value before/after |
|------|---|------------------|---------|---------------------------|
| 1 | <p>Check to see if the Photometer LIAs are on</p> <p>If PLIABITSTAT=1 then execute SPIRE-FM-SFT-PLIA-OFF-<P/R>.tcl</p> | PLIABITSTAT | 0 or 1 | |
| 2 | <p>Check to see if the Spectrometer LIAs are on</p> <p>If SLIABITSTAT=1 then execute SPIRE-FM-SFT-SLIA-OFF-<P/R>.tcl</p> | SLIABITSTAT | 0 or 1 | |

| | Name | Dep./Comp. | | Name | Dep./Comp. |
|---|-------------------------|------------|---|---------------------------------------|------------|
| | Alberti von Mathias Dr. | ASG23 | | Schmidt Thomas | AED15 |
| | Baldock Richard | FAE12 | | Schuler Günter | ASA42 |
| | Barlage Bernhard | AED13 | | Schweickert Gunn | ASG23 |
| | Bayer Thomas | ASA42 | | Sonn Nico | ASG51 |
| | Brune Holger | ASA45 | | Steininger Eric | AED32 |
| | Edelhoff Dirk | AED2 | X | Stritter Rene | AED11 |
| | Fehringer Alexander | ASG13 | | Suess Rudi | OTN/ASA44 |
| | Fricke Wolfgang Dr. | AED 65 | | Theunissen Martijn | DSSA |
| | Geiger Hermann | ASA42 | | Vascotto Riccardo | AED11 |
| | Grasl Andreas | OTN/ASA44 | | Wagner Klaus | ASG23 |
| X | Grasshoff Brigitte | AET12 | X | Wielbrock Walter | AET12 |
| X | Harner Simon | Terma | | Wöhler Hans | ASG23 |
| | Hendrikse Jeffrey | HE Space | | Wössner Ulrich | ASE252 |
| X | Hendry David | Terma | | Zumstein Armin | ASQ42 |
| | Hengstler Reinhold | ASA42 | | | |
| | Hinger Jürgen | ASG23 | | | |
| | Hohn Rüdiger | AED65 | | | |
| | Hölzle Edgar Dr. | AED32 | | | |
| | Hopfgarten Michael | AED32 | | | |
| | Huber Johann | ASA42 | | | |
| | Hund Walter | ASE252 | | | |
| X | Idler Siegmund | AED312 | | | |
| | Ivány von András | FAE12 | | | |
| | Jahn Gerd Dr. | ASG23 | | | |
| | Kalde Clemens | ASM2 | | | |
| | Kameter Rudolf | OTN/ASA42 | X | ESA/ESTEC | ESA |
| | Kettner Bernhard | AET42 | X | Thales Alenia Space Cannes | TAS-F |
| | Knoblauch August | AET32 | | Thales Alenia Space Torino | TAS-I |
| X | Koelle Markus | ASA43 | | | |
| X | Koppe Axel | AED312 | | Instruments: | |
| | Kroeker Jürgen | AED65 | | MPE (PACS) | MPE |
| | La Gioia Valentina | Terma | X | RAL (SPIRE) | RAL |
| | Lang Jürgen | ASE252 | | SRON (HIFI) | SRON |
| | Langenstein Rolf | AED15 | | | |
| | Langfermann Michael | ASA41 | | | |
| | Martin Olivier | ASA43 | | Subcontractors: | |
| | Maukisch Jan | ASA43 | | Austrian Aerospace | AAE |
| | Much Christoph | ASA43 | | Austrian Aerospace | AAEM |
| | Müller Jörg | ASA42 | | BOC Edwards | BOCE |
| | Müller Martin | ASA43 | | Dutch Space Solar Arrays | DSSA |
| | Peltz Heinz-Willi | ASG13 | | EADS Astrium Sub-Subsyat. & Equipment | ASSE |
| | Pietroboni Karin | AED65 | | EADS CASA Espacio | CASA |
| | Platzer Wilhelm | AED2 | | EADS CASA Espacio | ECAS |
| | Reichle Konrad | ASA42 | | European Test Services | ETS |
| | Runge Axel | OTN/ASA44 | | Patria New Technologies Oy | PANT |
| | Sauer Maximilian Dr. | AED65 | | SENER Ingenieria SA | SEN |
| | Schink Dietmar | AED32 | | Thales Alenia Space, Antwerp | TAS-ETCA |

End of Document

| | Name | Dep./Comp. | | Name | Dep./Comp. |
|---|-------------------------|------------|---|---------------------------------------|------------|
| | Alberti von Mathias Dr. | ASG23 | X | Schmidt Thomas | AED15 |
| | Baldock Richard | FAE12 | | Schweickert Gunn | ASG23 |
| | Barlage Bernhard | AED13 | | Sonn Nico | ASG51 |
| | Bayer Thomas | ASA42 | | Steininger Eric | AED32 |
| | Brune Holger | ASA45 | X | Stritter Rene | AED11 |
| | Edelhoff Dirk | AED2 | | Suess Rudi | OTN/ASA44 |
| | Fehringer Alexander | ASG13 | | Theunissen Martijn | DSSA |
| | Fricke Wolfgang Dr. | AED 65 | X | Vascotto Riccardo | HE Space |
| | Geiger Hermann | ASA42 | | Wagner Klaus | ASG23 |
| X | Grasl Andreas | OTN/ASA44 | | Wietbrock Walter | AET12 |
| | Grasshoff Brigitte | AET12 | | Wöhler Hans | ASG23 |
| | Hammer Simon | Terma | | Wössner Ulrich | ASE252 |
| | Hanka, Erhard | FI52 | | Zumstein Armin | ASQ42 |
| | Hendrikse Jeffrey | HE Space | | | |
| X | Hendry David | Terma | | | |
| | Hengstler Reinhold | ASA42 | | | |
| | Hinger Jürgen | ASG23 | | | |
| | Hohn Rüdiger | AED65 | | | |
| | Hölzle Edgar Dr. | AED32 | | | |
| | Hopfgarten Michael | AED32 | | | |
| | Huber Johann | ASA42 | | | |
| X | Hund Walter | ASE252 | | | |
| X | Idler Siegmund | AED312 | | | |
| | Ivány von András | FAE12 | | | |
| | Jahn Gerd Dr. | ASG23 | | | |
| | Kalde Clemens | ASM2 | X | ESA/ESTEC | ESA |
| | Kettner Bernhard | AET42 | X | Thales Alenia Space Cannes | TAS-F |
| | Klenke Uwe | ASG72 | | Thales Alenia Space Torino | TAS-I |
| | Knoblauch August | AET32 | | | |
| | Koelle Markus | ASA43 | | Instruments: | |
| X | Koppe Axel | AED312 | | MPE (FACS) | MPE |
| | Kroeker Jürgen | AED65 | X | RAL (SPIRE) | RAL |
| | La Gioia Valentina | Terma | | SRON (HIFI) | SRON |
| X | Lang Jürgen | ASE252 | | | |
| X | Langenstein Rolf | AED15 | | | |
| | Langfermann Michael | ASA41 | | Subcontractors: | |
| | Martin Olivier | ASA43 | | Austrian Aerospace | AAE |
| | Maukisch Jan | ASA43 | | Austrian Aerospace | AAEM |
| | Much Christoph | ASA43 | | BOC Edwards | BOCE |
| | Müller Jörg | ASA42 | | Dutch Space Solar Arrays | DSSA |
| X | Müller Martin | ASA43 | | EADS Astrium Sub-Subsyst. & Equipment | ASSE |
| | Pietroboni Karin | AED65 | | EADS CASA Espacio | CASA |
| | Platzer Wilhelm | AED2 | | EADS CASA Espacio | ECAS |
| | Reichle Konrad | ASA42 | | European Test Services | ETS |
| | Runge Axel | OTN/ASA44 | | Patria New Technologies Oy | PANT |
| | Sauer Maximilian Dr. | AED65 | | SENER Ingenieria SA | SEN |
| | Schink Dietmar | AED32 | | Thales Alenia Space, Antwerp | TAS-ETCA |