

TCS Subsystem Checkout
File: H_FCP_TCS_CHECK.xls
Author: E. Picallo



Procedure Summary

Objectives

This procedure describes the steps needed to verify the average temperature of all the thermal control loops, the TCT content and the TCS relevant entries in on board tables (FCCT, MOT, EAT and TCT).

Summary of Constraints

Control loops 1, 7, 12, 19, 31 and 49 are not used by the Thermal Control function.

It is required to enable the HK Diagnostic ASW 1 Packet in order to monitor the middle temperature parameters of the TCS control loops.

Spacecraft Configuration

Start of Procedure

CDMU in default configuration;

End of Procedure

CDMU in default configuration;

Reference File(s)

Input Command Sequences

Output Command Sequences

HFTCHECK

Referenced Displays

ANDs GRDs SLDs

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



ZAZAA999
 ZAZ7M999
 ZAZ84999
 ZAZ3Z999
 ZAZA0999
 ZAZ85999
 ZAZ86999
 ZAZ87999
 ZAZ40999
 ZAZ88999
 ZAZ89999
 ZAZ8A999


Configuration Control Information

DATE	FOP ISSUE	VERSION	MODIFICATION DESCRIPTION	AUTHOR	SPR REF
29/07/08	1	1	Created	E. Picallo	
22/10/08		2	CDMU ASW v3.6.2 and BSW v2.2 alignment	E. Picallo	
09/01/09	2	3	CDMU ASW V3.8 and BSW V2.4 alignment	E. Picallo	
24/02/09		4	control loops middle temperature TM checks added	E. Picallo	
05/03/09	2.1	5	updated with default CDMU ASW 3.8.2 FCCT	E. Picallo	
24/03/09	2.2	6	LOW NOP and cold start limit for STR-1 & 2 baffle should be -23°C on launch and in-flight Avg and Middle temperatures descriptions updated	E. Picallo	
07/04/09		7	Diagnostic channel acquisition verification added Correction: LOW NOP limit for STR-1 & 2 baffle should be -23.5°C on launch and should not be restored in-flight	E. Picallo	
15/04/09		8	FCCT align to CDMU OBSW 3.10 default values	E. Picallo	
19/04/09	2.3	9	HPSDB OOLs (Ground limits) values checked	E. Picallo	
04/05/09	2.4	10	Acquisition of DPU monitoring only thermistors added Acquisition of HPS2/17HCS1 related to Propellant Tanks added	E. Picallo	
15/09/09	2.5	11	Default FCCT table content align to CDMU ASW V 4.0	E. Picallo	

TCS Subsystem Checkout
File: H_FCP_TCS_CHECK.xls
Author: E. Picallo



Procedure Flowchart Overview



TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
Beginning of Procedure				
TC Seq. Name : HFTCHECK (TCS Checkout) TCS Subsystem Checkout TimeTag Type: N Sub Schedule ID: <input type="checkbox"/>				
1		Checkout of the TCT (Thermal Control Table)		Next Step: 2
		Execute Procedure: H_FCP_TCS_REPO Thermal Control Status Report		
2		Checkout of the FDIR Cross Correlated Table (FCCT)		Next Step: 3
		If the report FDIR Management Status Report TM(8,6,116) has already been requested, there is not needed to send the next TC(8,5,116)		
		Execute Telecommand <div style="text-align: right;">ReportFdirManagSts</div> TC Control Flags : <div style="text-align: right;">GBM IL DSE --Y -- ---</div> Subsch. ID : 10 Det. descr. : Report Fdir Management Status, TC(8,5,116)	DCN02170	
		The default FCCT table content corresponding to CDMU ASW V 4.0 is attached at the end of the procedure. Note: FCCT ID = 18 + TCT Loop Index (just needed TCS entries are included in the FCCT)		
3		Checkout of the Monitoring Table (MOT)		Next Step: 4
		If the report current monitoring list has already been requested, there is not needed to send the next TC(12,8)		
		Execute Telecommand <div style="text-align: right;">ReportMonitList</div> TC Control Flags : <div style="text-align: right;">GBM IL DSE --Y -- ---</div> Subsch. ID : 10 Det. descr. : TEMPLATE Report current monitoring list, TC(12,8) no appl. data	DC51F170	

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch																																																									
		Verify HPSx [1 9] Thermal Control Failure, GRPx [1 18] THERM and decontamination related entries in the MOT																																																											
		Verify the TCS failure monitoring entries: <table border="1"> <thead> <tr> <th>Parameter ID</th> <th>Mon ID</th> <th>Monitoring Status</th> </tr> </thead> <tbody> <tr><td>HPS1_Thermal_Control_Failure</td><td>21</td><td>ENABLED</td></tr> <tr><td>HPS2_Thermal_Control_Failure</td><td>27</td><td>ENABLED</td></tr> <tr><td>HPS3_Thermal_Control_Failure</td><td>33</td><td>ENABLED</td></tr> <tr><td>HPS4_Thermal_Control_Failure</td><td>39</td><td>ENABLED</td></tr> <tr><td>HPS5_Thermal_Control_Failure</td><td>45</td><td>ENABLED</td></tr> <tr><td>HPS6_Thermal_Control_Failure</td><td>51</td><td>ENABLED</td></tr> <tr><td>HPS7_Thermal_Control_Failure</td><td>57</td><td>ENABLED</td></tr> <tr><td>HPS8_Thermal_Control_Failure</td><td>63</td><td>ENABLED</td></tr> <tr><td>HPS9_Thermal_Control_Failure</td><td>69</td><td>ENABLED</td></tr> </tbody> </table>	Parameter ID	Mon ID	Monitoring Status	HPS1_Thermal_Control_Failure	21	ENABLED	HPS2_Thermal_Control_Failure	27	ENABLED	HPS3_Thermal_Control_Failure	33	ENABLED	HPS4_Thermal_Control_Failure	39	ENABLED	HPS5_Thermal_Control_Failure	45	ENABLED	HPS6_Thermal_Control_Failure	51	ENABLED	HPS7_Thermal_Control_Failure	57	ENABLED	HPS8_Thermal_Control_Failure	63	ENABLED	HPS9_Thermal_Control_Failure	69	ENABLED																													
Parameter ID	Mon ID	Monitoring Status																																																											
HPS1_Thermal_Control_Failure	21	ENABLED																																																											
HPS2_Thermal_Control_Failure	27	ENABLED																																																											
HPS3_Thermal_Control_Failure	33	ENABLED																																																											
HPS4_Thermal_Control_Failure	39	ENABLED																																																											
HPS5_Thermal_Control_Failure	45	ENABLED																																																											
HPS6_Thermal_Control_Failure	51	ENABLED																																																											
HPS7_Thermal_Control_Failure	57	ENABLED																																																											
HPS8_Thermal_Control_Failure	63	ENABLED																																																											
HPS9_Thermal_Control_Failure	69	ENABLED																																																											
		Verify the TCS HPS temperature entries: <table border="1"> <thead> <tr> <th>Parameter ID</th> <th>Mon ID</th> <th>Monitoring Status</th> </tr> </thead> <tbody> <tr><td>PCDU GRP1 THERM</td><td>78</td><td>ENABLED</td></tr> <tr><td>PCDU GRP2 THERM</td><td>79</td><td>ENABLED</td></tr> <tr><td>PCDU GRP3 THERM</td><td>80</td><td>ENABLED</td></tr> <tr><td>PCDU GRP4 THERM</td><td>81</td><td>ENABLED</td></tr> <tr><td>PCDU GRP5 THERM</td><td>82</td><td>ENABLED</td></tr> <tr><td>PCDU GRP6 THERM</td><td>83</td><td>ENABLED</td></tr> <tr><td>PCDU GRP7 THERM</td><td>84</td><td>ENABLED</td></tr> <tr><td>PCDU GRP8 THERM</td><td>85</td><td>ENABLED</td></tr> <tr><td>PCDU GRP9 THERM</td><td>86</td><td>ENABLED</td></tr> <tr><td>PCDU GRP10 THERM</td><td>87</td><td>ENABLED</td></tr> <tr><td>PCDU GRP11 THERM</td><td>88</td><td>ENABLED</td></tr> <tr><td>PCDU GRP12 THERM</td><td>89</td><td>ENABLED</td></tr> <tr><td>PCDU GRP13 THERM</td><td>90</td><td>ENABLED</td></tr> <tr><td>PCDU GRP14 THERM</td><td>91</td><td>ENABLED</td></tr> <tr><td>PCDU GRP15 THERM</td><td>92</td><td>ENABLED</td></tr> <tr><td>PCDU GRP16 THERM</td><td>93</td><td>ENABLED</td></tr> <tr><td>PCDU GRP17 THERM</td><td>94</td><td>ENABLED</td></tr> <tr><td>PCDU GRP18 THERM</td><td>95</td><td>ENABLED</td></tr> </tbody> </table>	Parameter ID	Mon ID	Monitoring Status	PCDU GRP1 THERM	78	ENABLED	PCDU GRP2 THERM	79	ENABLED	PCDU GRP3 THERM	80	ENABLED	PCDU GRP4 THERM	81	ENABLED	PCDU GRP5 THERM	82	ENABLED	PCDU GRP6 THERM	83	ENABLED	PCDU GRP7 THERM	84	ENABLED	PCDU GRP8 THERM	85	ENABLED	PCDU GRP9 THERM	86	ENABLED	PCDU GRP10 THERM	87	ENABLED	PCDU GRP11 THERM	88	ENABLED	PCDU GRP12 THERM	89	ENABLED	PCDU GRP13 THERM	90	ENABLED	PCDU GRP14 THERM	91	ENABLED	PCDU GRP15 THERM	92	ENABLED	PCDU GRP16 THERM	93	ENABLED	PCDU GRP17 THERM	94	ENABLED	PCDU GRP18 THERM	95	ENABLED		
Parameter ID	Mon ID	Monitoring Status																																																											
PCDU GRP1 THERM	78	ENABLED																																																											
PCDU GRP2 THERM	79	ENABLED																																																											
PCDU GRP3 THERM	80	ENABLED																																																											
PCDU GRP4 THERM	81	ENABLED																																																											
PCDU GRP5 THERM	82	ENABLED																																																											
PCDU GRP6 THERM	83	ENABLED																																																											
PCDU GRP7 THERM	84	ENABLED																																																											
PCDU GRP8 THERM	85	ENABLED																																																											
PCDU GRP9 THERM	86	ENABLED																																																											
PCDU GRP10 THERM	87	ENABLED																																																											
PCDU GRP11 THERM	88	ENABLED																																																											
PCDU GRP12 THERM	89	ENABLED																																																											
PCDU GRP13 THERM	90	ENABLED																																																											
PCDU GRP14 THERM	91	ENABLED																																																											
PCDU GRP15 THERM	92	ENABLED																																																											
PCDU GRP16 THERM	93	ENABLED																																																											
PCDU GRP17 THERM	94	ENABLED																																																											
PCDU GRP18 THERM	95	ENABLED																																																											
4		Checkout of the Event Action Table (EAT)		Next Step: 5																																																									
		If the report current content of the EAT has already been requested, there is not needed to send the next TC(19,6)																																																											
		Execute Telecommand <p style="text-align: right;">ReptEvtActTable</p> TC Control Flags : <p style="text-align: right;">GBM IL DSE --Y -- --</p> Subsch. ID : 10 Det. descr. : TEMPLATE Report The contents of the event/action table TC(19,6)	DCT86170																																																										
		Verify HPSx [1 9] Th Cntrl Failure, HPSx [1 18] PROTECT FAIL and decontamination (HASW_EAT_A000/A001) related entries in the EAT.																																																											

TCS Subsystem Checkout File: H_FCP_TCS_CHECK.xls Author: E. Picallo	 
---	--

Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
		Event Description Ev ID Event Status HPS1_Th_Cntrl_Failure 0x8013 Enabled HPS2_Th_Cntrl_Failure 0x8023 Enabled HPS3_Th_Cntrl_Failure 0x8033 Enabled HPS4_Th_Cntrl_Failure 0x8043 Enabled HPS5_Th_Cntrl_Failure 0x8053 Enabled HPS6_Th_Cntrl_Failure 0x8063 Enabled HPS7_Th_Cntrl_Failure 0x8073 Enabled HPS8_Th_Cntrl_Failure 0x8083 Enabled HPS9_Th_Cntrl_Failure 0x8093 Enabled		
5		Verify diagnostic channel acquisition		Next Step: 6
		Verify DIAG5 Interrogation from TH Ref. Voltage (5V) derived from 10V ADC Ref DIAG5_Interrog DEDKG160	>= 4.894 V <= 5.106 V	AND=ZAZAA999
		A TM(5,1,99) Diagnostic channel out of range, shall be generated whenever an acquired internal channel is found to be out of limit		
6		Enable HK Diagnostic ASW 1 Packet		Next Step: 7
		It is required to enable the HK Diagnostic ASW 1 Packet in order to monitor the middle temperature parameters of the TCS control loops.		
		Call procedure "Enable or disable the generation of an housekeeping or diagnostic packet" H_FCP_DHS_3033 1) Acquire the list of the current enabled TM packets 2) Verify if the HK Diagnostic ASW 1 packet is enabled: subtype=26, packet-ID=99 3) If it is disabled, enable it		
		Execute Procedure: H_FCP_DHS_3033 Enable or disable the generation of an housekeeping or diagnostic packet		
7		Acquire control loop average and middle temperatures		Next Step: 8

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
		<p>Note: The following Thermal control loop are not related to TCS class A/B loops:</p> <p>Thermal control loop 1 dedicated to the Decontamination Heating 1 (HPS1/18 HCS1) is disabled.</p> <p>Thermal control loop 7 dedicated to the Decontamination Heating 3 (HPS2/17 HCS1) is disabled.</p> <p>Thermal control loop 12 dedicated to Propellant Tanks (HPS2/17 HCS6) is disabled.</p> <p>Thermal control loop 19 dedicated to the Decontamination Heating 5 (HPS4/15 HCS1) is disabled.</p> <p>Thermal control loop 31 dedicated to the Decontamination Heating 7 (HPS6/13 HCS1) is disabled.</p> <p>Thermal control loop 49 dedicated to the Decontamination Heating 8 (HPS9/10 HCS1) is disabled.</p>		
7.1		Acquire control loop 2 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the XPND 2		
		The relevant line controls the whole XPND (RX+TX) and is driven by the RX Status that is supposed to be always ON		
		Verify Telemetry XpndRx2FuncSts DEL62170	ON or OFF	AND=ZAZ7M999
		If XPND2 Rx ON verify Telemetry ATemp02_XPND_2 DEA79170	> -10.0 <dec> < 50.0 <dec>	AND=ZAZ84999
		If XPND2 Rx OFF verify Telemetry ATemp02_XPND_2 DEA79170	> -20.0 <dec> < 50.0 <dec>	AND=ZAZ84999
7.2		Acquire control loop 2 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp02_XPND_2 DEA04170		AND=ZAZ3Z999
		<p>FCCT thresholds dedicated to the XPND 2: Operative range: Min = -12 °C; Max = 52 °C Non operative range: Min = -12 °C; Max = 52 °C</p> <p>Which thresholds apply is related to XPND2 RX ON/OFF status.</p>		
7.3		Acquire control loop 3 average temperature		<input type="checkbox"/>

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
		Average temperature of thermal control loop dedicated to the FCV A1B		
		Verify Telemetry ATemp03_FCV_A1B DEA7A170	> 10.0 <dec> < 65.0 <dec>	AND=ZAZ84999
7.4		Acquire control loop 3 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp03_FCV_A1B DEA05170	> 10.0 <dec> < 65.0 <dec>	AND=ZAZ3Z999
		FCCT thersholds dedicated to the FCV A1B: Operative range: Min = 8 °C ; Max = 90 °C Non operative range: Min = 8 °C ; Max = 90 °C		
7.5		Acquire control loop 4 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the FCV C2B		
		Verify Telemetry ATemp04_FCV_C2B DEA7B170	> 10.0 <dec> < 65.0 <dec>	AND=ZAZ84999
7.6		Acquire control loop 4 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp04_FCV_C2B DEA06170	> 10.0 <dec> < 65.0 <dec>	AND=ZAZ3Z999
		FCCT thresholds dedicated to the FCV C2B: Operative range: Min = 8 °C; Max = 90 °C Non operative range: Min = 8 °C; Max = 90 °C		
7.7		Acquire control loop 5 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the RCS pipe 2		
		Verify Telemetry ATemp05_RCSPipe2 DEA7C170	> 10.0 <dec> < 50.0 <dec>	AND=ZAZ84999
7.8		Acquire control loop 5 middle temperature		<input type="checkbox"/>

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
		Verify Telemetry MTemp05_RCSPipe2 DEA07170	> 10.0 <dec> < 50.0 <dec>	AND=ZAZ3Z999
		FCCT thresholds dedicated to the RCS pipe 2: Operative range: Min = 12 °C; Max = 52 °C Non operative range: Min = 12 °C; Max = 52 °C		
7.9		Acquire control loop 6 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the XPND 1		
		The relevant line controls the whole XPND (RX+TX) and is driven by the RX Status that is supposed to be always ON		
		Verify Telemetry XpndRx1FuncSts DEL58170	ON or OFF	AND=ZAZ7M999
		If XPND1 RX ON verify Telemetry ATemp06_XPND_1 DEA7D170	> -10.0 <dec> < 50.0 <dec>	AND=ZAZ84999
		If XPND1 RX OFF verify Telemetry ATemp06_XPND_1 DEA7D170	> -20.0 <dec> < 50.0 <dec>	AND=ZAZ84999
7.10		Acquire control loop 6 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp06_XPND_1 DEA08170		AND=ZAZ3Z999
		FCCT thresholds dedicated to the XPND 1: Operative range: Min = -12 °C; Max = 52 °C Non operative range: Min = -12 °C; Max = 52 °C Which thresholds apply is related to XPND1 Rx ON/OFF status.		
7.11		Acquire control loop 8 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the FCV C1B		
		Verify Telemetry ATemp08_FCV_C1B DEA7F170	> 10.0 <dec> < 65.0 <dec>	AND=ZAZ84999
7.12		Acquire control loop 8 middle temperature		<input type="checkbox"/>

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
		Verify Telemetry MTemp08_FCV_C1B DEA0A170	> 10.0 <dec> < 65.0 <dec>	AND=ZAZ3Z999
		FCCT thersholds dedicated to the FCV C1B: Operative range: Min = 8 °C; Max = 90 °C Non operative range: Min = 8 °C; Max = 90 °C		
7.13		Acquire control loop 9 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the FCV A2B		
		Verify Telemetry ATemp09_FCV_A2B DEA80170	> 10.0 <dec> < 65.0 <dec>	AND=ZAZ84999
7.14		Acquire control loop 9 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp09_FCV_A2B DEA0B170	> 10.0 <dec> < 65.0 <dec>	AND=ZAZ3Z999
		FCCT thersholds dedicated to the FCV A2B: Operative range: Min = 8 °C; Max = 90 °C Non operative range: Min = 8 °C; Max = 90 °C		
7.15		Acquire control loop 10 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the FCV C4B		
		Verify Telemetry ATemp10_FCV_C4B DEA81170	> 10.0 <dec> < 65.0 <dec>	AND=ZAZ84999
7.16		Acquire control loop 10 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp10_FCV_C4B DEA0C170	> 10.0 <dec> < 65.0 <dec>	AND=ZAZ3Z999
		FCCT thersholds dedicated to the FCV C4B: Operative range: Min = 8 °C; Max = 90 °C Non operative range: Min = 8 °C; Max = 90 °C		
7.17		Acquire control loop 11 average temperature		<input type="checkbox"/>

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
		Average temperature of thermal control loop dedicated to the FPSPU/FPDPU Which thresholds apply is related to FPDPU ON/OFF status.		
		Verify Telemetry PacsDpuFuncSts DEL50171	ON or OFF	AND=ZAZA0999
		If FPSPU/FPDPU ON Verify Telemetry ATemp11_FPSPU DEA82170	> -15.0 <dec> < 45.0 <dec>	AND=ZAZ85999
		If FPSPU/FPDPU OFF Verify Telemetry ATemp11_FPSPU DEA82170	> -30.0 <dec> < 45.0 <dec>	AND=ZAZ85999
7.18		Acquire control loop 11 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp11_FPSPU DEA0D170		AND=ZAZ3Z999
		FCCT thersholds dedicated to the FPSPU/FPDPU: Operative range: Min = -17 °C; Max = 47 °C Non operative range: Min = -25 °C; Max = 47 °C Which thresholds apply is related to FPDPU ON/OFF status.		
7.19		Acquire control loop 13 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the FPBOLC Which thresholds apply is related to FPBOLC ON/OFF status		
		Verify Telemetry PacsBolc1FuncSt DEL54171	ON or OFF	AND=ZAZA0999
		If FPBOLC ON Verify Telemetry ATemp13_FPBOLC DEA84170	> -15.0 <dec> < 45.0 <dec>	AND=ZAZ85999
		If FPBOLC OFF Verify Telemetry ATemp13_FPBOLC DEA84170	> -30.0 <dec> < 45.0 <dec>	AND=ZAZ85999
7.20		Acquire control loop 13 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp13_FPBOLC DEA0F170		AND=ZAZ3Z999

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
		FCCT thresholds dedicated to the FPBOLC: Operative range: Min = -17 °C; Max = 47 °C Non operative range: Min = -21 °C; Max = 47 °C Which thresholds apply is related to FPBOLC ON/OFF status		
7.21		Acquire control loop 14 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the CRS 1 Which thresholds apply is related to CRS1 ON/OFF status.		
		Verify Telemetry Crs1HFuncSts DEN68171	ON or OFF	AND=ZAZA0999
		If CRS1 ON Verify Telemetry ATemp14_CRS_1 DEA85170	> 0.0 <dec> < 50.0 <dec>	AND=ZAZ85999
		If CRS1 ON Verify Telemetry ATemp14_CRS_1 DEA85170	> 0.0 <dec> < 50.0 <dec>	AND=ZAZ85999
7.22		Acquire control loop 14 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp14_CRS_1 DEA10170	> 0.0 <dec> < 50.0 <dec>	AND=ZAZ3Z999
		FCCT thresholds dedicated to the CRS 1: Operative range: Min = 43 °C; Max = 52 °C Non operative range: Min = 43 °C; Max = 52 °C Which thresholds apply is related to CRS1 ON/OFF status.		
7.23		Acquire control loop 15 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the FPDECMEC Which thresholds apply is related to FPDECMEC ON/OFF status.		
		Verify Telemetry PacsDec1FuncSts DEL44171	ON or OFF	AND=ZAZA0999
		If FPDECMEC ON Verify Telemetry ATemp15_FPDECMEC DEA86170	> -15.0 <dec> < 45.0 <dec>	AND=ZAZ85999

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
		If FPDECMEC OFF Verify Telemetry ATemp15_FPDECMEC DEA86170	> -30.0 <dec> < 45.0 <dec>	AND=ZAZ85999
7.24		Acquire control loop 15 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp15_FPDECMEC DEA11170		AND=ZAZ3Z999
		FCCT thresholds dedicated to the FPDECMEC: Operative range: Min = -17 °C; Max = 47 °C Non operative range: Min = -22 °C; Max = 47 °C Which thresholds apply is related to FPDECMEC ON/OFF status.		
7.25		Acquire control loop 16 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the RCS pipe 1		
		Verify Telemetry ATemp16_RCSPipe1 DEA87170	> 10.0 <dec> < 50.0 <dec>	AND=ZAZ85999
7.26		Acquire control loop 16 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp16_RCSPipe1 DEA12170	> 10.0 <dec> < 50.0 <dec>	AND=ZAZ3Z999
		FCCT thersholds dedicated to the RCS pipe 1: Operative range: Min = 20 °C; Max = 52 °C Non operative range: Min = 20 °C; Max = 52 °C		
7.27		Acquire control loop 17 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the CCU Which thresholds apply is related to CCU A/B ON/OFF status.		
		Verify Telemetry CcuAFuncSts DEL97171	ON or OFF	AND=ZAZA0999
		Verify Telemetry CcuBFuncSts DEL96171	ON or OFF	AND=ZAZA0999

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
		If CCU A or CCU B ON Verify Telemetry ATemp17_CCU DEA88170	> -10.0 <dec> < 40.0 <dec>	AND=ZAZ85999
		If CCU A or CCU B OFF Verify Telemetry ATemp17_CCU DEA88170	> -35.0 <dec> < 40.0 <dec>	AND=ZAZ85999
7.28		Acquire control loop 17 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp17_CCU DEA13170		AND=ZAZ3Z999
		FCCT thersholds dedicated to the CCU: Operative range: Min = 11 °C; Max = 42 °C Non operative range: Min = 11 °C; Max = 42 °C Which thresholds apply is related to CCU A/B ON/OFF status.		
7.29		Acquire control loop 18 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the Gyro Which thresholds apply is related to Gyro ON/OFF status.		
		Verify Telemetry Gyro1FuncSts DEH38171	ON or OFF	AND=ZAZA0999
		If Gyro ON Verify Telemetry ATemp18_GYRO DEA89170	> -20.0 <dec> < 65.0 <dec>	AND=ZAZ85999
		If Gyro OFF Verify Telemetry ATemp18_GYRO DEA89170	> -25.0 <dec> < 65.0 <dec>	AND=ZAZ85999
7.30		Acquire control loop 18 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp18_GYRO DEA14170		AND=ZAZ3Z999
		FCCT thresholds dedicated to the Gyro: Operative range: Min = 9 °C; Max = 65 °C Non operative range: Min = 9 °C; Max = 65 °C Which thresholds apply is related to Gyro ON/OFF status.		
7.31		Acquire control loop 20 average temperature		<input type="checkbox"/>

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
		Average temperature of thermal control loop dedicated to the FHWOV Which thresholds apply is related to FHWOV ON/OFF status.		
		Verify Telemetry HifiWovFuncSts DEL49171	ON or OFF	AND=ZAZA0999
		If FHWOV ON Verify Telemetry ATemp20_FHWOV DEA8B170	< 10.0 <dec> > 2.0 <dec>	AND=ZAZ86999
		If FHWOV ON Verify Telemetry ATemp20_FHWOV DEA8B170	< 10.0 <dec> > -25.0 <dec>	AND=ZAZ86999
7.32		Acquire control loop 20 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp20_FHWOV DEA16170		AND=ZAZ3Z999
		FCCT thresholds dedicated to the FHWOV: Operative range: Min = 2 °C; Max = 12 °C Non operative range: Min = -20 °C; Max = 12 °C Which thresholds apply is related to FHWOV ON/OFF status.		
7.33		Acquire control loop 21 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the RCS pipe 6		
		Verify Telemetry ATemp21_RCSPipe6 DEA8C170	> 10.0 <dec> < 50.0 <dec>	AND=ZAZ86999
7.34		Acquire control loop 21 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp21_RCSPipe6 DEA17170	> 10.0 <dec> < 50.0 <dec>	AND=ZAZ3Z999
		FCCT thersholds dedicated to the RCS pipe 6: Operative range: Min = 11 °C; Max = 52 °C Non operative range: Min = 11 °C; Max = 52 °C		
7.35		Acquire control loop 22 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the FCV A1A		

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
		Verify Telemetry ATemp22_FCV_A1A DEA8D170	> 10.0 <dec> < 65.0 <dec>	AND=ZAZ86999
7.36		Acquire control loop 22 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp22_FCV_A1A DEA18170	> 10.0 <dec> < 65.0 <dec>	AND=ZAZ3Z999
		FCCT thresholds dedicated to the FCV A1A: Operative range: Min = 8 °C; Max = 90 °C Non operative range: Min = 8 °C; Max = 90 °C		
7.37		Acquire control loop 23 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the FCV C2A		
		Verify Telemetry ATemp23_FCV_C2A DEA8E170	> 10.0 <dec> < 65.0 <dec>	AND=ZAZ86999
7.38		Acquire control loop 23 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp23_FCV_C2A DEA19170	> 10.0 <dec> < 65.0 <dec>	AND=ZAZ3Z999
		FCCT thresholds dedicated to the FCV C2A: Operative range: Min = 8 °C; Max = 90 °C Non operative range: Min = 8 °C; Max = 90 °C		
7.39		Acquire control loop 24 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the RCS pipe 7		
		Verify Telemetry ATemp24_RCSPipe7 DEA8F170	> 10.0 <dec> < 50.0 <dec>	AND=ZAZ86999
7.40		Acquire control loop 24 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp24_RCSPipe7 DEA1A170	> 10.0 <dec> < 50.0 <dec>	AND=ZAZ3Z999

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
		FCCT thresholds dedicated to the RCS pipe 7: Operative range: Min = 11 °C; Max = 52 °C Non operative range: Min = 11 °C; Max = 52 °C		
7.41		Acquire control loop 25 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the CRS 2 Which thresholds apply is related to CRS2 ON/OFF status.		
		Verify Telemetry Crs2HFuncSts DEN69171	ON or OFF	AND=ZAZA0999
		If CRS2 ON Verify Telemetry ATemp25_CRIS_2 DEA90170	> 0.0 <dec> < 50.0 <dec>	AND=ZAZ86999
		If CRS2 OFF Verify Telemetry ATemp25_CRIS_2 DEA90170	> 0.0 <dec> < 50.0 <dec>	AND=ZAZ86999
7.42		Acquire control loop 25 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp25_CRIS_2 DEA1B170	> 0.0 <dec> < 50.0 <dec>	AND=ZAZ3Z999
		FCCT thresholds dedicated to the CRS 2: Operative range: Min = 43 °C; Max = 52 °C Non operative range: Min = 43 °C; Max = 52 °C Which thresholds apply is related to CRS2 ON/OFF status.		
7.43		Acquire control loop 26 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the FHHRH Which thresholds apply is related to FHHRH ON/OFF status		
		Verify Telemetry HifiHrhFuncSts DEL46171	ON or OFF	AND=ZAZA0999
		If FHHRH ON Verify Telemetry ATemp26_FHHRH DEA91170	> 12.0 <dec> < 40.0 <dec>	AND=ZAZ86999
		If FHHRH OFF Verify Telemetry ATemp26_FHHRH DEA91170	> -25.0 <dec> < 40.0 <dec>	AND=ZAZ86999

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
7.44		Acquire control loop 26 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp26_FHHRH DEA1C170		AND=ZAZ3Z999
		FCCT thresholds dedicated to the FHHRH: Operative range: Min = 25 °C; Max = 31 °C Non operative range: Min = -22 °C; Max = 31 °C Which thresholds apply is related to FHHRH ON/OFF status		
7.45		Acquire control loop 27 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the FHWEV Which thresholds apply is related to FHWEV ON/OFF status.		
		Verify Telemetry HifiWevFuncSts DEL53171	ON or OFF	AND=ZAZA0999
		If FHWEV ON Verify Telemetry ATemp27_FHWEV DEA92170	> 0.0 <dec> < 30.0 <dec>	AND=ZAZ86999
		If FHWEV OFF Verify Telemetry ATemp27_FHWEV DEA92170	> -25.0 <dec> < 30.0 <dec>	AND=ZAZ86999
7.46		Acquire control loop 27 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp27_FHWEV DEA1D170		AND=ZAZ3Z999
		FCCT thresholds dedicated to the FHWEV: Operative range: Min = -2 °C; Max = 32 °C Non operative range: Min = -22 °C; Max = 32 °C Which thresholds apply is related to FHWEV ON/OFF status.		
7.47		Acquire control loop 28 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the FCV C3B		
		Verify Telemetry ATemp28_FCV_C3B DEA93170	> 10.0 <dec> < 65.0 <dec>	AND=ZAZ87999

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
7.48		Acquire control loop 28 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp28_FCV_C3B DEA1E170	> 10.0 <dec> < 65.0 <dec>	AND=ZAZ3Z999
		FCCT thresholds dedicated to the FCV C3B: Operative range: Min = 8 °C; Max = 90 °C Non operative range: Min = 8 °C; Max = 90 °C		
7.49		Acquire control loop 29 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the RCS pipe 8		
		Verify Telemetry ATemp29_RCSPipe8 DEA94170	> 10.0 <dec> < 50.0 <dec>	AND=ZAZ87999
7.50		Acquire control loop 29 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp29_RCSPipe8 DEA1F170	> 10.0 <dec> < 50.0 <dec>	AND=ZAZ3Z999
		FCCT thresholds dedicated to the RCS pipe 8: Operative range: Min = 16 °C; Max = 52 °C Non operative range: Min = 16 °C; Max = 52 °C		
7.51		Acquire control loop 30 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the RCS PT unit		
		Verify Telemetry ATemp30_LV_1_2 DEA95170	> 10.0 <dec> < 50.0 <dec>	AND=ZAZ87999
7.52		Acquire control loop 30 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp30_LV_1_2 DEA20170	> 10.0 <dec> < 50.0 <dec>	AND=ZAZ3Z999
		FCCT thresholds dedicated to the RCS PT unit: Operative range: Min = 7 °C; Max = 52 °C Non operative range: Min = 7 °C; Max = 52 °C		

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
7.53		Acquire control loop 32 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the RWL 4 Which thresholds apply is related to RWL4 ON/OFF status.		
		Verify Telemetry Rw4FuncSts DEG33171	ON or OFF	AND=ZAZA0999
		If RWL4 ON Verify Telemetry Atemp32_RWL_4 DEA97170	> 0.0 <dec> < 50.0 <dec>	AND=ZAZ87999
		If RWL4 OFF Verify Telemetry Atemp32_RWL_4 DEA97170	> -10.0 <dec> < 55.0 <dec>	AND=ZAZ87999
7.54		Acquire control loop 32 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp32_RWL_4 DEA22170		AND=ZAZ3Z999
		FCCT thresholds dedicated to the RWL 4: Operative range: Min = -2 °C; Max = 57 °C Non operative range: Min = -6 °C; Max = 57 °C Which thresholds apply is related to RWL4 ON/OFF status.		
7.55		Acquire control loop 33 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the RWL 1 Which thresholds apply is related to RWL1 ON/OFF status.		
		Verify Telemetry Rw1FuncSts DEL38171	ON or OFF	AND=ZAZA0999
		If RWL1 ON Verify Telemetry Atemp33_RWL_1 DEA98170	> 0.0 <dec> < 55.0 <dec>	AND=ZAZ87999
		If RWL1 OFF Verify Telemetry Atemp33_RWL_1 DEA98170	> -10.0 <dec> < 55.0 <dec>	AND=ZAZ87999
7.56		Acquire control loop 33 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp33_RWL_1 DEA23170		AND=ZAZ40999

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
		FCCT thresholds dedicated to the RWL 1: Operative range: Min = -2°C; Max = 57 °C Non operative range: Min = -6 °C; Max = 57 °C Which thresholds apply is related to RWL1 ON/OFF status.		
7.57		Acquire control loop 34 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the RWL 3 Which thresholds apply is related to RWL3 ON/OFF status. Operative range: Min = -2 °C; Max = 57 °C Non operative range: Min = -6 °C; Max = 57 °C		
		Verify Telemetry Rw3FuncSts DEL36171	ON or OFF	AND=ZAZA0999
		If RWL3 ON Verify Telemetry ATemp34_RWL_3 DEA99170	> 0.0 <dec> < 55.0 <dec>	AND=ZAZ87999
		If RWL3 OFF Verify Telemetry ATemp34_RWL_3 DEA99170	> -10.0 <dec> < 55.0 <dec>	AND=ZAZ87999
7.58		Acquire control loop 34 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp34_RWL_3 DEA24170		AND=ZAZ40999
		FCCT thresholds dedicated to the RWL 3: Operative range: Min = -2 °C; Max = 57 °C Non operative range: Min = -6 °C; Max = 57 °C Which thresholds apply is related to RWL3 ON/OFF status.		
7.59		Acquire control loop 35 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the FHIFV Which thresholds apply is related to FHIFV ON/OFF status.		
		Verify Telemetry HifiIfvFuncSts DEL39171	ON or OFF	AND=ZAZA0999
		If FHIFV ON Verify Telemetry ATemp35_FHIFV DEA9A170	> -10.0 <dec> < 40.0 <dec>	AND=ZAZ87999

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
		If FHIFV OFF Verify Telemetry ATemp35_FHIFV DEA9A170	> -20.0 <dec> < 40.0 <dec>	AND=ZAZ87999
7.60		Acquire control loop 35 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp35_FHIFV DEA25170		AND=ZAZ40999
		FCCT thersholds dedicated to the FHIFV: Operative range: Min = -12 °C; Max = 42 °C Non operative range: Min = -12 °C; Max = 42 °C Which thresholds apply is related to FHIFV ON/OFF status.		
7.61		Acquire control loop 36 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the RWL 2 Which thresholds apply is related to RWL2 ON/OFF status.		
		Verify Telemetry Rw2FuncSts DEL37171	ON or OFF	AND=ZAZA0999
		If RWL2 ON Verify Telemetry ATemp36_RWL_2 DEA9B170	> 0.0 <dec> < 55.0 <dec>	AND=ZAZ87999
		If RWL2 OFF Verify Telemetry ATemp36_RWL_2 DEA9B170	> -10.0 <dec> < 55.0 <dec>	AND=ZAZ87999
7.62		Acquire control loop 36 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp36_RWL_2 DEA26170		AND=ZAZ40999
		FCCT thresholds dedicated to the RWL 2: Operative range: Min = -2 °C; Max = 57 °C Non operative range: Min = -6 °C; Max = 57 °C Which thresholds apply is related to RWL2 ON/OFF status.		
7.63		Acquire control loop 37 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the Star Trackers mounting plate Operative range: Min = -3 °C; Max = 30 °C Non operative range: Min = -10 °C; Max = 30 °C		

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
		Note that the thermal control sees only one STR, unit. The unit status seen for STR by the thermal control is ON if either of the STR A or B is ON. i.e. it is sufficient that one STR is on for the TCS to apply the operative thresholds.		
		Verify Telemetry Str1FuncSts DEG01170	ON or OFF	AND=ZAZA0999
		Verify Telemetry Str2FuncSts DEG00170	ON or OFF	AND=ZAZA0999
		If STR1 or STR2 ON Verify Telemetry ATemp37_STRs DEA9C170	> -20.0 <dec> < 50.0 <dec>	AND=ZAZ88999
		If STR1 or STR2 OFF Verify Telemetry ATemp37_STRs DEA9C170	> -20.0 <dec> < 50.0 <dec>	AND=ZAZ88999
7.64		Acquire control loop 37 middle temperature		□
		Verify Telemetry MTemp37_STRs DEA27170	> -20.0 <dec> < 50.0 <dec>	AND=ZAZ40999
		FCCT thresholds dedicated to the Star Trackers mounting plate: Operative range: Min = -3 °C; Max = 30 °C Non operative range: Min = -10 °C; Max = 30 °C Which thresholds apply is related to STR 1/2 ON/OFF status.		
7.65		Acquire control loop 38 average temperature		□
		Average temperature of thermal control loop dedicated to the Battery		
		Verify Telemetry ATemp38_Battery DEA9D170	> 0.0 <dec> < 35.0 <dec>	AND=ZAZ88999
7.66		Acquire control loop 38 middle temperature		□
		Verify Telemetry MTemp38_Battery DEA28170	> 0.0 <dec> < 35.0 <dec>	AND=ZAZ40999
		FCCT thresholds dedicated to the Battery: Operative range: Min = -2 °C; Max = 37 °C Non operative range: Min = -2 °C; Max = 37 °C		

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
7.67		Acquire control loop 39 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the FHWOH Which thresholds apply is related to FHWOH ON/OFF status.		
		Verify Telemetry HifiWohFuncSts DEL40171	ON or OFF	AND=ZAZA0999
		If FHWOH ON Verify Telemetry ATemp39_FHWOH DEA9E170	> 1.0 <dec> < 9.0 <dec>	AND=ZAZ88999
		If FHWOH OFF Verify Telemetry ATemp39_FHWOH DEA9E170	> -25.0 <dec> < 9.0 <dec>	AND=ZAZ88999
7.68		Acquire control loop 39 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp39_FHWOH DEA29170		AND=ZAZ40999
		FCCt thresholds dedicated to the FHWOH: Operative range: Min = 1 °C; Max = 11 °C Non operative range: Min = -15 °C; Max = 11 °C Which thresholds apply is related to FHWOH ON/OFF status.		
7.69		Acquire control loop 40 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the FHWEH Which thresholds apply is related to FHWEH ON/OFF status		
		Verify Telemetry HifiWehFuncSts DEL48171	ON or OFF	AND=ZAZA0999
		If HIFIWEH ON Verify Telemetry ATemp40_FHWEH DEA9F170	> 0.0 <dec> < 30.0 <dec>	AND=ZAZ88999
		If HIFIWEH OFF Verify Telemetry ATemp40_FHWEH DEA9F170	> -25.0 <dec> < 30.0 <dec>	AND=ZAZ88999
7.70		Acquire control loop 40 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp40_FHWEH DEA2A170		AND=ZAZ40999

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
		FCCT thresholds dedicated to the FHWEH: Operative range: Min = -2 °C; Max = 32 °C Non operative range: Min = -7 °C; Max = 32°C Which thresholds apply is related to FHWEH ON/OFF status		
7.71		<i>Acquire control loop 41 average temperature</i>		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the FCV C1A		
		Verify Telemetry ATemp41_FCV_C1A DEAA0170	> 10.0 <dec> < 65.0 <dec>	AND=ZAZ88999
7.72		<i>Acquire control loop 41 middle temperature</i>		<input type="checkbox"/>
		Verify Telemetry MTemp41_FCV_C1A DEA2B170	> 10.0 <dec> < 65.0 <dec>	AND=ZAZ40999
		FCCT thresholds dedicated to the FCV C1A: Operative range: Min = 8 °C; Max = 90 °C Non operative range: Min = 8 °C; Max = 90 °C		
7.73		<i>Acquire control loop 42 average temperature</i>		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the FCV A2A		
		Verify Telemetry ATemp42_FCV_A2A DEAA1170	> 10.0 <dec> < 65.0 <dec>	AND=ZAZ88999
7.74		<i>Acquire control loop 42 middle temperature</i>		<input type="checkbox"/>
		Verify Telemetry MTemp42_FCV_A2A DEA2C170	> 10.0 <dec> < 65.0 <dec>	AND=ZAZ40999
		FCCT thersholds dedicated to the FCV A2A: Operative range: Min = 8 °C; Max = 90 °C Non operative range: Min = 8 °C; Max = 90 °C		
7.75		<i>Acquire control loop 43 average temperature</i>		<input type="checkbox"/>

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
		Average temperature of thermal control loop dedicated to the FHHRV Which thresholds apply is related to FHHRV ON/OFF status.		
		Verify Telemetry HifiHrvFuncSts DEL41171	ON or OFF	AND=ZAZA0999
		If FHHRV ON Verify Telemetry ATemp43_FHHRV DEAA2170	> 21.0 <dec> < 40.0 <dec>	AND=ZAZ88999
		If FHHRV OFF Verify Telemetry ATemp43_FHHRV DEAA2170	> -25.0 <dec> < 40.0 <dec>	AND=ZAZ88999
7.76		Acquire control loop 43 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp43_FHHRV DEA2D170		AND=ZAZ40999
		FCCT thresholds dedicated to the FHHRV: Operative range: Min = 19 °C; Max = 25 °C Non operative range: Min = -25 °C; Max = 25 °C Which thresholds apply is related to FHHRV ON/OFF status.		
7.77		Acquire control loop 44 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the FCV C3A		
		Verify Telemetry ATemp44_FCV_C3A DEAA3170	> 10.0 <dec> < 65.0 <dec>	AND=ZAZ88999
7.78		Acquire control loop 44 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp44_FCV_C3A DEA2E170	> 10.0 <dec> < 65.0 <dec>	AND=ZAZ40999
		FCCT thresholds dedicated to the FCV C3A: Operative range: Min = 8 °C; Max = 90 °C Non operative range: Min = 8 °C; Max = 90 °C		
7.79		Acquire control loop 45 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the RCS pipe 3		

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
		Verify Telemetry ATemp45_RCSPipe3 DEAA4170	> 10.0 <dec> < 50.0 <dec>	AND=ZAZ89999
7.80		Acquire control loop 45 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp45_RCSPipe3 DEA2F170	> 10.0 <dec> < 50.0 <dec>	AND=ZAZ40999
		FCCT thresholds dedicated to the RCS pipe 3: Operative range: Min = 11 °C; Max = 52 °C Non operative range: Min = 11 °C; Max = 52 °C		
7.81		Acquire control loop 46 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the STR 2 Baffle Which thresholds apply is related to STR2 ON/OFF status.		
		Verify Telemetry Str2FuncSts DEG00170	ON or OFF	AND=ZAZA0999
		If STR2 ON Verify Telemetry ATemp46_STR2_Baf DEAA5170	> 0.0 <dec> < 50.0 <dec>	AND=ZAZ89999
		If STR2 OFF Verify Telemetry ATemp46_STR2_Baf DEAA5170	> 0.0 <dec> < 50.0 <dec>	AND=ZAZ89999
7.82		Acquire control loop 46 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp46_STR2_Baf DEA30170	> 0.0 <dec> < 50.0 <dec>	AND=ZAZ40999
		FCCT thresholds dedicated to the STR 2 Baffle: Operative range: Min = 11 °C; Max = 30 °C Non operative range: Min = -23.5 °C; Max = 30 °C Which thresholds apply is related to STR2 ON/OFF status.		
7.83		Acquire control loop 47 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the RCS pipe 5		

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
		Verify Telemetry ATemp47_RCSPipe5 DEAA6170	> 10.0 <dec> < 50.0 <dec>	AND=ZAZ89999
7.84		Acquire control loop 47 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp47_RCSPipe5 DEA31170	> 10.0 <dec> < 50.0 <dec>	AND=ZAZ40999
		FCCT thresholds dedicated to the RCS pipe 5: Operative range: Min = 20 °C; Max = 52 °C Non operative range: Min = 20 °C; Max = 52 °C		
7.85		Acquire control loop 48 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the FHLCU/FHIFH Which thresholds apply is related to FHLCU ON/OFF status		
		Verify Telemetry HifiLcuFuncSts DEL55171	ON or OFF	AND=ZAZA0999
		If HIFILCU ON Verify Telemetry ATemp48_FHLCU DEAA7170	> -10.0 <dec> < 40.0 <dec>	AND=ZAZ89999
		If HIFILCU OFF Verify Telemetry ATemp48_FHLCU DEAA7170	> -25.0 <dec> < 40.0 <dec>	AND=ZAZ89999
7.86		Acquire control loop 48 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp48_FHLCU DEA32170		AND=ZAZ40999
		FCCT thresholds dedicated to the FHLCU/FHIFH: Operative range: Min = 8 °C; Max = 42 °C Non operative range: Min = -20 °C; Max = 42 °C Which thresholds apply is related to FHLCU ON/OFF status		
7.87		Acquire control loop 50 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the Tank -Y		
		Verify Telemetry ATemp50_Tank_-Y DEAA9170	> 10.0 <dec> < 45.0 <dec>	AND=ZAZ89999

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
7.88		Acquire control loop 50 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp50_Tank_-Y DEA34170	> 10.0 <dec> < 45.0 <dec>	AND=ZAZ40999
		FCCT thresholds dedicated to the Tank -Y: Operative range: Min = 8 °C; Max = 40 °C Non operative range: Min = 8 °C; Max = 40 °C		
7.89		Acquire control loop 51 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the FCV C4A		
		Verify Telemetry ATemp51_FCV_C4A DEAAA170	> 10.0 <dec> < 65.0 <dec>	AND=ZAZ89999
7.90		Acquire control loop 51 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp51_FCV_C4A DEA35170	> 10.0 <dec> < 65.0 <dec>	AND=ZAZ40999
		FCCT thresholds dedicated to the FCV C4A: Operative range: Min = 8 °C; Max = 90 °C Non operative range: Min = 8 °C; Max = 90 °C		
7.91		Acquire control loop 52 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the FHLSU Which thresholds apply is related to LSU ON/OFF status.		
		Verify Telemetry HifiLsuFuncSts DEL42171	ON or OFF	AND=ZAZA0999
		If LSU ON Verify Telemetry ATemp52_FHLSU DEEAB170	> 10.0 <dec> < 35.0 <dec>	AND=ZAZ89999
		If LSU OFF Verify Telemetry ATemp52_FHLSU DEEAB170	> -15.0 <dec> < 35.0 <dec>	AND=ZAZ89999
7.92		Acquire control loop 52 middle temperature		<input type="checkbox"/>

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
		Verify Telemetry MTemp52_FHLSU DEA36170		AND=ZAZ40999
		FCCT thresholds dedicated to the FHLSU: Operative range: Min = 8 °C; Max = 37 °C Non operative range: Min = -13 °C; Max = 37 °C Which thresholds apply is related to LSU ON/OFF status.		
7.93		Acquire control loop 53 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the STR 1 baffle Which thresholds apply is related to STR1 ON/OFF status.		
		Verify Telemetry Str1FuncSts DEG01170	ON or OFF	AND=ZAZA0999
		If STR1 ON Verify Telemetry ATemp53_STR1_Baf DEAAC170	> 0.0 <dec> < 50.0 <dec>	AND=ZAZ89999
		If STR1 OFF Verify Telemetry ATemp53_STR1_Baf DEAAC170	> 0.0 <dec> < 50.0 <dec>	AND=ZAZ89999
7.94		Acquire control loop 53 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp53_STR1_Baf DEA37170	> 0.0 <dec> < 50.0 <dec>	AND=ZAZ40999
		FCCT thresholds dedicated to the STR 1 baffle: Operative range: Min = 11 °C; Max = 30 °C Non operative range: Min = -23.5 °C; Max = 30 °C Which thresholds apply is related to STR1 ON/OFF status.		
7.95		Acquire control loop 54 average temperature		<input type="checkbox"/>
		Average temperature of thermal control loop dedicated to the Tank +Y		
		Verify Telemetry ATemp54_Tank_+Y DEAAD170	> 10.0 <dec> < 45.0 <dec>	AND=ZAZ8A999
7.96		Acquire control loop 54 middle temperature		<input type="checkbox"/>
		Verify Telemetry MTemp54_Tank_+Y DEA38170	> 10.0 <dec> < 45.0 <dec>	AND=ZAZ40999

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo



Step No.	Time	Activity/Remarks	TC/TLM	Display/ Branch
		FCCT thresholds dedicated to the Tank +Y: Operative range: Min = 8 °C; Max = 40 °C Non operative range: Min = 8 °C; Max = 40 °C		
8		Acquire TCS monitoring only thermistors		Next Step: 9
		Verify FPDP (monitoring only) temperature Telemetry THM_52_PropTank TM052601		AND=ZAZ85999
		Verify FPDP (monitoring only) temperature Telemetry THM_100_PropTank TM100601		AND=ZAZ85999
9		Acquire Propellant Tanks lines status		Next Step: END
		Thermal control loop 12 dedicated to Propellant Tanks (HPS2/17 HCS6) is disabled and their monitoring frequencies set to 0, thus the loops are considered as spare.		
		The Propellant Tanks lines are not controlled by CDMS. They are use to maintain a permanent thermal gradient between gas side and propellant side of the tank. It need to be switched ON as part of the pre-Launch activities. The CDMU ASW assumes they are ON and only switches the related HCS of the HPS 'in use' in case of reconfiguration or when switching to Survival Mode.		
		Verify Telemetry tanks_G2H6_S WM21F565		AND=ZAZ85999
		Verify Telemetry tanks_G17H6_S WM91M565		AND=ZAZ85999
End of Procedure				

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo

Check ID	Name	Param1	Param2	Param3	Param4	Param5	Param6	Output Flag	NOTE	TCS Line(ref. AL0069)	Loop Index (ref. to TCT)
ChkId_17	FCCT_XPND1_RX_Power	XPND1 RX FCL current Min=0	XPND1 RX FCL current Max=0.38	XPND1 RX supply voltage Min (Voh)=4.5	XPND1 RX supply voltage Max (Voh)=5.5	Not Used	Not Used	XPND1 RX Power: DID_ASW_CCC_RES_5:6	XPND1 RX FCL current <-limits AND XPND1 RX supply voltage <-limit	N/A	N/A
ChkId_18	FCCT_XPND2_RX_Power	XPND2 RX FCL current Min=0	XPND2 RX FCL current Max=0.38	XPND2 RX supply voltage Min (Voh)=4.5	XPND2 RX supply voltage Max (Voh)=5.5	Not Used	Not Used	XPND2 RX Power: DID_ASW_CCC_RES_5:7	XPND2 RX FCL current <-limits AND XPND2 RX supply voltage <-limit	N/A	N/A
ChkId_20	FCCT_XPND2_HPS1_HCS2	FDIR LOW_NOP [°C] =-12	FDIR HIGH_NOP [°C] =52	time-out [sec]=64800	Cold Start Temp [°C] =-12	FDIR LOW_OP [°C] =-12	FDIR HIGH_OP [°C] =52	XPND2 TCS Failure HPS1_HCS2 DID_ASW_CCC_RES_2:14	This group of FCCT result is monitored by the Monitoring Entry with Id =21	TcsLine02	2
ChkId_21	FCCT_FCV41B_HPS1_HCS3	FDIR LOW_NOP [°C] =-8	FDIR HIGH_NOP [°C] =50	time-out [sec]=64800	Cold Start Temp [°C] =-8	FDIR LOW_OP [°C] =-8	FDIR HIGH_OP [°C] =50	FCV41B TCS Failure HPS1_HCS3 DID_ASW_CCC_RES_2:13		TcsLine39	3
ChkId_22	FCCT_FCV2B_HPS1_HCS4	FDIR LOW_NOP [°C] =-8	FDIR HIGH_NOP [°C] =50	time-out [sec]=64800	Cold Start Temp [°C] =-8	FDIR LOW_OP [°C] =-8	FDIR HIGH_OP [°C] =50	FCV2B TCS Failure HPS1_HCS4 DID_ASW_CCC_RES_2:12		TcsLine40	4
ChkId_23	FCCT_RCS_pipe2_HPS1_HCS5	FDIR LOW_NOP [°C] =-12	FDIR HIGH_NOP [°C] =52	time-out [sec]=64800	Cold Start Temp [°C] =-12	FDIR LOW_OP [°C] =-12	FDIR HIGH_OP [°C] =52	RCS piping #2 TCS Failure HPS1_HCS5 DID_ASW_CCC_RES_2:11		TcsLine11	5
ChkId_24	FCCT_XPND1_HPS1_HCS6	FDIR LOW_NOP [°C] =-12	FDIR HIGH_NOP [°C] =52	time-out [sec]=64800	Cold Start Temp [°C] =-12	FDIR LOW_OP [°C] =-12	FDIR HIGH_OP [°C] =52	XPND1 TCS Failure HPS1_HCS6 DID_ASW_CCC_RES_2:10	TcsLine01	6	
ChkId_26	FCCT_FCV1B_HPS2_HCS2	FDIR LOW_NOP [°C] =-8	FDIR HIGH_NOP [°C] =50	time-out [sec]=64800	Cold Start Temp [°C] =-8	FDIR LOW_OP [°C] =-8	FDIR HIGH_OP [°C] =50	FCV1B TCS Failure HPS2_HCS2 DID_ASW_CCC_RES_2:6	This group of FCCT result is monitored by the Monitoring Entry with Id =27	TcsLine41	8
ChkId_27	FCCT_FCV2B_HPS2_HCS3	FDIR LOW_NOP [°C] =-8	FDIR HIGH_NOP [°C] =50	time-out [sec]=64800	Cold Start Temp [°C] =-8	FDIR LOW_OP [°C] =-8	FDIR HIGH_OP [°C] =50	FCV2B TCS Failure HPS2_HCS3 DID_ASW_CCC_RES_2:5		TcsLine42	9
ChkId_28	FCCT_FCV4B_HPS2_HCS4	FDIR LOW_NOP [°C] =-8	FDIR HIGH_NOP [°C] =50	time-out [sec]=64800	Cold Start Temp [°C] =-8	FDIR LOW_OP [°C] =-8	FDIR HIGH_OP [°C] =50	FCV4B TCS Failure HPS2_HCS4 DID_ASW_CCC_RES_2:4		TcsLine43	10
ChkId_29	FCCT_DPU_SPU_HPS2_HCS5	FDIR LOW_NOP [°C] =-25	FDIR HIGH_NOP [°C] =47	time-out [sec]=64800	Cold Start Temp [°C] =-25	FDIR LOW_OP [°C] =-17	FDIR HIGH_OP [°C] =47	FPDUI/SPU TCS Failure HPS2_HCS5 DID_ASW_CCC_RES_2:3		TcsLine05	11
ChkId_31	FCCT_FPBO1C_HPS3_HCS1	FDIR LOW_NOP [°C] =-21	FDIR HIGH_NOP [°C] =47	time-out [sec]=64800	Cold Start Temp [°C] =-21	FDIR LOW_OP [°C] =-17	FDIR HIGH_OP [°C] =47	FPBO1C TCS Failure HPS3_HCS1 DID_ASW_CCC_RES_3:15	This group of FCCT result is monitored by the Monitoring Entry with Id =33	TcsLine06	13
ChkId_32	FCCT_CRS_1_HPS3_HCS2	FDIR LOW_NOP [°C] =-43	FDIR HIGH_NOP [°C] =52	time-out [sec]=64800	Cold Start Temp [°C] =-43	FDIR LOW_OP [°C] =-43	FDIR HIGH_OP [°C] =52	CRS-1 TCS Failure HPS3_HCS2 Loop 07 DID_ASW_CCC_RES_3:14		TcsLine07	14

Doc No. : PT-HMOC-OPS-FOP-6001-OPS-OAH
Fop Issue : 3.0
Issue Date: 13/04/10

Status : Version 11 - Unchanged
Last Checkin: 15/09/09

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo

Check ID	Name	Param1	Param2	Param3	Param4	Param5	Param6	Output Flag	NOTE	TCS Line(ref. H-P-TN-AI-0069)	Loop Index (ref. to TCT)
CHKId_33	FCCT_FPDECMEC_HPS3_HCS3	FDIR LOW_NOP [°C] =-22	FDIR HIGH_NOP [°C] =47	time-out [sec]=64800	Cold Start Temp [°C] =-22	FDIR LOW_OP [°C] =-17	FDIR HIGH_OP [°C] =47	FPDECMEC TCS Failure HPS3_HCS3 DID_ASW_CCC_RES_3:13	This group of FCCT result is monitored by the Monitoring Entry with Id =33	TcsLine08	15
CHKId_34	FCCT_RCS pipe6_HPS3_HCS4	FDIR LOW_NOP [°C] =-20	FDIR HIGH_NOP [°C] =52	time-out [sec]=64800	Cold Start Temp [°C] =-20	FDIR LOW_OP [°C] =20	FDIR HIGH_OP [°C] =52	RCS piping #1 TCS Failure HPS3_HCS4 DID_ASW_CCC_RES_3:12		TcsLine09	16
CHKId_35	FCCT_CCU_HPS3_HCS5	FDIR LOW_NOP [°C] =-11	FDIR HIGH_NOP [°C] =42	time-out [sec]=64800	Cold Start Temp [°C] =-11	FDIR LOW_OP [°C] =11	FDIR HIGH_OP [°C] =42	CCU TCS Failure HPS3_HCS5 DID_ASW_CCC_RES_3:11		TcsLine10	17
CHKId_36	FCCT_GYRO_HPS1_HCS6	FDIR LOW_NOP [°C] =-9	FDIR HIGH_NOP [°C] =65	time-out [sec]=64800	Cold Start Temp [°C] =-9	FDIR LOW_OP [°C] =9	FDIR HIGH_OP [°C] =65	GYRO TCS Failure HPS1_HCS6 DID_ASW_CCC_RES_3:10	TcsLine38	18	
CHKId_38	FCCT_FHWOV_HPS4_HCS2	FDIR LOW_NOP [°C] =-20	FDIR HIGH_NOP [°C] =12	time-out [sec]=64800	Cold Start Temp [°C] =-20	FDIR LOW_OP [°C] =-2	FDIR HIGH_OP [°C] =12	FHWOV TCS Failure HPS4_HCS2 DID_ASW_CCC_RES_3:6	This group of FCCT result is monitored by the Monitoring Entry with Id =30	TcsLine12	20
CHKId_39	FCCT_RCS pipe6_HPS4_HCS3	FDIR LOW_NOP [°C] =-11	FDIR HIGH_NOP [°C] =52	time-out [sec]=64800	Cold Start Temp [°C] =-11	FDIR LOW_OP [°C] =11	FDIR HIGH_OP [°C] =52	RCS piping #6 TCS Failure HPS4_HCS3 DID_ASW_CCC_RES_3:5		TcsLine46	21
CHKId_40	FCCT_FCV1A1A_HPS4_HCS4	FDIR LOW_NOP [°C] =-8	FDIR HIGH_NOP [°C] =90	time-out [sec]=64800	Cold Start Temp [°C] =-8	FDIR LOW_OP [°C] =8	FDIR HIGH_OP [°C] =90	FCV 1A1A&1B TCS Failure HPS4_HCS4 DID_ASW_CCC_RES_3:4		TcsLine29	22
CHKId_41	FCCT_FCV C2A_HPS4_HCS5	FDIR LOW_NOP [°C] =-8	FDIR HIGH_NOP [°C] =90	time-out [sec]=64800	Cold Start Temp [°C] =-8	FDIR LOW_OP [°C] =8	FDIR HIGH_OP [°C] =90	FCV C2A&C2B TCS Failure HPS4_HCS5 DID_ASW_CCC_RES_3:3		TcsLine30	23
CHKId_42	FCCT_RCS pipe7_HPS4_HCS6	FDIR LOW_NOP [°C] =-11	FDIR HIGH_NOP [°C] =52	time-out [sec]=64800	Cold Start Temp [°C] =-11	FDIR LOW_OP [°C] =11	FDIR HIGH_OP [°C] =52	RCS piping #7 TCS Failure HPS4_HCS6 DID_ASW_CCC_RES_3:2		TcsLine46	24
CHKId_43	FCCT_CRS_2_HPS5_HCS1	FDIR LOW_NOP [°C] =-43	FDIR HIGH_NOP [°C] =52	time-out [sec]=64800	Cold Start Temp [°C] =-43	FDIR LOW_OP [°C] =43	FDIR HIGH_OP [°C] =52	CRS2 TCS Failure HPS5_HCS1 DID_ASW_CCC_RES_4:15		TcsLine49	25
CHKId_44	FCCT_FHRRH_HPS5_HCS2	FDIR LOW_NOP [°C] =-22	FDIR HIGH_NOP [°C] =31	time-out [sec]=64800	Cold Start Temp [°C] =-22	FDIR LOW_OP [°C] =25	FDIR HIGH_OP [°C] =31	FHRRH TCS Failure HPS5_HCS2 DID_ASW_CCC_RES_4:14		TcsLine18	26
CHKId_45	FCCT_FHWEVICU_HPS5_HCS3	FDIR LOW_NOP [°C] =-22	FDIR HIGH_NOP [°C] =32	time-out [sec]=64800	Cold Start Temp [°C] =-22	FDIR LOW_OP [°C] =-2	FDIR HIGH_OP [°C] =32	FHWEVICU TCS Failure HPS5_HCS3 DID_ASW_CCC_RES_4:13	This group of FCCT result is monitored by the Monitoring Entry with Id =45	TcsLine15	27
CHKId_46	FCCT_FCV C3B_HPS5_HCS4	FDIR LOW_NOP [°C] =-8	FDIR HIGH_NOP [°C] =90	time-out [sec]=64800	Cold Start Temp [°C] =-8	FDIR LOW_OP [°C] =8	FDIR HIGH_OP [°C] =90	FCV C3B TCS Failure HPS5_HCS4 DID_ASW_CCC_RES_4:12		TcsLine44	28
CHKId_47	FCCT_RCS pipe8_HPS5_HCS5	FDIR LOW_NOP [°C] =-10	FDIR HIGH_NOP [°C] =52	time-out [sec]=64800	Cold Start Temp [°C] =-10	FDIR LOW_OP [°C] =10	FDIR HIGH_OP [°C] =52	RCS piping #8 TCS Failure HPS5_HCS5 DID_ASW_CCC_RES_4:11		TcsLine47	29

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo

Check ID	Name	Param1	Param2	Param3	Param4	Param5	Param6	Output Flag	NOTE	TCS Lineref H.P. TN. AI-0069)	Loop Index (ref. to TCT)
ChkId_48	FCCT_PTLFLV12_HP55_HCS6	FDIR LOW_NOP [°C] =-7	FDIR HIGH_NOP [°C] =52	time-out [sec]=64800	Cold Start Temp [°C] =7	FDIR LOW_OP [°C] =7	FDIR HIGH_OP [°C] =52	PTLFLV12 TCS Failure HP55_HCS6 DID_ASW_CCC_RES_4:10	This group of FCCT result is monitored by the Monitoring Entry with Id =45	TcsLine48	30
ChkId_50	FCCT_RWL4_HPS6_HCS2	FDIR LOW_NOP [°C] =-6	FDIR HIGH_NOP [°C] =57	time-out [sec]=64800	Cold Start Temp [°C] =-6	FDIR LOW_OP [°C] =-2	FDIR HIGH_OP [°C] =57	RWL4 TCS Failure HPS6_HCS2 DID_ASW_CCC_RES_4:6	This group of FCCT result is monitored by the Monitoring Entry with Id =51	TcsLine22	32
ChkId_51	FCCT_RWL1_HPS6_HCS3	FDIR LOW_NOP [°C] =-6	FDIR HIGH_NOP [°C] =57	time-out [sec]=64800	Cold Start Temp [°C] =-6	FDIR LOW_OP [°C] =-2	FDIR HIGH_OP [°C] =57	RWL1 TCS Failure HPS6_HCS3 DID_ASW_CCC_RES_4:5			
ChkId_52	FCCT_RWL3_HPS6_HCS4	FDIR LOW_NOP [°C] =-6	FDIR HIGH_NOP [°C] =57	time-out [sec]=64800	Cold Start Temp [°C] =-6	FDIR LOW_OP [°C] =-2	FDIR HIGH_OP [°C] =57	RWL3 TCS Failure HPS6_HCS4 DID_ASW_CCC_RES_4:4			
ChkId_53	FCCT_FHIV_HPS6_HCS5	FDIR LOW_NOP [°C] =-12	FDIR HIGH_NOP [°C] =42	time-out [sec]=64800	Cold Start Temp [°C] =-12	FDIR LOW_OP [°C] =-12	FDIR HIGH_OP [°C] =42	FHIV TCS Failure HPS6_HCS5 DID_ASW_CCC_RES_4:3			
ChkId_54	FCCT_RWL2_HPS6_HCS6	FDIR LOW_NOP [°C] =-6	FDIR HIGH_NOP [°C] =57	time-out [sec]=64800	Cold Start Temp [°C] =-6	FDIR LOW_OP [°C] =-2	FDIR HIGH_OP [°C] =57	RWL2 TCS Failure HPS6_HCS6 DID_ASW_CCC_RES_4:2			
ChkId_55	FCCT_STRS_HPS7_HCS1	FDIR LOW_NOP [°C] =-10	FDIR HIGH_NOP [°C] =30	time-out [sec]=64800	Cold Start Temp [°C] =-10	FDIR LOW_OP [°C] =-3	FDIR HIGH_OP [°C] =30	STRS TCS Failure HPS7_HCS1 DID_ASW_CCC_RES_6:15			
ChkId_56	FCCT_BATTERY_HPS7_HCS2	FDIR LOW_NOP [°C] =-2	FDIR HIGH_NOP [°C] =37	time-out [sec]=64800	Cold Start Temp [°C] =-2	FDIR LOW_OP [°C] =-2	FDIR HIGH_OP [°C] =37	BATTERY TCS Failure HPS7_HCS2 DID_ASW_CCC_RES_6:14	This group of FCCT result is monitored by the Monitoring Entry with Id =57	TcsLine03	38
ChkId_57	FCCT_FHWOH_HPS7_HCS3	FDIR LOW_NOP [°C] =-15	FDIR HIGH_NOP [°C] =11	time-out [sec]=64800	Cold Start Temp [°C] =-15	FDIR LOW_OP [°C] =-1	FDIR HIGH_OP [°C] =11	FHWOH TCS Failure HPS7_HCS3 DID_ASW_CCC_RES_6:13			
ChkId_58	FCCT_FHWEH_HPS7_HCS4	FDIR LOW_NOP [°C] =-7	FDIR HIGH_NOP [°C] =32	time-out [sec]=64800	Cold Start Temp [°C] =-7	FDIR LOW_OP [°C] =-2	FDIR HIGH_OP [°C] =32	FHWEH TCS Failure HPS7_HCS4 DID_ASW_CCC_RES_6:12			
ChkId_59	FCCT_FCV C1A_HPS7_HCS5	FDIR LOW_NOP [°C] =-8	FDIR HIGH_NOP [°C] =90	time-out [sec]=64800	Cold Start Temp [°C] =-8	FDIR LOW_OP [°C] =8	FDIR HIGH_OP [°C] =90	FCV C1A&C1B TCS Failure HPS7_HCS5 DID_ASW_CCC_RES_6:11			
ChkId_60	FCCT_FCV A2A_HPS7_HCS6	FDIR LOW_NOP [°C] =-8	FDIR HIGH_NOP [°C] =90	time-out [sec]=64800	Cold Start Temp [°C] =-8	FDIR LOW_OP [°C] =8	FDIR HIGH_OP [°C] =90	FCV A2A&A2B TCS Failure HPS7_HCS6 DID_ASW_CCC_RES_6:10			
ChkId_61	FCCT_FHHRV_HPS8_HCS1	FDIR LOW_NOP [°C] =-25	FDIR HIGH_NOP [°C] =25	time-out [sec]=64800	Cold Start Temp [°C] =-25	FDIR LOW_OP [°C] =19	FDIR HIGH_OP [°C] =25	FHHRV TCS Failure HPS8_HCS1 DID_ASW_CCC_RES_6:7		TcsLine13	43
ChkId_62	FCCT_FCV C3A_HPS8_HCS2	FDIR LOW_NOP [°C] =-8	FDIR HIGH_NOP [°C] =90	time-out [sec]=64800	Cold Start Temp [°C] =-8	FDIR LOW_OP [°C] =8	FDIR HIGH_OP [°C] =90	FCV C3A&C3B TCS Failure HPS8_HCS2 DID_ASW_CCC_RES_6:6	This group of FCCT result is monitored by the Monitoring Entry	TcsLine34	44

TCS Subsystem Checkout
 File: H_FCP_TCS_CHECK.xls
 Author: E. Picallo

Check ID	Name	Param1	Param2	Param3	Param4	Param5	Param6	Output Flag	NOTE	TCS Line(ref. H-P-TN-AL0069)	Loop Index (ref. to TCT)
ChMid_63	FCCT_RCS pipe3_HP58_HCS3	FDIR LOW_NOP [°C] =11	FDIR HIGH_NOP [°C] =52	time-out [sec]=64800	Cold Start Temp [°C] =11	FDIR LOW_OP [°C] =11	FDIR HIGH_OP [°C] =52	RCS piping #3 TCS Failure HP58_HCS3 DID_ASW_CCC_RES_6:5	with Id=63	TcsLine35	45
ChMid_64	FCCT_STR2_PBBF_HP58_HCS4	FDIR LOW_NOP [°C] =-23.5	FDIR HIGH_NOP [°C] =30	time-out [sec]=64800	Cold Start Temp [°C] =-23.5	FDIR LOW_OP [°C] =11	FDIR HIGH_OP [°C] =30	STR 2 Primary Baffle TCS Failure HP58_HCS4 DID_ASW_CCC_RES_6:4		TcsLine36	46
ChMid_65	FCCT_RCS pipe5_HP58_HCS5	FDIR LOW_NOP [°C] =16	FDIR HIGH_NOP [°C] =52	time-out [sec]=64800	Cold Start Temp [°C] =16	FDIR LOW_OP [°C] =16	FDIR HIGH_OP [°C] =52	RCS piping #5 TCS Failure HP58_HCS5 DID_ASW_CCC_RES_6:3		TcsLine37	47
ChMid_66	FCCT_FHLCU_HP58_HCS6	FDIR LOW_NOP [°C] =-20	FDIR HIGH_NOP [°C] =42	time-out [sec]=64800	Cold Start Temp [°C] =-20	FDIR LOW_OP [°C] =8	FDIR HIGH_OP [°C] =42	FHLCU TCS Failure HP58_HCS6 DID_ASW_CCC_RES_6:2		TcsLine19	48
ChMid_68	FCCT_Tank+Y_HP59_HCS2	FDIR LOW_NOP [°C] =8	FDIR HIGH_NOP [°C] =40	time-out [sec]=64800	Cold Start Temp [°C] =8	FDIR LOW_OP [°C] =8	FDIR HIGH_OP [°C] =40	Tank+Y TCS Failure HP59_HCS2 DID_ASW_CCC_RES_5:14		TcsLine26	50
ChMid_69	FCCT_FCV CAA_HP59_HCS3	FDIR LOW_NOP [°C] =8	FDIR HIGH_NOP [°C] =90	time-out [sec]=64800	Cold Start Temp [°C] =8	FDIR LOW_OP [°C] =8	FDIR HIGH_OP [°C] =90	FCV CAA&CAB TCS Failure HP59_HCS3 DID_ASW_CCC_RES_5:13		TcsLine33	51
ChMid_70	FCCT_FHLSU_HP59_HCS4	FDIR LOW_NOP [°C] =-13	FDIR HIGH_NOP [°C] =37	time-out [sec]=64800	Cold Start Temp [°C] =-13	FDIR LOW_OP [°C] =8	FDIR HIGH_OP [°C] =37	FHLSU TCS Failure HP59_HCS4 DID_ASW_CCC_RES_5:12	This group of FCCT result is monitored by the Monitoring Entry with Id =69	TcsLine20	52
ChMid_71	FCCT_STR1_PBBF_HP59_HCS5	FDIR LOW_NOP [°C] =-23.5	FDIR HIGH_NOP [°C] =30	time-out [sec]=64800	Cold Start Temp [°C] =-23.5	FDIR LOW_OP [°C] =11	FDIR HIGH_OP [°C] =30	STR_1 Primary Baffle TCS Failure HP59_HCS5 DID_ASW_CCC_RES_5:11		TcsLine14	53
ChMid_72	FCCT_Tank+Y_HP59_HCS6	FDIR LOW_NOP [°C] =8	FDIR HIGH_NOP [°C] =40	time-out [sec]=64800	Cold Start Temp [°C] =8	FDIR LOW_OP [°C] =8	FDIR HIGH_OP [°C] =40	Tank+Y TCS Failure HP59_HCS6 DID_ASW_CCC_RES_5:10		TcsLine25	54
ChMid_73	FCCT_ins_TM_Monitoring	Delta T = 30sec=30	Not Used	Not Used	Not Used	Not Used	Not Used	DID_ASW_PACS_TM_CN DID_ASW_SPIRE_TM_CN DID_ASW_HFI_TM_CNT DID_ASW_HFL_TM_CNT DID_ASW_SCS_TM_CNT DID_ASW_LFI_TM_CNT	The Delta-T parameter is used by the ASW define a period to update the instrument TM counters. Every delta-T exceeds the ASW computes the difference between previous value and current value of instrument TM counters. The difference is then put into the listed Data Pool Id and monitored by MOT.	N/A	N/A